

We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,900

Open access books available

185,000

International authors and editors

200M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities



WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com



Semi Analytical Analysis of Steady State Condition of Steam Generator

Zaki Su'ud

*Nuclear Reactor Research Group, Bandung Institute of Technology,
Jl. Ganesha no 10, Bandung
Indonesia*

1. Introduction

Steam generator is an important device in power plant. Steam generator use the heat to produce steam which then used to drive turbine for producing electricity. Various thermal related processes occurs in steam generator during its normal operation and also during abnormal or accident condition. Therefore perfect treatment of steam generator will include various complex mathematical model which need computational fluid dynamics. However in this chapter we will simplify the model which still give reasonable results. There are many types of steam generators. Figure 1 shows an example of counter flow type steam generator in which hot liquid flow outside the cylinders from top to the bottom while the water-steam flows inside the pipes from the bottom to the top of the steam generator.




Fig. 1. Simplified schematic of counter flow heat exchanger

2. Mathematical model

The mathematical model of steam generators includes energy conservation equations, momentum conservation equations, and mass conservation equations.

2.1 Energy conservation equations

$$\begin{aligned} c_{p,p} W_p \frac{\partial T_p}{\partial z} - A_p \frac{\partial}{\partial z} (k_p \frac{\partial T_p}{\partial z}) &= -h_p S_p (T_p - T_W) \\ -\pi(r_{Wo}^2 - r_{Wi}^2) \frac{\partial}{\partial z} (k_W \frac{\partial T_W}{\partial z}) &= h_p S_p (T_p - T_W) - h_s S_s (T_W - T_s) \\ c_{p,s} W_s \frac{\partial T_s}{\partial z} - A_s \frac{\partial}{\partial z} (k_s \frac{\partial T_s}{\partial z}) &= -h_s S_s (T_W - T_s) \end{aligned} \quad (1)$$

2.2 Momentum conservation equation

$$\begin{aligned} \frac{\partial}{\partial z} \left(\frac{G_p^2}{\rho_p} \right) &= -\frac{\partial p_p}{\partial z} - \frac{f_p}{2\rho_p} D_p |G_p| G_p - \rho_p g \\ \frac{\partial}{\partial z} \left(\frac{G_s^2}{\rho_s} \right) &= -\frac{\partial p_s}{\partial z} - \frac{f_s}{2\rho_s} D_s |G_s| G_s - \rho_s g \end{aligned} \quad (2)$$

2.3 Mass conservation equation

$$\begin{aligned} \frac{\partial G_p}{\partial z} &= 0 \\ \frac{\partial G_s}{\partial z} &= 0 \end{aligned} \quad (3)$$

3. Analytic solution of steady state condition of steam generator

In steam generators, liquid in the primary side is in single phase condition while the liquid in the secondary side change from sub cooled condition, then saturated condition, and then entering super heated steam condition in the last stage.

We will first discuss the analytical solution for single phase counter flow heat exchanger system. The results will be used to analyse some part of steam generator segments.

3.1 Analytical solution of counter flow single phase heat exchanger

Energy conservation equations for single phase counter flow heat exchanger is

$$\begin{aligned} c_{p,p} W_p \frac{\partial T_p}{\partial z} - A_p \frac{\partial}{\partial z} (k_p \frac{\partial T_p}{\partial z}) &= -h_p S_p (T_p - T_W) \\ -\pi(r_{Wo}^2 - r_{Wi}^2) \frac{\partial}{\partial z} (k_W \frac{\partial T_W}{\partial z}) &= h_p S_p (T_p - T_W) - h_s S_s (T_W - T_s) \\ c_{p,s} W_s \frac{\partial T_s}{\partial z} - A_s \frac{\partial}{\partial z} (k_s \frac{\partial T_s}{\partial z}) &= -h_s S_s (T_W - T_s) \end{aligned} \quad (4)$$

If the wall is thin and has good heat conduction capability we can simplify the model by eliminating the wall and include its effect in the overall heat transfer coefficient.

$$\begin{aligned} c_{p,p}W_p \frac{\partial T_p}{\partial z} - A_p \frac{\partial}{\partial z} \left(k_p \frac{\partial T_p}{\partial z} \right) &= -h_{eff}S_p(T_p - T_s) \\ c_{p,s}W_s \frac{\partial T_s}{\partial z} - A_s \frac{\partial}{\partial z} \left(k_s \frac{\partial T_s}{\partial z} \right) &= -h_{eff}S_s(T_p - T_s) \end{aligned} \quad (5)$$

Where h_{eff} is overall heat transfer coefficient from primary side to secondary side including the effect of the wall.

In normal condition, usually the effect of heat conduction is small so that we can further simplify the model into:

$$\begin{aligned} c_{p,p}W_p \frac{\partial T_p}{\partial z} &= -h_{eff}S_p(T_p - T_s) \\ c_{p,s}W_s \frac{\partial T_s}{\partial z} &= -h_{eff}S_s(T_p - T_s) \end{aligned} \quad (6)$$

In this stage we set the analytic solution of the above model as

$$\begin{aligned} T_p(z) &= Ae^{kz} + Be^{-kz} \\ T_s(z) &= Ce^{kz} + De^{-kz} \end{aligned} \quad (7)$$

Substituting equation (7) into (6) we get

$$\begin{aligned} A &= \frac{h_p S_p}{kc_{p,p}W_p + h_p S_p} C \\ B &= \frac{h_p S_p}{h_p S_p - kc_{p,p}W_p} D \end{aligned} \quad (8)$$

And,

$$\begin{aligned} h_{eff}^2 S_p S_s &= (kc_{p,p}W_p + h_{eff}S_p)(kc_{p,s}W_s + h_{eff}S_s) \\ k &= \frac{1}{c_{p,p}W} + \frac{1}{c_{p,s}W} \end{aligned} \quad (9)$$

Now we apply boundary condition:

$$\begin{aligned} T_p(0) &= T_{p_{in}} \\ T_s(H) &= T_{s_{in}} \end{aligned} \quad (10)$$

And we get

$$\begin{aligned} A + B &= T_{p_{in}} \\ Ce^{kH} + De^{-kH} &= T_{s_{in}} \end{aligned}$$

Substituting A,B, C and D we get

$$\begin{aligned} C &= \frac{T_{p,in}e^{-kH} - \eta_2 T_{s,in}}{\eta_1 e^{-kH} - \eta_2 e^{kH}} \\ D &= \frac{\eta_1 T_{s,in} - T_{p,in}e^{kH}}{\eta_1 e^{-kH} - \eta_2 e^{kH}} \\ \eta_1 &= \frac{h_{eff} S_p}{kc_{p,p}W_p + h_{eff} S_p} \\ \eta_2 &= \frac{h_{eff} S_p}{h_{eff} S_p - kc_{p,p}W_p} \\ A &= \eta_1 C \\ B &= \eta_2 C \end{aligned} \tag{11}$$

3.2 Analytical solution of counter flow steam generator

In steam generator we can in general divide it into three regions: sub cooled region, saturated region, and super heated region, see figure 1. In sub cooled region the water-steam side is in the form of water and the steam generator can be treated using the method developed in section 2.1




Fig. 2. Simplified model of single channel concentric tubes

In saturated region the water-steam side of SG experiences boiling process, a conversion of water into steam at constant temperature. After all water has been converted into steam then in the super heated section the water-steam side is in the form of steam which experiences temperature increase as it receive heat from the primary side. In this region we can also apply the method developed in section 2.1.

The boundary position between sub cooled region and saturated region and between saturated region and superheated region are influenced by many parameters such as inlet temperature of primary and secondary sides, flowrates in primary and secondary sides, thermal properties of primary and secondary sides, pipes properties, etc. Therefore we use iterative method to determine these boundary positions.

The method to determine these boundary positions is as follows. First we guess these two boundaries and based on these assumption we perform energy balance analysis for this simplified model.

Then we start with upper part in which the primary inlet temperature is $T_{p_{in}}$ and while the secondary inlet temperature is just water saturation temperature. Using the formulated in 2.1 we get primary and secondary temperature distribution. From this stage we get primary outlet temperature.

Next we move to the saturated region. Based on the just previous calculation we use the previous primary outlet temperature as primary inlet temperature in saturated region. The secondary inlet temperature is water-steam saturated temperature in which the water is started to boil. From this stage of calculation we get primary and secondary temperature distributions.

Finally we can set primary site inlet temperature for the sub cooled region from the primary outlet temperature in the saturated region. The secondary outlet temperature in the subcooled region is just the water channel inlet temperature. Therefore we can get temperature distribution for the sub cooled region and therefore we now get for all regions.

Now we must check energy balance consistency in sub cooled and saturated regions. First we check whether or not the heat received by secondary side in the sub cooled region is exactly same with that needed to change the intake sub cooled water to the start of saturation condition.

In case that the heat from the primary side is not enough to increase the sub cooled temperature into saturated temperature then we need to shift the assumption of boundary between sub cooled and saturated regions to be higher than the current position. On the other hand if the saturated condition of water-steam side has been reached before the current sub cooled - saturated regions then we should decrease the boundary.

Similar judgment must be taken for boundary between saturated and super heated regions.

For the saturated region, the energy balance equation can be written as

$$\begin{aligned} c_{p,p} W_p \frac{\partial T_p}{\partial z} &= -h_{eff} S_p (T_p - T_s) \\ c_{p,s} W_s \frac{\partial T_s}{\partial z} &= -h_{eff} S_s (T_p - T_s) \\ T_s &= \text{saturated temperature} \end{aligned} \quad (12)$$

We can rearrange the equation (12) as

$$\begin{aligned} c_{p,p}W_p \frac{\partial T_p}{\partial z} + h_{eff}ST_p &= h_{eff}ST_s \\ c_{p,p}W_p \frac{\partial T_p}{\partial z} e^{\alpha z} + h_{eff}ST_p e^{\alpha z} &= h_{eff}ST_s e^{\alpha z} \\ \frac{d}{dz}(\beta T_p e^{\alpha z}) &= h_{eff}ST_s e^{\alpha z} \end{aligned} \quad (13)$$

where

$$\begin{aligned} \beta &= c_{p,p}W_p \\ \alpha &= \frac{h_s S}{c_{p,p}W_p} \end{aligned} \quad (14)$$

Solving (13) we get

$$T_p(z) = T_s + \frac{C}{\beta} e^{-\alpha z}$$

Introducing boundary condition $T_p(0)=T_{p0}$ then we get

$$T_p(z) = T_s + (T_{p0} - T_s) e^{-\frac{h_s S}{c_{p,p}W_p} z}$$

where C is a constant.

Note that z is assumed started at the boundary between saturated and super heated region.

For the sub cooled region as in super heated region we can use the method describe in the section of 2.1.

3.3 Algorithm and program for semi analytical method of steam generator analysis

The algorithm to solve counter flow steam generator system is as follows

- Set an assumption of boundary between sub-cooled region and saturated region and also between saturated region and super heated region.
- Calculate temperature distribution in the superheated region using the method described in the section 2.1 and using inlet primary liquid temperature as $T_{p,in}$ and water saturated temperature as secondary side inlet temperature
- Calculate temperature distribution along primary side of saturated region using the method describe in the section 2.2 using primary side outlet temperature of super heated section as primary inlet temperature
- Calculate temperature distribution in the sub-cooled region using the method described in the section 2.1 and using primary side outlet temperature of saturated region as $T_{p,in}$ and water inlet temperature secondary side inlet temperature
- Check consistency of the assumed boundary. Is secondary side in sub-cooled region reach transition between sub-cooled and saturated region at the end of this region? Is secondary side of saturated region reaches transition between saturated region and super heated region at the end of this region?

- f. If the consistency check in e. is fail then we have to readjust the assumption considering the results in e, other wise the boundaries are right and the calculation is finished.

Here the program in Fortran language to solve this problem.

For initialization process:

```

c
c This subroutine is to calculate thermohydraulic of Steam Generator
c using semi analytical method
c
subroutine semansg
  INCLUDE "common1.f"
  write(6,*)'enter anasg routine:tp,ts',tpin,tsin
  astp=ssgs
  psys=psyst
  tsat=temsw(psys)-273.15
  enthfl=entw(psys)
  enthgs=entstv(psys)
  enthfg=enthgs-enthfl
  tpout=tsin
  tsout=tpin
  mxz=maxsub+maxsat+maxsph
  mx2=maxsub+maxsat
  gp=wp
  gs=ws
  tsin=tsin0
c
c superheated region preparation, setting parameters
c
  tsin=tsat
  tpav=(tpin+tsat)/2.0
  tsav=(tsout+tsat)/2.0
  tpsav=(tpav+2.0*tsav)/3.0
  hshv=entshv(psys,tsav)
  cpp=cpc(tpav)
  cps=cpslv(hshv,psys)
  cpp1=cpp
  cps1=cps
  diam=2.0*ro
  a1=3.0**0.5/4.0*pitcsg**2-3.14159*diam**2/8.0
  pw1=3.14159*diam/2.0
  dep=4.0*a1/pw1
  de=dep
  des=2.0*ri
  rep=gp/asgp*dep/visc(tpav)
  prp=visc(tpav)*cpc(tpav)/conc(tpav)
  pecp=rep*prp

```



```

pod=pitcsg/diam
xnusp=7.55*pod-6.3/pod**(17*pod*(pod-0.81))
xnusp=xnusp+0.0174*(1.0-exp(-6.0*(pod-1.0)))*(pecp-200.0)**0.9
hpp=xnusp*conc(tpav)/dep
res=gs/asgs*des/visshv(hshv,psys)
prs=visshv(hshv,psys)*cpshv(hshv,psys)/conshv(hshv,psys)
xnus=0.024*res**0.8*prs**0.4
hss=0.5*xnus*conshv(hshv,psys)/ri
hmt=2.0*3.14159*conm(tpsav)/alog(ro/ri)
u=1.0/(1.0/hpp+1.0/hss+astp/hmt)
u1=u
tmp1=-6.28*ro*u*ztsg*(1.0/(gs*cps)-1.0/(gp*cpp))
tmp2=-6.28*ro*u*(1.0/(gs*cps)-1.0/(gp*cpp))
tsin=tsat
aa=(tpin-tsin)/(exp1(tmp1)-gp*cpp/(gs*cps))
bb=tpin-(tpin-tsin)/(1.0-gp*cpp/(gs*cps)/exp1(tmp1))
bb1=tsin-gp*cpp/(gs*cps)*aa

```

c

c saturated region preparation, setting parameters

c

```

tpav=(tsgp(mx2)+tsat)/2.0
tsav=tsat
tpsav=(tpav+2.0*tsav)/3.0
cpp=cpc(tpav)
cpp2=cpp
rep=gp/asgp*dep/visc(tpav)
prp=visc(tpav)*cpc(tpav)/conc(tpav)
pecp=rep*prp
pod=pitcsg/diam
xnusp=7.55*pod-6.3/pod**(17*pod*(pod-0.81))
xnusp=xnusp+0.0174*(1.0-exp(-6.0*(pod-1.0)))*(pecp-200.0)**0.9
hpp=xnusp*conc(tpav)/dep
hmt=2.0*3.14159*conm(tpsav)/alog(ro/ri)
u2=1.0/(1.0/hpp+astp/hmt)

```

c

c subcooled region preparation, setting parameters

c

```

tpav=(tsgp(maxsub)+tsin0)/2.0
tsav=(tsgp(maxsub)+tsin0)/2.0
tpsav=(tpav+2.0*tsav)/3.0
tsub=(tsin0+tsat)/2.0
hsbw=entsbw(psys,tsub)
cpp=cpc(tpav)
rep=gp/asgp*dep/visc(tpav)
prp=visc(tpav)*cpc(tpav)/conc(tpav)
pecp=rep*prp

```

```

pod=pitcsg/diam
xnusp=7.55*pod-6.3/pod**(17*pod*(pod-0.81))
xnusp=xnusp+0.0174*(1.0-exp(-6.0*(pod-1.0)))*(pecp-200.0)**0.9
hpp=xnusp*conc(tpav)/dep
cpp3=cpp
cps3=cpw(hsbw,psys)
res=gs/asgs*des/visw(hsbw,psys)
prs=visw(hsbw,psys)*cpw(hsbw,psys)/conw(hsbw,psys)
xnus=0.024*res**0.8*prs**0.4
hss=0.5*xnus*conw(hsbw,psys)/ri
hmt=2.0*3.14159*conm(tpsav)/alog(ro/ri)
u3=1.0/(1.0/hpp+1.0/hss+astp/hmt)

```

The following iteration routine is used to calculate temperature distribution across steam generators iteratively until the consistency check become successful.

```

c
c  searching routine
c
  tsgpa=tsat
  tsgsa=tsat
  tsgpb=tsat
  tsgsb=tsat
  tsgpo=tsin
  tsgso=tpin
  aboun0=aboun
  bboun0=bboun
  numblp=0
c
c  super heated region -> iteration
c
50 tsin=tsat
  tpav=(tpin+tsgpb)/2.0
  tsav=(tsgso+tsat)/2.0
  tpsav=(tpav+2.0*tsav)/3.0
  cpp1=cpc(tpav)
  hshv=entshv(psys,tsav)
  cps1=cpshv(hshv,psys)
  cpp=cpc(tpav)
  cps=cpshv(hshv,psys)
  cpp1=cpp
  cps1=cps
  rep=gp/asgp*dep/visc(tpav)
  prp=visc(tpav)*cpc(tpav)/conc(tpav)
  pecp=rep*prp
  xnusp=7.55*pod-6.3/pod**(17*pod*(pod-0.81))
  xnusp=xnusp+0.0174*(1.0-exp(-6.0*(pod-1.0)))*(pecp-200.0)**0.9

```

```

hpp=xnusp*conc(tpav)/dep
res=gs/asgs*des/visshv(hshv,psys)
prs=visshv(hshv,psys)*cpshv(hshv,psys)/conshv(hshv,psys)
xnus=0.024*res**0.8*prs**0.4
hss=0.5*xnus*conshv(hshv,psys)/ri
hmt=2.0*3.14159*conm(tpsav)/alog(ro/ri)
u1=1.0/(1.0/hpp+1.0/hss+astp/hmt)
write(6,*)'tpav,tsav,xnus,hpp,hss,hmt,u1:'
write(6,*)'tpav,tsav,xnus,hpp,hss,hmt,u1'
c
c saturated region -> iteration
c
tpav=(tsgpa+tsgpb)/2.0
tsav=tsat
tpsav=(tpav+2.0*tsav)/3.0
cpp2=cpc(tpav)
rep=gp/asgp*dep/visc(tpav)
prp=visc(tpav)*cpc(tpav)/conc(tpav)
pecp=rep*prp
pod=pitcsg/diam
xnusp=7.55*pod-6.3/pod**(17*pod*(pod-0.81))
xnusp=xnusp+0.0174*(1.0-exp(-6.0*(pod-1.0)))*(pecp-200.0)**0.9
hpp=xnusp*conc(tpav)/dep
hmt=2.0*3.14159*conm(tpsav)/alog(ro/ri)
u2=1.0/(1.0/hpp+astp/hmt)
write(6,*)'tpav,tsav,xnus,hpp,hmt,u2:'
write(6,*)'tpav,tsav,xnus,hpp,hmt,u2'
c
c subcooled region -> iteration
c
tpav=(tsgpo+tsgpa)/2.0
tsav=(tsat+tsin0)/2.0
tpsav=(tpav+2.0*tsav)/3.0
tavsb=(tsin0+tsat)/2.0
hsbw=entsbw(psys,tavsb)
cpp3=cpc(tpav)
cps3=cpw(hsbw,psys)
res=gs/asgs*des/visw(hsbw,psys)
prs=visw(hsbw,psys)*cpw(hsbw,psys)/conw(hsbw,psys)
xnus=0.024*res**0.8*prs**0.4
hss=0.5*xnus*conw(hsbw,psys)/ri
cpp=cpc(tpav)
rep=gp/asgp*dep/visc(tpav)
prp=visc(tpav)*cpc(tpav)/conc(tpav)
pecp=rep*prp
xnusp=7.55*pod-6.3/pod**(17*pod*(pod-0.81))

```

```

xnu sp=xnu sp+0.0174*(1.0-exp(-6.0*(pod-1.0)))*(pecp-200.0)**0.9
hpp=xnu sp*conc(tpav)/dep
hmt=2.0*3.14159*conm(tavsb)/log(ro/ri)
u3=1.0/(1.0/hpp+1.0/hss+astp/hmt)
write(6,*)'tpav,tsav,xnu s,hss,hpp,hmt,u3:'
write(6,*)tpav,tsav,xnu s,hss,hpp,hmt,u3
tmp1=-6.28*ro*u1*(ztsg-bboun)*(1.0/(gs*cps1)-1.0/(gp*cpp1))
tmp2=-6.28*ro*u1*(1.0/(gs*cps1)-1.0/(gp*cpp1))
aa1=(tpin-tsav)/(exp1(tmp1)-gp*cpp1/(gs*cps1))
bb1=tpin-(tpin-tsav)/(1.0-gp*cpp1/(gs*cps1)/exp1(tmp1))
tsgpb=(tpin-tsav)/(exp1(tmp1)-gp*cpp1/(gs*cps1))+bb1
tmpsat=6.28*ro*u2/(gp*cpp2)*(bboun-aboun)
tsgpa=tsav+(tsgpb-tsav)*exp1(-tmpsat)
tmp3=-6.28*ro*u3*aboun*(1.0/(gs*cps3)-1.0/(gp*cpp3))
tmp4=-6.28*ro*u3*(1.0/(gs*cps3)-1.0/(gp*cpp3))
aa3=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))
bb3=tsgpa-(tsgpa-tsin0)/(1.0-gp*cpp3/(gs*cps3)/exp1(tmp3))
tsgsa=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))*
&      gp*cpp3/(gs*cps3)*exp1(tmp4*aboun)+bb3
hqq=(tsgpb-tsav)*gp*cpp2*(1.0-exp1(-tmpsat))/gs
aa=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))
bb=tsgpa-(tsgpa-tsin0)/(1.0-gp*cpp3/(gs*cps3)/exp1(tmp3))
zzz=0.0
tsgpo=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))*
&      exp1(tmp4*zzz)+bb
aa=(tpin-tsav)/(exp1(tmp1)-gp*cpp1/(gs*cps1))
bb=tpin-(tpin-tsav)/(1.0-gp*cpp1/(gs*cps1)/exp1(tmp1))
zzz=ztsg
tsgso=(tpin-tsav)/(exp1(tmp1)-gp*cpp1/(gs*cps1))*
&      gp*cpp1/(gs*cps1)*exp1(tmp2*zzz)+bb
errp=1.0+errstd
errm=1.0-errstd
c
c Checking the consistency
c
c
c if (hqq.lt.errm*enthfg) then
c   if (tsgsa.gt.errp*tsav) then
c     aboun=aboun-daboun
c   else
c     bboun=bboun+dbboun
c   endif
c   if (tsgsa.lt.errm*tsav) then
c     aboun=aboun+daboun
c   endif
c endif

```

```

    if (hqq.gt.errp*enthfg) then
      if (tgsa.gt.errp*tsat) then
        aboun=aboun-daboun
        bboun=bboun-dbboun
      else
        bboun=bboun-dbboun
      endif
    endif
  endif
c
c If all consistent then finish, otherwise readjust the boundary between
c sub-cooled region and saturated region and between saturated region and
c super heated region
c
  if ((abs(tgsa-tsat).lt.errstd*tsat).and.
& (abs(hqq-enthfg).lt.errstd*enthfg)) goto 90
  if ((abs(hqq-enthfg).lt.errstd*enthfg).and.
& (tgsa.gt.errp*tsat)) aboun=aboun-daboun
  if ((abs(hqq-enthfg).lt.errstd*enthfg).and.
& (tgsa.lt.errm*tsat)) aboun=aboun+daboun
  if (aboun.lt.0.0) aboun=0.0
  if (bboun.lt.0.0) aboun=0.0
  if (aboun.gt.ztsg) aboun=ztsg
  if (bboun.gt.ztsg) bboun=ztsg
  numblp=numblp+1
write(6,*)'loop number :',numblp,maxlop
  if (numblp.gt.maxlop) goto 90
  if (numblp.eq.1) then
    tgsao=tgsa
    hqqo=hqq
    goto 50
  endif
  tcheck=(tgsao-tsat)*(tgsa-tsat)
  qcheck=(hqqo-enthfg)*(hqq-enthfg)
  if (numblp.eq.2) then
    tgsao=tgsa
    hqqo=hqq
    tcheco=tcheck
    qcheco=qcheck
    goto 50
  endif
  tcheco=tcheck
  qcheco=qcheck
  if ((tcheck.lt.0.0).and.(tcheco.lt.0.0)) then
    daboun=daboun/2.0
  endif
  if ((qcheck.lt.0.0).and.(qcheco.lt.0.0)) then

```

```

        dbboun=dbboun/2.0
    endif
    tsgsao=tsgsa
    hqqo=hqq
    goto 50
c
c After convergent calculate final temperature distribution across
c primary and secondary sides and also estimation of wall temperature
c distribution
c
90 max1=int(aboun/ztsq*mxz)
    if (zsg(max1+1).lt.aboun) max1=max1+1
    max2=int(bboun/ztsq*mxz)
    if (zsg(max2+1).lt.bboun) max2=max2+1
    aa=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))
    bb=tsgpa-(tsgpa-tsin0)/(1.0-gp*cpp3/(gs*cps3)/exp1(tmp3))
    do 60 i=1,max1
        zzz=zsg(i)
        tsgp(i)=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))*
&        exp1(tmp4*zzz)+bb
        tsgs(i)=(tsgpa-tsin0)/(exp1(tmp3)-gp*cpp3/(gs*cps3))*
&        gp*cpp3/(gs*cps3)*exp1(tmp4*zzz)+bb
        tsgm(i)=(tsgp(i)+tsgs(i))/2.0
c    write(6,*)i,zzz,tsgp(i),tsgs(i),tsgm(i)
    60 continue
    do 70 i=max1+1,max2
        zzz=(zsg(i)-bboun)/(bboun-aboun)
        tsgp(i)=(tsgpb-tsatsat)*exp1(tmptsat*zzz)+tsatsat
        tsgs(i)=tsatsat
        tsgm(i)=(tsgp(i)+tsgs(i))/2.0
    70 continue
    aa=(tpin-tsatsat)/(exp1(tmp1)-gp*cpp1/(gs*cps1))
    bb=tpin-(tpin-tsatsat)/(1.0-gp*cpp1/(gs*cps1)/exp1(tmp1))
    do 80 i=max2+1,mxz
        zzz=zsg(i)-bboun
        tsgp(i)=(tpin-tsatsat)/(exp1(tmp1)-gp*cpp1/(gs*cps1))*
&        exp1(tmp2*zzz)+bb
        tsgs(i)=(tpin-tsatsat)/(exp1(tmp1)-gp*cpp1/(gs*cps1))*
&        gp*cpp1/(gs*cps1)*exp1(tmp2*zzz)+bb
        tsgm(i)=(tsgp(i)+tsgs(i))/2.0
c    write(6,*)i,zsg(i),tsgp(i),tsgs(i),tsgm(i)
    80 continue
    i=1
    write(6,*)i,zsg(i),tsgp(i),tsgs(i),tsgm(i)
    i=mxz
    write(6,*)i,zsg(i),tsgp(i),tsgs(i),tsgm(i)

```

```
call pdrsg
100 format(i5,f8.2,2x,f12.4,2x,f12.4)
return
end
c
```

This is the end of the program.

3.4 Examples of calculation results

In this example the primary side is lead-bismuth eutectic liquid metal while the secondary side is water-steam system. The system parameters are shown in the following table

Parameter	Value
Height (m)	4
Inner radius of pipe (cm)	1.1
Outer radius of pipe (cm)	1.25
Pipe pitch(cm)	4
Primary side flow rate (kg/s)	2250
Secondary side flow rate (kg/s)	30
Number of bundles	200
Secondary side inlet temperature (C)	225
Primary side inlet temperature (C)	510
System pressure(MPa)	7

Table 1. Steam generator parameters for calculation example

The calculation results is shown in the following figure




Fig. 3. Example of heat exchanger semi analytical analysis

3.5 Discussion and application

It is important to note that many thermal-hydraulic related constants for liquid metal Pb-Bi and water-steam system must be obtained and used during analysis. Such data can be obtained from references, e.g references number 1-5. In the program given in section 2.3 some thermal hydraulic constants are calculated using specific function such as

- temsw(P) : to calculate water-steam system saturated temperature
- entshv(psys,tsav): to calculate enthalphy of super heated vapour
- cpc(tp):to calculate specific heat of primary coolant
- conc(tp):to calculate thermal conductivity of primary coolant
- visshv(hshv,psys): to calculate viscosity of super heated vapour
- conshv(hshv,psys): to calculate thermal conductivity of super heated vapour

To calculate the pressure drop across the pipe inner and outer we can integrate the momentum balance equation. In general we have gravitational, friction, acceleration, and form related pressure drop components and we need specific correlation for friction and form pressure drop. To calculate this we can use the correlation from the references: 1,3,4,5. The data from the third reference is useful especially when we have the flow regime is in transition between laminar and turbulence.


The semi analytical analysis of steam generator in a certain level can be used for transient analysis of power system for example as long as the transient is relatively slow so that quasi-static approach can be adopted.

To get more accurate steam generator analysis we can use direct numerical solution of equations 1-3 and use the result of semi analytical analysis as initial guess of primary and

secondary side temperature distributions. In general the results from semi analytical analysis has good accuracy compared to that from direct numerical calculations.

4. References

- [1] Kakac, S. et al. (1997) Handbook of Single-Phase Convective Heat transfer, John Wiley & Sons.
- [2] Raznjevic (1976) Handbook of Thermodynamic Tables and Charts, Hemisphere, Washington.
- [3] Cheng, S.K., Todreas, N.E., (1986) Hydrodynamic models and correlations for bare and wire-wrapped hexagonal rod bundles, *Nucl. Eng. Des.*, 92, 227.
- [4] Coffield, R.D., Markley, R.A., (1980), Natural convection analysis and verification for LMFBR cores, *Nucl. Eng. Des.*, 62, 181-198.
- [5] Guppy, J.G., (1993), Super System Code, NUREG/CR-3169.
- [6] Zaki S., Sekimoto, H. (1996), Accident Analysis of Lead or Lead-Bismuth Cooled Small Safe Long-Life Fast Reactor using Metallic or Nitride Fuel, *J. Nucl. Eng. And Design*, 162, Elsevier Science, 205-222.



Steam Generator Systems: Operational Reliability and Efficiency

Edited by Dr. Valentin Uchanin

ISBN 978-953-307-303-3

Hard cover, 424 pages

Publisher InTech

Published online 16, March, 2011

Published in print edition March, 2011

The book is intended for practical engineers, researchers, students and other people dealing with the reviewed problems. We hope that the presented book will be beneficial to all readers and initiate further inquiry and development with aspiration for better future. The authors from different countries all over the world (Germany, France, Italy, Japan, Slovenia, Indonesia, Belgium, Romania, Lithuania, Russia, Spain, Sweden, Korea and Ukraine) prepared chapters for this book. Such a broad geography indicates a high significance of considered subjects.

How to reference

In order to correctly reference this scholarly work, feel free to copy and paste the following:

Zaki Su'ud (2011). Semi Analytical Analysis of Steady State Condition of Steam Generator, Steam Generator Systems: Operational Reliability and Efficiency, Dr. Valentin Uchanin (Ed.), ISBN: 978-953-307-303-3, InTech, Available from: <http://www.intechopen.com/books/steam-generator-systems-operational-reliability-and-efficiency/semi-analytical-analysis-of-steady-state-condition-of-steam-generator>

INTECH
open science | open minds

InTech Europe

University Campus STeP Ri
Slavka Krautzeka 83/A
51000 Rijeka, Croatia
Phone: +385 (51) 770 447
Fax: +385 (51) 686 166
www.intechopen.com

InTech China

Unit 405, Office Block, Hotel Equatorial Shanghai
No.65, Yan An Road (West), Shanghai, 200040, China
中国上海市延安西路65号上海国际贵都大饭店办公楼405单元
Phone: +86-21-62489820
Fax: +86-21-62489821

© 2011 The Author(s). Licensee IntechOpen. This chapter is distributed under the terms of the [Creative Commons Attribution-NonCommercial-ShareAlike-3.0 License](https://creativecommons.org/licenses/by-nc-sa/3.0/), which permits use, distribution and reproduction for non-commercial purposes, provided the original is properly cited and derivative works building on this content are distributed under the same license.

IntechOpen

IntechOpen