

We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,900

Open access books available

185,000

International authors and editors

200M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities



WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com



Calibration of the GNSS Receivers — Methods, Results and Evaluation

Ta-Kang Yeh

Additional information is available at the end of the chapter

<http://dx.doi.org/10.5772/58887>

1. Introduction

GNSS (Global Navigation Satellite System) positioning technology has been utilized for surveying engineering, satellite geodesy and navigation in Taiwan. However, the performances of GNSS receivers need to correspond with the accuracy. In order to ensure the positioning precision and to correspond the ISO (International Organization for Standardization) requirement, the calibration of GNSS receivers are becoming more important [1]. The quality control and quality assurance standards of ISO 9000 emphasizes that the testing, measuring and verifying equipment (including testing software) should be controlled, calibrated and maintained [2]. Measuring equipment should have metrological characteristics as required for the intended use (for example accuracy, stability, range and resolution) [3]. ISO/IEC Guide 17025 states that the laboratory report should cover the uncertainty of calibration and testing results [4]. To ensure the measurement quality for ISO requirement, the traceability of calibration has been important to many fields of applications. In Taiwan, the GNSS calibration system has already been constructed by NML (National Measurement Laboratory, Taiwan) to provide calibration services for GNSS receivers. The ISO method [5] is adopted to calculate the uncertainty of the GNSS calibration system for describing the calibration results.

2. GNSS measurement system

The GNSS calibration network is composed of ultra-short baselines. The coordinates of calibration base points referred to the reference frame of ITRF (International Terrestrial Reference Frame). The distances of standard baselines and coordinates of calibration base points of ITRF are analyzed by GNSS positioning units, they are described as follows:

1. The field of ultra-short calibration baseline of GNSS receiver is located on the roof of building 16th of Industrial Technology Research Institute. There are two IGS (International GNSS Service) permanent stations TNML and TCMS operating continuously and five calibration base points called NML3, NML4, NML5, NML6 and NML7. Relative layout is as below in Figure 1. The appearance of permanent stations of TNML and TCMS are as Figure 2a, and appearance of calibration base points NML3 & 4 & 5 are as Figure 2b. The antennas are set up at stations with forced centering devices on every pillar.




Figure 1. The layout of field for ultra-short calibration baseline of GNSS positioning [1]



Figure 2. (a) Appearance of fixed stations; (b) Appearance of pillars of calibration base points [1]

2. GNSS positioning units include: (a) Precise positioning GNSS receiver AOA BenchMark with accuracy $2\text{ mm} + 0.002 \times 10^{-6} \times D$, D is distance. (b) GNSS receiver Leica RS500 with accuracy $3\text{ mm} + 0.5 \times 10^{-6} \times D$, D is distance. (c) GNSS receiver Ashtech Z-Surveyor with accuracy $5\text{ mm} + 1 \times 10^{-6} \times D$, D is distance [6]. Chock-ring antenna which can reduce multi-path effect. Precise instrument MET3A meteorological unit record temperature, relative humidity and pressure automatically. With those units can be improved the accuracy of GNSS positioning [7]. Moreover, the static relative positioning of middle distance, we chose TWTF as a base station which is maintained by the NSTFL (National Standard Time and Frequency Laboratory, Taiwan).

GNSS positioning is using known coordinates of satellites to calculate the distances from satellites to receivers and using the distances to calculate the unknown coordinates. Using time measurements can determinate the pseudo range from satellites to receivers, or using phase ambiguity can determinate the distances that carriers passed by. Coordinates of satellites can have from broadcast orbits from GNSS satellites signal, or download higher precision satellites ephemeris from IGS website [8]. Moreover, the Bernese version 5.0 software, which is developed by AIUB (Institute of Astronomy, University of Berne) to calculate the 3D coordinates.

The AOA BenchMark GNSS receiver is adopted at station TNML and its internal frequency is traced to the NSTFL. The frequency stability, expressed as a modified Allan deviation in Figure 3. The results of time offset was around 7.1×10^{-9} second and frequency offset was 4.9×10^{-14} after linear analyzing.. The frequency stability of the external rubidium oscillator is approximately at the 10^{-13} level [9].




Figure 3. Result of frequency calibration of TNML station

The main function of the GNSS calibration network is to determine the referential ITRF coordinates. Figure 4 presents the traceability chart and the ITRF coordinates are determined by GNSS positioning units.




Figure 4. Measurement system traceability diagram

3. Calibration procedure and methods

3.1. Preliminary operation

1. The instrument under calibration (IUC) should include the operation menu, power supply, battery, and the charger.
2. Check the battery of the IUC. If the power is insufficient, charge the battery according to the operation menu.
3. The calibrator should be familiar with the calibration procedures and the instrument operations according to the user's instruction.
4. Confirm and record the model number and the serial number of IUC (including antenna). If accessories package of IUC is incomplete, inform the customer to return the IUC or to prepare accessories package completely.

5. Take out the IUC and the antenna from the box in the under-calibration zone. Inspect the instrument appearance and give a general check. Set the parameters: the lowest angle of satellites (cutoff angle), the minimum number of satellites, and the sample rate according to the operation menu.
6. Check the forced-centering base on the pillars in calibration field, it should not be loose.
7. Make sure the receivers of permanent GNSS stations TNML and TCMS are receiving GNSS data normally.
8. Receivers should be open to the sky. The line of sight between receivers and satellites should not be blocked by objects near by the calibration field when the calibration procedures are executing.

3.2. Calibration steps

1. Open the aluminum covers of base point, set up the antenna of GNSS on the forced-centering base on pillars, rotate the direction mark on antenna to the north and fix it. Check the ends of signal cable are plugged in the antenna and IUC receiver exactly.
2. Turn on the power of IUC. According to the operation menu to set the parameters: the lowest angle of satellites (cutoff angle) to be 15° , the minimum number of satellites should be 3, measurement time interval (sampling rate) to be 15 seconds, and measurement time to be 8 hours.
3. Make sure the battery life to 12 hours and data memory is enough. Start to measure and recheck the GNSS data are recorded in the memory exactly until to 8 hours.
4. Download the data from IUC according to the procedures of operation menu. Transform all raw data to RINEX format, and filename is named by the principle of calibration base point and GNSS days.
5. Take out antenna from fixed pillar and put it in the box exactly and close it.
6. Set up the working standard of antenna and GNSS receiver of this calibration system on the forced-centering base on the pillars, rotate the direction mark on antenna to the north and fix it. Check the ends of signal cable are plugged in the antenna and receiver exactly.
7. Turn on the power of GNSS receiver. According to the operation menu to set the parameters: the lowest angle of satellites (cutoff angle) to be 15° , the minimum number of satellites should be 3, measurement time interval (sample rate) to be 15 seconds, and measurement time to be 24 hours.
8. Make sure the battery life to 12 hours and the data memory is enough, the start to measure until to 24 hours continuously.
9. Stop measuring, download the GNSS data from working standard receiver. Transform the raw data to RINEX format, and filename is named by the principle of calibration base point and GNSS days.

4. Uncertainty analysis

Following the evaluation method recommended by ISO, all the error sources shall be classified into type A and type B. Type A is evaluated by the statistical method and type B by other methods. Both evaluations are based on hypothetical probability distribution. All the estimated standard uncertainties are then combined to the combined standard uncertainty. The coverage factor and the expanded uncertainty are determined at the 95 % level of confidence. The error sources and the expanded uncertainties of the calibration results are analyzed as follow:

4.1. Modeling the measurement equation

The difference (C_1) between the indication of instrument under calibration (L_m) and the reference value of working standard (L_r) is expressed as

$$C_1 = L_m - L_r$$

where L_m is the indication of instrument under calibration, L_r is the reference value of working standard, and C_1 is the difference between measurement and reference.

According to the equation, the standard uncertainty $u(C_1)$ is expressed as

$$u(C_1) = [u(L_r)^2 + u(L_m)^2]^{1/2}$$

where $u(L_r)$ is the standard uncertainty of reference value, and $u(L_m)$ is the standard uncertainty of measurement.

4.2. Uncertainty in coordinates of TNML permanent station

1. Standard uncertainty of measurement repeatability $u(x_1)$: Data from four IGS tracking stations (USUD, GUAM, NTUS and WUHN) were obtained 60 days from October 2012 to December 2012. The 3D coordinates of TNML are calculated and shown in Figures 5. The standard deviations of the TNML coordinates are as follows: standard deviation in X axis $\sigma_{X3} = 3.2$ mm, standard deviation in Y axis $\sigma_{Y3} = 2.9$ mm, standard deviation in Z axis $\sigma_{Z3} = 3.1$ mm. If the 3D coordinates of TNML are equally weighted, the 1D combined standard uncertainty was $\sigma_1 = [(\sigma_{X3}^2 + \sigma_{Y3}^2 + \sigma_{Z3}^2) / 3]^{1/2} = [(3.2^2 + 2.9^2 + 3.1^2) / 3]^{1/2} = 3.1$ mm. The uncertainty of repeatability of measurement of TNML $u(x_1) = 3.1$ mm at the 68.3 % confidence level. Moreover, 60 measurements were made and the degrees of freedom was $\nu_1 = 3 \times 60 - 3 = 177$.
2. Standard uncertainty of centering and levelling $u(x_2)$: We utilized the forced centering device to set up the GNSS antenna and the maximum 1D error was about 0.5 mm [10]. When it comes to the distribution, the rectangular was considered and the 1D standard




Figure 5. Differences of geographical coordinates of TNML_ITRF2005

uncertainty was obtained as $u(x_2) = 0.5 / 3^{1/2} = 0.3$ mm. The relative uncertainty was determined at 20 % and the degrees of freedom was calculated as $\nu_2 = (1/2) \times (20/100)^{-2} = 12.5$.

3. Standard uncertainty of GNSS receiver frequency $u(x_3)$: The AOA BenchMark receiver is adopted at station TNML and its internal frequency is traced to the NSTFL. The frequency stability, expressed as a modified Allan deviation, nominal specifications is less than 10^{-12} [11]. The frequency stability of the external rubidium oscillator is 10^{-13} . The 1D error from the frequency stability for GNSS positioning is obtained to be about $2 \text{ mm} + 0.002 \times 10^{-6} \times D$, where D (around 2200 km) is the average distance from TNML to IGS tracking stations. The 1D error is approximately $2 \text{ mm} + 0.002 \times 10^{-6} \times 2.2 \times 10^9 \text{ mm} = 6.4 \text{ mm}$. When it comes to the distribution, the rectangular was considered and the 1D standard uncertainty was obtained as $u(x_1) = 6.4 / 3^{1/2} = 3.7$ mm. The relative uncertainty is determined as 10 % and the degrees of freedom is $\nu_3 = (1/2) \times (10/100)^{-2} = 50$.
4. Standard uncertainty of phase center offset and variation $u(x_4)$: The 1D error from the offset and variation of the antenna's phase center is around 0.1 mm after correction [12]. When it comes to the distribution, the rectangular was also considered and the 1D standard uncertainty was obtained as $u(x_4) = 0.1 / 3^{1/2} = 0.1$ mm. The relative uncertainty is determined at 25 % and the degrees of freedom is $\nu_4 = (1/2) \times (25/100)^{-2} = 8$.
5. Standard uncertainty of satellite orbit $u(x_5)$: The precision of the IGS final orbit is better than 5 cm and these data are downloaded from the IGS website. The 1D error from the satellite orbit for GNSS positioning is around $0.003 \times 10^{-6} \times D$, which is almost equal to 5 cm divisor 20,000 km (the distance to satellite), where D (around 2200 km) is the average distance from TNML to IGS tracking stations. The 1D error is about $0.003 \times 10^{-6} \times 2.2 \times 10^9 \text{ mm} = 6.6 \text{ mm}$. When it comes to the distribution, the rectangular was also considered and the 1D standard uncertainty was obtained as $u(x_5) = 6.6 / 3^{1/2} = 3.8$ mm. The relative uncertainty is determined as 20 % and the degrees of freedom is $\nu_5 = (1/2) \times (20/100)^{-2} = 12.5$.

Standard uncertainty components	Variance estimates (a)	Divisor (b)	Standard uncertainties (c) = (a) ÷ (b)	Sensitivity coefficients (d)	uncertainty components (e) = (c) × (d)	Degrees of freedom
Measurement repeatability $u(x_2)$	3.1 mm	1	3.1 mm	1	3.1 mm	177
Centering and leveling $u(x_2)$	0.5 mm	$\sqrt{3}$	0.3 mm	1	0.3 mm	12.5
GNSS receiver frequency $u(x_3)$	6.4 mm	$\sqrt{3}$	3.6 mm	1	3.7 mm	50
Phase center offset $u(x_4)$	0.1 mm	$\sqrt{3}$	0.1 mm	1	0.1 mm	8
Satellite orbit $u(x_5)$	6.6 mm	$\sqrt{3}$	3.8 mm	1	3.8 mm	12.5
Atmospheric delay correction $u(x_6)$	4.4 mm	$\sqrt{3}$	2.5 mm	1	2.5 mm	12.5
IGS station coordinates $u(x_7)$	6.0 mm	$\sqrt{3}$	3.5 mm	1	3.5 mm	8

Table 1. Uncertainties analysis of coordinates of fixed station TNML

- Standard uncertainty of troposphere and ionosphere delay correction $u(x_6)$: In the relative positioning, most of the tropospheric and ionospheric errors are reduced. The error after correction is about $0.002 \times 10^{-6} \times D$ [13], where D (around 2200 km) is the average distance from TNML to IGS tracking stations. The 1D error is approximately $0.002 \times 10^{-6} \times 2.2 \times 10^9 \text{ mm} = 4.4 \text{ mm}$. When it comes to the distribution, the rectangular was also considered and the 1D standard uncertainty was obtained as $u(x_6) = 4.4 / 3^{1/2} = 2.5 \text{ mm}$. The relative uncertainty is estimated at 20 %, therefore degree of freedom is $\nu_6 = (1/2) \times (20/100)^{-2} = 12.5$.
- Standard uncertainty of IGS station coordinates $u(x_7)$: The 1D coordinate repeatability of IGS tracking stations are 3–6 mm [8] and the maximum errors are used as 6 mm. When it comes to the distribution, the rectangular was also considered and the 1D standard uncertainty was obtained as $u(x_7) = 6 / 3^{1/2} = 3.5 \text{ mm}$. The relative uncertainty is calculated as 25 % and the number of degrees of freedom is $\nu_7 = (1/2) \times (25/100)^{-2} = 8$.

Table 1 presents the uncertainties at station TNML.

4.3. Uncertainty in coordinates of the ultra-short distance network

- Standard uncertainty of reference measurement repeatability $u(x_8)$: Coordinates of calibration pillars NML 3 were measured using GNSS working standard for 2 weeks. The data processing utilized the reference station TNML and obtained the ITRF coordinates in two sessions. Moreover, the 1D standard deviation was calculated as shown in Table 2. The average distance from fixed station TNML to each pillar is around 48 m. The number of degrees of freedom is $\nu_8 = 2 \times 3 \times (6-1) = 30$. The 1D combined standard uncertainty is $u(x_8) = [(0.6^2 + 0.6^2) / 2]^{1/2} = 0.6 \text{ mm}$.
- Standard uncertainty in centering and levelling $u(x_9)$: The same descriptions in chapter 4.2, standard uncertainty of instrument's levelling and centering is $u(x_9) = 0.5 / 3^{1/2} = 0.3$

NML3	Standard deviation on X axis σ_X (mm)	Standard deviation on Y axis σ_Y (mm)	Standard deviation on Z axis σ_Z (mm)	1D standard deviation σ_{8a} $= [(\sigma_X^2 + \sigma_Y^2 + \sigma_Z^2) / 3]^{1/2}$ (mm)
Week 1	0.3	0.5	0.8	0.6
Week 2	0.3	0.5	0.8	0.6

Table 2. Standard deviations of three axis of points NML3, 4, 5, 6, 7

mm. The relative uncertainty was calculated at 20 % and the number of degrees of freedom was $\nu_9 = (1/2) \times (20/100)^{-2} = 12.5$.

- Standard uncertainty in phase center offset and variation $u(x_{10})$: The same descriptions in chapter 4.2, a rectangular distribution is assumed and 1D standard uncertainty is $u(x_{10}) = 0.1 / 3^{1/2} = 0.1$ mm. The relative uncertainty was calculated at 25 %, and the number of degrees of freedom was $\nu_{10} = (1/2) \times (25/100)^{-2} = 8$.
- Standard uncertainty in satellite orbit $u(x_{11})$: The same descriptions in chapter 4.2, the range of the influence is about $0.003 \times 10^{-6} \times 48 \times 10^3 \approx 0.0$ mm (1.44×10^{-4}). A rectangular distribution is assumed and 1D standard uncertainty is $u(x_{11}) = 0.0 / 3^{1/2} = 0.0$ mm. The relative uncertainty was calculated at 20 %, and the number of degrees of freedom was $\nu_{11} = (1/2) \times (20/100)^{-2} = 12.5$.
- Standard uncertainty in troposphere and ionosphere delay correction $u(x_{12})$: The same descriptions in chapter 4.2, the extent of the 1D influence is about $0.002 \times 10^{-6} \times 48 \times 10^3$ mm ≈ 0.0 mm (9.6×10^{-5}). A rectangular distribution is assumed and the 1D standard uncertainty is $u(x_{12}) = 0.0 / 3^{1/2} = 0.0$ mm. The relative uncertainty is estimated at 20 %, therefore degree of freedom is $\nu_{12} = (1/2) \times (20/100)^{-2} = 12.5$.

Table 3 presents the uncertainties of coordinates of the ultra-short distance network (NML3, 4, 5, 6, 7 relative to TNML).

Standard uncertainty components	Variance estimates (a)	Divisor (b)	Standard uncertainties (c) = (a) ÷ (b)	Sensitivity coefficients (d)	uncertainty components (e) = (c) × (d)	Degrees of freedom
Measurement repeatability $u(x_8)$	0.6 mm	1	0.6 mm	1	0.6 mm	30
Centering and levelling $u(x_9)$	0.5 mm	$\sqrt{3}$	0.3 mm	1	0.3 mm	12.5
Phase center offset $u(x_{10})$	0.1 mm	$\sqrt{3}$	0.1 mm	1	0.1 mm	8
Satellite orbit $u(x_{11})$	0.0 mm	$\sqrt{3}$	0.0 mm	1	0.0 mm	12.5
Weather delay correction $u(x_{12})$	0.0 mm	$\sqrt{3}$	0.0 mm	1	0.0 mm	12.5

Table 3. Uncertainties analysis in coordinates of points NML3, 4, 5, 6, 7 relative to station TNML

4.4. Combined standard uncertainty in coordinates of TNML

The sources of error are assumed to be independence. The 1D combined standard uncertainty of fixed station TNML is $u_c(C_1)$

$$\begin{aligned} u_c(C_1) &= (u(x_1)^2 + u(x_2)^2 + u(x_3)^2 + u(x_4)^2 + u(x_5)^2 + u(x_6)^2 + u(x_7)^2)^{1/2} \\ &= [(3.1)^2 + (0.3)^2 + (3.7)^2 + (0.1)^2 + (3.8)^2 + (2.5)^2 + (3.5)^2]^{1/2} = 7.5 \text{ mm} \end{aligned}$$

The effective number of degrees of freedom $\nu_{\text{eff}(C_1)}$ is determined by the Welch-Satterthwaite formula [14]

$$\begin{aligned} \nu_{\text{eff}(C_1)} &= (u_c(C_1))^4 \left/ \left(\frac{u(x_1)^4}{v_1} + \frac{u(x_2)^4}{v_2} + \frac{u(x_3)^4}{v_3} + \frac{u(x_4)^4}{v_4} + \frac{u(x_5)^4}{v_5} + \frac{u(x_6)^4}{v_6} + \frac{u(x_7)^4}{v_7} \right) \right. \\ &= (7.5)^4 \left/ \left(\frac{3.1^4}{177} + \frac{0.3^4}{12.5} + \frac{3.7^4}{50} + \frac{0.1^4}{8} + \frac{3.8^4}{12.5} + \frac{2.5^4}{12.5} + \frac{3.5^4}{8} \right) \right. = 7.3 \end{aligned}$$

4.5. Combined standard uncertainty in coordinates of the ultra-short distance network

The sources of error are assumed to be independence. The 1D combined standard uncertainty in coordinates of base points NML3, 4, 5, 6, 7 relative to TNML is $u_c(C_2)$

$$\begin{aligned} u_c(C_2) &= (u(x_8)^2 + u(x_9)^2 + u(x_{10})^2 + u(x_{11})^2 + u(x_{12})^2)^{1/2} \\ &= [(0.6)^2 + (0.3)^2 + (0.1)^2 + (0.0)^2 + (0.0)^2]^{1/2} = 0.7 \text{ mm} \end{aligned}$$

The effective number of degrees of freedom $\nu_{\text{eff}(C_2)}$ is determined by the Welch-Satterthwaite formula

$$\begin{aligned} \nu_{\text{eff}(C_2)} &= (u_c(C_2))^4 \left/ \left(\frac{u(x_8)^4}{v_8} + \frac{u(x_9)^4}{v_9} + \frac{u(x_{10})^4}{v_{10}} + \frac{u(x_{11})^4}{v_{11}} + \frac{u(x_{12})^4}{v_{12}} \right) \right. \\ &= (0.7)^4 \left/ \left(\frac{0.6^4}{30} + \frac{0.3^4}{12.5} + \frac{0.1^4}{8} + \frac{0^4}{12.5} + \frac{0^4}{12.5} \right) \right. = 48 \end{aligned}$$

4.6. Expanded uncertainty in coordinates of TNML

At the 95 % confidence level, the coverage factor k_1 is 1.99 when the effective degrees of freedom $\nu_{\text{eff}(C_1)}$ is 73. The 1D expanded uncertainty U_1 is equal to the coverage factor k_1 multiplied by the 1D combined standard uncertainty $U_1 = k_1 \times u_c(C_1)$. Furthermore, the 1D expanded uncertainty of reference station TNML is $U_1 = 1.99 \times 7.5 = 14.9 \text{ mm}$ at the 95 % confidence level. At the 95 % confidence level, the 3D coverage factor k_{1_3D} is equal to 2.79 (issued by Federal Geodetic

Control Committee in America [15]). Therefore, at the 95 % confidence level, the 3D expanded uncertainty of the reference station TNML is $U_{1_3D} = k_{1_3D} \times u_c(C_1) = 2.79 \times 7.5 = 20.9$ mm.

4.7. Expanded uncertainty in coordinates of the ultra-short distance network

At the 95 % confidence level, the coverage factor k_2 is 2.03 when the effective degrees of freedom $\nu_{eff(C2)}$ is 33. The 1D expanded uncertainty U_2 is equal to the coverage factor k_2 multiplied by the 1D combined standard uncertainty $U_2 = k_2 \times u_c(C_2)$. Furthermore, the 1D expanded uncertainty of points NML3, 4, 5, 6, 7, relative to the reference station TNML is $U_2 = 2.03 \times 1.7 = 3.5$ mm at the 95 % confidence level. The 3D coverage factor k_{2_3D} is equal to 2.79 [15] at the 95 % confidence level. Therefore, the 3D expanded uncertainty of points NML3, 4, 5, 6, 7, relative to the reference station TNML is $U_{2_3D} = k_{2_3D} \times u_c(C_2) = 2.79 \times 1.7 = 4.8$ mm at the 95 % confidence level.

5. Measurement assurance program

The analysis of uncertainty in measurement of GNSS static and kinematic positioning calibration system is according to the “Guide to the Expression of Uncertainty in Measurement” published by ISO and has been discussed in chapter 4. The measurement assurance program designed a process using a set of checking parameters and measurement control charts. The approach of measurement assurance program was recommended by SP676-II [16] published by National Institute of Standards and Technology (NIST) in U.S.A.

5.1. Quality assurance design

There are two units to check: (1) checking the accuracy of the coordinates of fixed station TNML, and (2) the accuracy of the slope distances of the ultra-short distance network.

1. Analysis of the coordinates of fixed station TNML

Data from four IGS tracking stations (USUD, GUAM, NTUS and WUHN) were obtained every day for whole year. The 3D coordinates of TNML are calculated for daily solutions over one year. The mean and the standard deviation values are obtained. The standard deviation is as the control parameter and to monitor the accuracy of the measurement system.

2. Analysis of the slope distances of the ultra-short distance network

The slope distances of calibration pillars NML 3, 4, 5, 6 and 7 were measured using GNSS receivers. Besides, processing the data associated with station TNML using Bernese software yielded relative distances and the standard deviation was computed.

5.2. Parameters and control chart

Measurements were taken periodically using the procedure mentioned previous section. The checking parameters include the arithmetic mean (A_c), upper control limit (UCL), and lower control limit (LCL). The coverage factor is 3.0 at the 99.7% confidence level. Every control chart should renew at least every year.

$$A_c = \frac{1}{n} \sum_{i=1}^n x_i$$

$$S_c = \left[\frac{1}{n-1} \sum_{i=1}^n (x_i - A_c)^2 \right]^{1/2}$$

$$UCL = A_c + 3S_c$$

$$LCL = A_c - 3S_c$$

1. The control chart of the coordinates of fixed station TNML

Measurements were obtained 24 hours for every day from January in 2012 to April in 2014. The 3D coordinates of TNML daily solutions are calculated and the control charts are shown in Figure 6. The ITRF2005 coordinates of the TNML are as follows: $X_{avg} = -2982779.3482$ m, $Y_{avg} = 4966662.5319$ m, $Z_{avg} = 2658805.6435$ m. The transformed geographical coordinates are: $Lat_{avg} = 24.79795393$ deg, $Long_{avg} = 120.98734731$ deg, and $H_{avg} = 75.8685$ m. The upper control limit for Latitude is $UCL_{Lat} = 9.5$ mm and lower control limit $LCL_{Lat} = -9.5$ mm. The upper control limit for Longitude is $UCL_{Long} = 12.2$ mm and $LCL_{Long} = -12.2$ mm. The upper control limit for Height is $UCL_H = 20.3$ mm and $LCL_H = -20.3$ mm.

2. The control chart of the slope distances of the ultra-short distance network

Measurements were obtained from February 2008 to March 2014. The slope distance from calibration pillars to TNML are calculated and the control charts are shown in Figures 7 to 11. The upper control limit (UCL) and lower control limit (LCL) are determined at the 99.7 % confidence level.




Figure 6. Control chart of TNML fixed station in 2014




Figure 7. Control chart of slope distances between NML3 to TNML




Figure 8. Control chart of slope distances between NML4 to TNML




Figure 9. Control chart of slope distances between NML5 to TNML




Figure 10. Control chart of slope distances between NML6 to TNML




Figure 11. Control chart of slope distances between NML7 to TNML

6. Conclusion

This chapter describes the procedures of the calibration for the GNSS receivers by using the GNSS ultra-short baselines calibration network and the precise GNSS positioning units. The main purposes are describing the error sources caused by the calibration procedure of the GNSS receivers and analyzing the uncertainties of the calibration system. The evaluated uncertainties include measurement repeatability, centering and levelling, phase center offset, satellite orbit and the correction for atmospheric delay. The other errors such as human and material resources did not discussed here. The uncertainties evaluations of the calibration system are according to the “Guide to the Expression of Uncertainty in Measurement” published by the ISO.

The ISO method is adopted to calculate the expanded uncertainty of the calibrating network for GNSS calibration system. At the 95% confidence level, the 3D expanded uncertainty of the reference station TNML is around 20.9 mm. The 3D expanded uncertainties of the ultra-short distance network are obtained to be approximately 4.8 mm in relative to the reference station TNML. The example of the calibration report please refers the appendix. We believe the precision of the calibration system is enough to evaluate the performance of the geodetic GNSS receivers and to ensure the precision of the regional users. This method can check the quality of GNSS receivers in time. Following the standard operating procedure, the accuracy of the GNSS positioning can be ensured for accommodating the ISO requirement.

Appendix

Example of a calibration report [1]



		Report No.:	
Instrument:	GNSS Receiver	Temperature:	(24.6 ± 2.6) °C
Manufacturer:	Trimble	Relative Humidity:	(81 ± 11) %
Model:	4000SSE	Ambient Pressure:	(1006 ± 1) hPa
Serial No.:	3325A03403		

Calibration Results and Descriptions

I . Calibration results

1. Static relative positioning of ultra-short distance

Relative coordinate components to TNML of pillar NML3	Referential value [m] R_1	Measured value [m] A	Difference [mm] $A-R_1$	Expanded uncertainty [mm]
ΔX_1	25.2068	25.2116	4.8	4.8
ΔY_1	-9.6594	-9.6658	-6.4	
ΔZ_1	30.2044	30.2014	-3.0	
D_1	40.5092	40.5114	2.3	

2. Static relative positioning of middle distance

Relative coordinate components to TWTF of pillar NML3	Referential value [m] R_2	Measured value [m] B	Difference [mm] $B-R_2$	Expanded uncertainty [mm]
ΔX_2	11673.4791	11673.5064	27.3	19
ΔY_2	15344.9696	15344.9321	-37.5	
ΔZ_2	-15660.2632	-15660.2833	-20.1	
D_2	24839.1234	24839.1257	2.3	

Note: 1. On the ultra-short distance calibration network (See Figure below), the calibrated item GNSS receiver (Model: Trimble 4000SSE, S/N: 3325A03403) and Antenna (Model: 33429-00, S/N: 0220173347) was set on the pillar NML3.

2. Data for the antenna forward to 0° were obtained between 7:30 ~ 11:30 (GNSS time) on Mar. 11, 2004. GNSS data were logged every 15 seconds, and the cutoff angle was 15 degrees.

3. The instrument specification is (RMS 5 mm + 1 × 10⁻⁶ × D), where D is the slope distance.

II. Descriptions

1. Date and place

The calibration was performed on [Mar. 11, 2004](#) at the ultra-short distance calibration network, and the GNSS receiver being calibrated was set on the pillar [NML3](#).

2. Methods

2.1 The calibration was performed according to the “Instrument calibration technique for the calibration of GNSS receiver.”

2.2 The referential values R_1 , R_2 of the ultra-short distance calibration network were measured by using high precise GNSS receivers and choke ring antennas. The instruments were set on the calibration pillar [NML3](#) and logged data every 15 seconds for 24 hours. The data were processed by Bernese 5.0 software and the referential values were obtained. The steps of the calculation are as follows:

2.2.1 The raw data were converted to the receiver independent exchange format (RINEX) and converted to the Bernese format.

2.2.2 The IGS precise ephemeris were converted to the tabular orbit format and converted to the Bernese format for processing data.

2.2.3 The code data were checked and the outliers were detected.

2.2.4 The single point positioning was processed by using code data and the tropospheric scatter model. Using least-squares estimation method, the approximate coordinates of stations and clock offsets of GNSS receivers were calculated.

2.2.5 The single differential phase data were composed by the principle of shorter distance.

2.2.6 The cycle slips were detected and recovered by using triple difference.

2.2.7 We then composed the double differential phase data to calculate the parameters, baselines and coordinates.

2.3 In the static relative positioning of ultra-short distance, we chose TNML as a base station ($X = -2982779.2361$ m, $Y = 4966662.5825$ m, $Z = 2658805.6798$ m, which is maintained by National Measurement Laboratory). Measured values were obtained by processing baseline using Bernese 5.0 software. Measured value A was obtained with the antenna forward to 0° (meaning forward to north). The differences were computed by subtracting referential value R_1 from values A .

In addition, the relation between the slope distance D_1 and the difference of coordinate components ΔX_1 , ΔY_1 , ΔZ_1 is as follows:

$$D_1 = \left(\Delta X_1^2 + \Delta Y_1^2 + \Delta Z_1^2 \right)^{1/2}$$

In the Bernese software, the parameters were set as follows:

- * System of coordinate: ITRF2005
- * Data used: L1&L2
- * Method of solving ambiguity: QIF
- * Method of tropospheric correction: Saastamoinen
- * Type of orbit: IGS precise ephemeris

2.4 In the static relative positioning of middle distance, we chose TWTF as a base station ($X = -2994428.2803$ m, $Y = 4951309.2038$ m, $Z = 2674496.8043$ m, which is maintained by National Standard Time and Frequency Laboratory). Measured values were obtained by processing baseline using Bernese 5.0 software. Measured value B was obtained with the antenna forward to 0° (meaning forward to north). The differences were computed by subtracting referential value R_2 from values B .

The relation between the slope distance D_2 and the difference of coordinate components ΔX_2 , ΔY_2 , ΔZ_2 is as follows:

$$D_2 = \left(\Delta X_2^2 + \Delta Y_2^2 + \Delta Z_2^2 \right)^{1/2}$$

In the Bernese software, the parameters were set as follows:

- * System of coordinate: ITRF2005
- * Data used: L3
- * Method of solving ambiguity: QIF
- * Method of tropospheric correction: Saastamoinen
- * Type of orbit: IGS precise ephemeris

3. Calibration standards

The frequency standard is Datum 8040A rubidium oscillator, with serial No. 0213005334 and traced to National Standard of Time and Frequency Laboratory, with report No. FTC-2014-04-16 on 29 April, 2014. The calibration interval is three years.

4. Expanded uncertainty

- 4.1 The expanded uncertainty was evaluated according to the following document: "Measurement system validation procedure for the calibration of GNSS receiver."
- 4.2 The expanded uncertainty was obtained by multiplying the combined standard uncertainty with a coverage factor $k = 2.79$, corresponding to the 95 % confidence level.

Acknowledgements

The author would like to thank Dr. Chiung-Wu Lee (National Measurement Laboratory of Taiwan) for providing valuable informations, which deeply help me to finish this chapter. The author also would like to thank the Ministry of Science and technology of the Republic of China, Taiwan, for financially supporting this research under Contract No. MOST 102-2622-E-305-002-CC3.

Author details

Ta-Kang Yeh

Address all correspondence to: bigsteel@mail.ntpu.edu.tw

Department of Real Estate and Built Environment, National Taipei University, New Taipei City, Taiwan

References

- [1] Yeh TK, Wang CS, Lee CW, Liou YA. Construction and uncertainty evaluation of a calibration system for GPS receivers, *Metrologia*, 43(5); 2006. p451-460.
- [2] Chinese National Standards (CNS). Model of quality for designing, developing, producing, installing and servicing of quality system. Bureau of Standards, Metrology and Inspection: Cxlink2681 (ISO 9001); 1996.
- [3] International Organization for Standardization (ISO). Quality assurance requirements for measuring equipment—Part I: Metrological confirmation system for measuring equipment. International Organization for Standardization: ISO 10012-1; 1992.
- [4] International Organization for Standardization (ISO). General requirements for the competence of calibration and testing laboratories. International Organization for Standardization: ISO/IEC Guide 25; 1996.
- [5] International Organization for Standardization (ISO). Guide to the expression of Uncertainty in Measurement (GUM). International Organization for Standardization; 1995. p9-24.
- [6] National Measurement Laboratory (NML). Instrument calibration technique for GNSS static and kinematic positioning calibration system. Industrial Technology Research Institute: 07-3-91-0086; 2014.
- [7] National Measurement Laboratory (NML). Measurement system validation procedure for GNSS static and kinematic positioning calibration system. Industrial Technology Research Institute: 07-3-91-0043; 2014.
- [8] Neilan RE, Beutler G, Kouba J. The International GNSS Service in 1997: 5 years of practical experience. Proceeding of the Scientific Assembly of IAG, Rio de Janeiro, Brazil; 1997.
- [9] Lesage P, Ayi T. Characterization of frequency stability: analysis of the modified Allan variance and properties of its estimate. *IEEE Trans. Instrum. Meas.* 1984; IM-33(4): 332-336.

- [10] Lee CW, Yeh TK, Peng GS. Traceability in metrology and uncertainty evaluation of a calibration system for GPS receivers, *Proceedings of SPIE - The International Society for Optical Engineering*, 5190; 2003. p410-418.
- [11] National Measurement Laboratory (NML). Study on time and frequency analysis of GNSS receiver and traceability for GNSS positioning. Industrial Technology Research Institute: 07-3-91-0002; 2002.
- [12] Mader GL. GNSS antenna calibration at the National Geodetic Survey: NGS. <http://www.ngs.noaa.gov/ANTCAL> (accessed 1 May 2014).
- [13] Teunissen PJG and Kleusberg A. *GPS for Geodesy*. 2nd edn. Springer, Berlin; 1998. p121-166.
- [14] International Organization for Standardization (ISO). *Uncertainty of measurement—Part 3: Guide to the expression of uncertainty in measurement (GUM)*. International Organization for Standardization: ISO/IEC Guide 98-3; 2008.
- [15] Federal Geodetic Control Committee (FGCC). *Geometric geocentric accuracy standards and specifications for using GNSS relative positioning techniques*. Federal Geodetic Control Committee; 1988.
- [16] Croarkin C. *Measurement assurance program part II: Development and implementation*. National Bureau of Standards: NBS SP676-II; 1985.