

We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,900

Open access books available

185,000

International authors and editors

200M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities



WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com



Parallel Iteration Method for Frequency Estimation Using Trigonometric Decomposition

He Wen, Junhao Zhang, Radek Martinek,
Petr Bilik and Zidek Jan

Additional information is available at the end of the chapter

<http://dx.doi.org/10.5772/66778>

Abstract

The parallel iteration method for frequency estimation based on trigonometric decomposition is presented. First, the multi-frequency signal can be expressed in a matrix form based on the trigonometric decomposition, which implies a possibility to solve the nonlinear mapping functions of frequency estimation by a parallel iteration procedure. Then, frequency estimation with the minimized square errors is achieved by using the gradient-descent method in the parallel iteration procedure, which can effectively restrain the interferences from harmonics and noise. Finally, the workflow is shown, and the efficiency of the proposed method was demonstrated through computer simulations and experiments.

Keywords: frequency estimation, trigonometric decomposition, parallel iteration, signal processing

1. Introduction

With the widespread application of nonlinear loads such as uninterruptible power supply, electric arc furnaces, and other power-electronic devices in power electronic systems, resulting power quality problems have drawn much attention. Frequency estimation is a very important issue in the power system because of the need for an assessment of the power quality [1, 2]. In addition, the frequency of a distribution network can extremely vary during transient events, and it can be very difficult to track the frequency with enough accuracy [3].

In the past years, various methods have been presented to estimate the power system frequency [4, 5]. The DFT-based methods provide a nonparametric approach and require a low computational effort [6–8]. Unfortunately, they have inherent limitations due to the picket fence and spectral leakage effects caused by the noncoherent sampling. Since the system

fundamental frequency may deviate from its nominal value because of the power mismatch between the generation and load demands, it is almost impossible to achieve the strict coherent sampling and thus some degree of spectral leakage cannot be avoided. A commonly used frequency estimation methods to compensate both spectral leakage and picket fence effects are the so-called windowed interpolated FFT (WIFFT) method [9]. However, the WIFFT can only reduce, but not completely remove, the estimation errors at the cost of an increment in the computation burden of the frequency estimation.

Other popular frequency estimation methods include the zero-crossing technique, Kalman filter, least-squares method, and artificial neural networks, which are characterized by high resolution. However, they may either suffer from low accuracy or less computational efficiency [10]. For example, the Prony method can provide high-accuracy frequency estimates when the model order is known; however, the determination of the model order is often a difficult task, which requires intensive computational algorithms [5].

Trigonometric decomposition is a well-known technique for determine different frequency components of periodic signals. According to the Fourier analysis, general functions or signals may be represented or approximated by sums of simpler trigonometric functions. So, it is relatively easy to estimate the frequency of a pure sine-wave by trigonometric decomposition. However, estimating frequency of a real signal distorted by harmonics and noise is much more difficult. This is because the frequency estimation errors due to the interference from the harmonics and noise remain significant in trigonometric decomposition, especially when the number of acquired signal cycles is very small. To reduce the frequency estimation errors, an iteration procedure can be applied in trigonometric decomposition; however, the computation would much more complex than the fast Fourier transform. For real-time processing requirements, most of the aforementioned methods offer a tradeoff between accuracy and speed [3]. Therefore, seeking efficient methods to estimate power system frequency for power-quality assessment and solutions has been a significant challenge.

This chapter proposes a parallel iteration method for frequency estimation based on trigonometric decomposition. According to the theory of trigonometric decomposition, a multifrequency signal can be expressed using matrix algebra, which provides a base for the parallel iteration to solve the nonlinear mapping functions of frequency estimation. By using the gradient-descent method in the iteration procedure, the frequency is estimated with the minimized square errors and thus the interferences from harmonics and noise can effectively be restrained. The organization of this chapter is as follows: in Section 2, the proposed method is presented. Simulation and experiment results are provided in Section 3, and the conclusion is made in Section 4.

2. Proposed frequency estimation method

2.1. Trigonometric decomposition of periodic signal

Let us consider a multifrequency electrical waveform $x(n)$ sampled at a known frequency f_s , i.e.,

$$x(n) = U_0 + \sum_{h=1}^H U_h \sin(2\pi h f n / f_s + \varphi_h) \quad (1)$$

where $n = 0, 1, \dots, N-1$; f is the fundamental frequency, H is the number of frequency components, U_h and φ_h are, respectively, the amplitude and phase of the h th component, U_0 is the offset, and N is the acquisition length. To satisfy the Nyquist criterion, the frequency of the H th harmonic is assumed to be smaller than $f_s/2$.

By applying trigonometric decomposition, it can be rewritten Eq. (1) as follow:

$$x(n) = U_0 + \sum_{h=1}^H [U_h \sin \varphi_h \cos(2\pi h f n / f_s) + U_h \cos \varphi_h \sin(2\pi h f n / f_s)] \quad (2)$$

For the sake of simplicity, the a_h and b_h can be used to represent $U_h \sin \varphi_h$ and $U_h \cos \varphi_h$, respectively, i.e.,

$$a_h = U_h \sin \varphi_h \text{ and } b_h = U_h \cos \varphi_h \quad (3)$$

So, Eq. (1) can be expressed as

$$x(n) = U_0 + \sum_{h=1}^H [a_h \cos(2\pi h f n / f_s) + b_h \sin(2\pi h f n / f_s)] \quad (4)$$

By using the matrix operation, Eq. (4) can also be written as

$$X = ZD + AC + BS \quad (5)$$

where $X = [x(1), x(2), \dots, x(N)]$ denotes the vector of the sampled signal, $Z = U_0$, $D = [1_1, 1_2, \dots, 1_N]$, $A = [a_1, a_2, \dots, a_H]$, $B = [b_1, b_2, \dots, b_H]$,

$$C = \begin{bmatrix} \cos(\eta) & \cos(2\eta) & \dots & \cos(N\eta) \\ \cos(2\eta) & \cos(4\eta) & \dots & \cos(2N\eta) \\ \vdots & \vdots & \ddots & \vdots \\ \cos(H\eta) & \cos(H2\eta) & \dots & \cos(HN\eta) \end{bmatrix} \quad (6)$$

and

$$S = \begin{bmatrix} \sin(\eta) & \sin(2\eta) & \dots & \sin(N\eta) \\ \sin(2\eta) & \sin(4\eta) & \dots & \sin(2N\eta) \\ \vdots & \vdots & \ddots & \vdots \\ \sin(H\eta) & \sin(H2\eta) & \dots & \sin(HN\eta) \end{bmatrix} \quad (7)$$

with $\eta = 2\pi f / f_s$.

2.2. Parallel iteration algorithm

From Eq. (5), the frequency estimation for each component can be regarded as a nonlinear mapping problem through N samples, which can be defined as

$$f = F_m(X, Z, D, A, C, B, S) \quad (8)$$

where F_m is the nonlinear mapping functions for the fundamental frequency. The solution procedure for detecting the fundamental frequency of Eq. (8) is not easy. This is because it is difficult to determine the nonlinear mapping functions F_m , which should be implicit function. It has been noticed that the iteration is one of the approaches developed to solve the nonlinear mapping problem. In the following, the procedure with parallel iteration for solving the nonlinear mapping functions F_m of Eq. (8) with a fast convergence is proposed.

Suppose $Y = [y(1), y(2), \dots, y(N)]$ denote the vector of the estimated signal. According to the least-squares method, the estimated frequency f_e should be the one that minimizes the square error, which can be expressed as

$$f_e = \arg \min[E^2] = \operatorname{argmin}[(X-Y)(X-Y)^T] \quad (9)$$

where $(\bullet)^T$ denotes the transpose operation.

By using the gradient-descent method, a group of equations can be obtained by setting each partial derivative of E^2 equal to zero. Then, the parallel iteration equations can be obtained as following,

$$\begin{cases} f^{(k+1)} = f^{(k)} - \lambda \frac{\partial E^{(k)}}{\partial f^{(k)}} \\ \quad = f^{(k)} + \gamma \frac{E^{(k)}}{f_s} \left(\psi \cdot * C^{(k)T} B^{(k)T} - \psi \cdot * S^{(k)T} A^{(k)T} \right) \\ Z^{(k+1)} = Z^{(k)} - \lambda \frac{\partial E^{(k)}}{\partial Z_k} = Z^{(k)} + \lambda E^{(k)} D^T \\ A^{(k+1)} = A^{(k)} - \lambda \frac{\partial E^{(k)}}{\partial A_k} = A^{(k)} + \lambda E^{(k)} C^T \\ B^{(k+1)} = B^{(k)} - \lambda \frac{\partial E^{(k)}}{\partial B^{(k)}} = B^{(k)} + \lambda E^{(k)} S^T \end{cases} \quad (10)$$

where $*$ denotes the element-by-element multiplication; $\gamma = 2/U_1^2$ and λ are the descent coefficients, ψ is a matrix of constants

$$\psi = \begin{bmatrix} 1 & 2 & \dots & N \\ 2 & 4 & \dots & 2N \\ \vdots & \vdots & \ddots & \vdots \\ H & 2H & \dots & HN \end{bmatrix} \quad (11)$$

2.3. Convergence of parallel iteration procedure

From Eq. (9), the Lyapunov function can be defined as

$$J_k = \frac{1}{2} \|E^{(k)}\|^2 \quad (12)$$

and the gradient can be calculated by

$$\Delta J_k = \frac{1}{2} \|E^{(k+1)}\|^2 - \frac{1}{2} \|E^{(k)}\|^2 \quad (13)$$

where $\|\bullet\|^2$ denotes the square of the **F**-norm.

By using the Taylor expansion, the $E^{(k+1)}$ can be rewritten as

$$E^{(k+1)} = E^{(k)} + \Delta Z_k \frac{\partial E^{(k)}}{\partial Z_k} + \Delta A_k \frac{\partial E^{(k)}}{\partial A_k} + \Delta B_k \frac{\partial E^{(k)}}{\partial B_k} \quad (14)$$

where the partial derivatives can be calculated as

$$\begin{cases} \frac{\partial \Lambda_k}{\partial Z_k} = -D \\ \frac{\partial \Lambda_k}{\partial A_k} = -C \\ \frac{\partial \Lambda_k}{\partial B_k} = -S \end{cases} \quad (15)$$

By using Eq. (9), Eq. (14) can be expressed as

$$E^{(k+1)} = E^{(k)} \left[I - \lambda (D^T D + C^T C + S^T S) \right] \quad (16)$$

where I is an identity matrix. By substituting Eq. (16) into Eq. (13), the gradient can be expressed as

$$\Delta J_k = \frac{1}{2} \|E^{(k)}\|^2 [\|I - \lambda (D^T D + C^T C + S^T S)\|^2 - 1] \quad (17)$$

According to the triangle inequality of the matrix norm, the following inequality can be obtained

$$\begin{aligned} \|I - \lambda (D^T D + C^T C + S^T S)\|^2 &\leq \left(\|I\| - \lambda \|D^T D + C^T C + S^T S\| \right)^2 \\ &= 1 - 2\lambda \|D^T D + C^T C + S^T S\| + \lambda^2 \|D^T D + C^T C + S^T S\|^2 \end{aligned} \quad (18)$$

Substitute Eq. (17) into Eq. (18), one can obtain

$$\Delta J_k \leq \frac{1}{2} \|E^{(k)}\|^2 \|D^T D + C^T C + S^T S\| (-2 + \lambda \|D^T D + C^T C + S^T S\|) \quad (19)$$

In Eq. (19), considering the $\|E^{(k)}\|^2 \|D^T D + C^T C + S^T S\| \geq 0$, to guarantee the convergence of the parallel iteration procedure, i.e., $\Delta J_k < 0$, it is required to hold the following condition

$$-2 + \lambda \|D^T D + C^T C + S^T S\| < 0 \quad (20)$$

That is to say the convergence of parallel iteration procedure can be guaranteed if λ satisfy the following condition

$$0 < \lambda < 2/\|D^T D + C^T C + S^T S\|_F \quad (21)$$

where $\|\bullet\|_F$ denotes the **F**-norm.

2.4. Workflow of the proposed method

Figure 1 shows the workflow of the parallel iteration method for frequency estimation using trigonometric decomposition, where ε denotes the tolerance. The major steps are as follows:




Figure 1. Workflow of the parallel iteration method for frequency estimation using trigonometric decomposition.

1. Initialize the parallel iteration parameters. Set the initial frequency f to be 50 Hz, the initial value of both A and B to be random values within the range (0–1), the initial value of Z to be zero.
2. Calculate the iteration values of C, S, Y, E based on Eqs. (5)–(7).
3. Update iteration values by using Eq. (10).
4. Check if the early-stopping constraint, i.e., $E^{(k+1)} < E^{(k)}$, is met. If not, adjust the λ and return to step (1).
5. Check if the stopping constraint, i.e. $E < \varepsilon$, is met. If not, return to step (3). If yes, keep the value of f_e and output.

It is worth mentioning that the early stopping constraint is to guarantee that the error differences between two iterations are decreasing.

3. Simulation and experimental results

To evaluate the performances of the proposed algorithm, we perform a series of simulations on an electrical power signal with and without white noise in this section. To make comparisons,

the WIFFT algorithm and discrete phase difference correction (DPDC) algorithm [7] based on the Hanning window (HNW), 3-term Max decay window (MDW), and the proposed method are adopted. At last, the proposed algorithm is evaluated by practical measurements.

3.1. Comparison with other algorithms without noise

An electrical power signal with 11 orders of harmonics, whose amplitudes are actually measured in an electric power network, is analyzed. This signal model is also used in Ref. [11] and can be expressed as

$$x(n) = \sum_{h=1}^{11} A_h \sin(2\pi h f n + \varphi_h) \quad (22)$$

where the fundamental frequency f is set as 50.2 Hz, the sampling frequency is 3200 Hz, the amplitude A_h and the phase φ_h of each harmonic component are given in **Table 1**.

The WIFFT and DPDC algorithms and the proposed method are adopted to make a comparison. The absolute errors of fundamental and harmonic frequencies by using different algorithms are listed in **Table 2**, where $aE-b$ represents $a \times 10^{-b}$.

Table 2 shows that the accuracy of frequency estimation obtained by the proposed method is higher than those obtained by the WIFFT and DPDC algorithms.

h	1	2	3	4	5	6	7	8	9	10	11
A_h (V)	240	0.1	12	0.1	2.7	0.05	2.1	0	0.3	0	0.6
φ_h (°)	0	10	20	30	40	50	60	–	80	–	100

Table 1. Parameters of each harmonic component of signal (22).

	h	1	2	3	4	5	6	7	9	11
WIFFT	HNW	7E-5	1E1	2E-3	1E-1	1E-3	5E-2	4E-4	9E-4	9E-5
	MDW	1E-6	1E-1	3E-5	8E-3	1E-5	1E-2	2E-5	4E-5	7E-6
DPDC	HNW	2E-4	6E1	2E-3	8E-1	7E-3	9E-1	5E-4	8E-3	4E-3
	MDW	3E-6	4E-1	2E-5	7E-2	1E-5	7E-2	2E-5	1E-6	8E-6
	Proposed	3E-11	3E-11	3E-11	3E-11	3E-11	3E-11	3E-11	3E-11	3E-11

Table 2. Absolute errors of fundamental and harmonic frequencies by using different algorithms.

3.2. With white Gaussian noise

To analyze the influence of white noise, the signal is superposed with zero-mean Gaussian noise. For each SNR value 3000 runs are performed by using $N = 512$ samples.

The estimation variances of fundamental frequency by using different algorithms are listed in **Table 3**. From **Table 3**, it can be seen that the proposed method can achieve the lowest

variances of frequency estimation among all the four adopted algorithms making it to be a good choice for high accurate frequency estimation.

SNR	WIFFTHNW	WIFFTMDW	DPDCHNW	DPDCMDW	Proposed
20 dB	3E-8	6E-8	1E-8	3E-8	9E-9
30 dB	3E-9	6E-9	1E-9	3E-9	9E-10
40 dB	3E-10	6E-10	1E-10	3E-10	9E-11
50 dB	3E-11	4E-11	1E-11	3E-11	9E-12
60 dB	4E-12	6E-12	1E-12	3E-12	9E-13
70 dB	4E-13	6E-13	1E-13	3E-13	8E-14
80 dB	4E-14	6E-14	2E-14	3E-14	9E-15

Table 3. Estimation variances of fundamental frequency by using different algorithms with white noise.

3.3. With frequency varying

In addition, the signal is simulated with SNR = 40 dB and frequency varying from 48.5 and 51.5 Hz to investigate the influences of both the white noise and frequency variations on frequency estimation.

The biases of frequency estimation by using different algorithms with frequency variations and SNR = 40 dB are listed in **Table 4**. As shown in **Table 4**, the biases of the frequency estimation obtained by the proposed method are 1–2 orders of magnitude lower than those obtained by the adopted WIFFT and DPDC algorithm.

f/Hz	WIFFTHNW	WIFFTMDW	DPDCHNW	DPDCMDW	Proposed
48.5	−8E-5	2E-6	7E-3	1E-4	−1E-6
49.0	−4E-4	1E-5	6E-3	9E-5	−5E-7
49.5	−7E-4	1E-5	3E-3	4E-5	1E-6
50.0	−7E-4	2E-5	7E-6	7E-5	2E-6
50.5	−5E-4	1E-5	2E-4	3E-6	3E-7
51.0	−2E-4	1E-6	1E-3	2E-5	1E-6
51.5	8E-5	2E-6	4E-3	5E-5	2E-6

Table 4. Biases of fundamental frequency estimation by using different algorithms with frequency variations and SNR = 40 dB.

3.4. Experimental results

The experiments are carried out by using the electrical power standard HBS1030, the data acquisition system ELVIS II of National Instrument. The measurement scheme is depicted in **Figure 2**.

As shown in **Figure 2**, the electrical power standard HBS1030 is used to generate multisine waves with the accuracy 0.05%. The signal is sampled by the data acquisition system ELVIS II with 16-bit analog-to-digital (A/D) converter. The sampling frequency is set as 3.2 kHz. The

measurement results of the fundamental frequency are shown in **Table 5**, where the “true” values for calculating the measurement absolute errors are provided by the electrical power standard HBS1030. The experimental results demonstrate that the presented algorithms have high accuracy in practice.




Figure 2. Measurement scheme for the laboratory experiment of the proposed method.

f	49.1	49.2	49.3	49.4	49.5	49.6	49.7	49.8	49.9
Error	4E-4	3E-4	2E-4	3E-4	2E-4	1E-4	2E-4	2E-4	1E-4
f	50.1	50.2	50.3	50.4	50.5	50.6	50.7	50.8	50.9
Error	1E-4	1E-4	2E-4	3E-4	3E-4	3E-4	3E-4	4E-4	4E-4

Table 5. Absolute errors of frequency estimation by experiments.

4. Conclusion

Since frequency estimation errors caused by harmonic interference and noise remain significant when the number of acquired signal cycles is very small, this chapter presents a parallel iteration method for frequency estimation using trigonometric decomposition. Due to the nature of trigonometric decomposition of periodic signal, the parallel iteration can be effectively executed to solve the nonlinear mapping functions of frequency estimation with a fast convergence. Additionally, the minimized square errors can be achieved by using the gradient-descent method in the iteration procedure. By observing the simulation and experimental results, it is seen that the proposed method is more accurate than the WIFFT and DPDC in comparisons.

Acknowledgements

This work has partially been supported by the National Natural Science Foundation of China under grant 61370014.

Author details

He Wen^{1*}, Junhao Zhang¹, Radek Martinek², Petr Bilik² and Zidek Jan²

*Address all correspondence to: he_wen82@126.com

1 College of Electrical and Information Engineering, Hunan University, Changsha, Hunan Province, China

2 Faculty of Electrical Engineering and Computer Science, VSB-Technical University of Ostrava, Ostrava, Czech Republic

References

- [1] J. Borkowski, D. Kania, and J. Mroczka, "Interpolated-DFT-based fast and accurate frequency estimation for the control of power," *IEEE Transactions on Industrial Electronics*, vol. 61, pp. 7026–7034, 2014.
- [2] MISAK, Stanislav; PROKOP, Lukas; BILIK, Petr. Power quality analysis in off-grid power system. In Conference Proceedings: The 10th International Conference, ELEKTRO 2014, Rajecke Teplice, Slovakia, 19 May 2014 through 20 May 2014, Category number CFP1448S-ART, Code 106459, pp. 337-342, ISBN: 978-147993721-9, DOI: 10.1109/ELEKTRO.2014.6848914.
- [3] M. D. Kusljevic, J. J. Tomic, and L. D. Jovanovic, "Frequency estimation of three-phase power system using weighted-least-square algorithm and adaptive FIR filtering," *IEEE Transactions on Instrumentation and Measurement*, vol. 59, pp. 322–329, 2010.
- [4] H. Wen, Z. S. Teng, and S. Y. Guo, "Triangular self-convolution window with desirable sidelobe behaviors for harmonic analysis of power system," *IEEE Transactions on Instrumentation and Measurement*, vol. 59, pp. 543–552, 2010.
- [5] D. Belega, D. Dallet, and D. Petri, "Accuracy of sine wave frequency estimation by multipoint interpolated DFT approach," *IEEE Transactions on Instrumentation and Measurement*, vol. 59, pp. 2808–2815, 2010.
- [6] I. Kamwa, S. R. Samantaray, and G. Joos, "Wide frequency range adaptive phasor and frequency PMU algorithms," *IEEE Transactions on Smart Grid*, vol. 5, pp. 569–579, 2014.
- [7] H. Wen, Z. S. Teng, Y. Wang, and X. G. Hu, "Spectral correction approach based on desirable sidelobe window for harmonic analysis of industrial power system," *IEEE Transactions on Industrial Electronics*, vol. 60, pp. 1001–1010, 2013.
- [8] E. Lavopa, P. Zanchetta, M. Sumner, and F. Cupertino, "Real-time estimation of fundamental frequency and harmonics for active shunt power filters in aircraft electrical systems," *IEEE Transactions on Industrial Electronics*, vol. 56, pp. 2875–2884, 2009.

- [9] C. Offelli and D. Petri, "Interpolation techniques for real-time multifrequency waveform analysis," *IEEE Transactions on Instrumentation and Measurement*, vol. 39, pp. 106–111, 1990.
- [10] L. Hsiung Cheng, "Power harmonics and interharmonics measurement using recursive group-harmonic power minimizing algorithm," *IEEE Transactions on Industrial Electronics*, vol. 59, pp. 1184–1193, 2012.
- [11] Z. Fusheng, G. Zhongxing, and Y. Wei, "The algorithm of interpolating windowed FFT for harmonic analysis of electric power system," *IEEE Transactions on Power Delivery*, vol. 16, pp. 160–164, 2001.

IntechOpen

