

We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,900

Open access books available

186,000

International authors and editors

200M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities



WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com



Use of Regression Analysis to Determine the Model of Lighting Control in Smart Home with Implementation of KNX Technology

Jan Vanus, Radek Martinek, Petr Bilik, Jan Zidek and He Wen

Additional information is available at the end of the chapter

<http://dx.doi.org/10.5772/116602>

Abstract

To optimize the management of operational and technical functions in the smart home (SH) and for use of effective methods of energy management in SH, it is generally necessary to provide statistics and process relevant data from operational measurement devices. This chapter describes the use of modern methods for statistical data processing using regression analysis techniques. The aim of the analysis is to describe the dependence of single measured values using an appropriate mathematical model that can be efficiently implemented in the control system of SH. This model can be used for the functions of supervision and diagnostics of optimum comfort setting inside the indoor environment of SH. Real experimental measurements of objective parameters of the indoor environment were realized in the selected rooms of unique wooden building in the passive standard. The researched methods were experimentally verified by classifying the behavior of lighting in the SH-selected rooms under specified conditions. The achieved experimental results will be used for the operating and technical functions control in SH for reducing the building operating costs.

Keywords: smart home, energy management, processing, measurement, regression model

1. Introduction

For monitoring, detection, and recognition of operating and technical conditions in SH, it is possible to use information from the measured data using operational sensors. Regression analysis can be used for the measured data processing and mathematical description of dependence between the measured quantities. Results from regression analysis can be

used in SH concept [1], SH care concept [2] (for quantify the activity for a complex set of SH activities and predict cognitive health of participants [3]), smart metering concepts [4–6], for example in a new method for estimating the demand response potential of residential air conditioning (A/C), using hourly electricity consumption data ("smart meter" data) from customer accounts in Northern California [7], and smart grid concepts [8, 9]. To visualize [10–13] and monitoring [14] of operational and technical functions in SH [15, 16], it is necessary to use a robust visualization tool with reliable storage of measured data with respect to the needs of the SH inhabitants [17]. In our case, the measured data are read from the individual KNX technology and BACnet technology sensors by means of the Desigo Insight visualization tool. The individual KNX and BACnet technology components are used for the blinds, lighting, cooling, heating, and ventilation control in SH (Figures 1 and 2).




Figure 1. Aerial view of the location of SH in terms of the cardinal points on the premises of the Technical University of Ostrava.



Figure 2. Side view of the SH wooden house describing the placement of rooms 202, 203, and 204.

For analysis of the measured data to determine the model of lighting control in SH (**Figures 1 and 2**) built-in within the Moravian-Silesian Wood Cluster (MSDK), we used the regression analysis methods. The measured values of nonelectrical quantities (e.g., illuminance, CO_2 , temperature, humidity, etc.) in different rooms (e.g., rooms 202, 203, 204) of the building offer more information about the behavior of the operational and technical system in SH. **Figure 3** shows the measured values of illuminance E_{202} (lx), E_{203} (lx), and E_{204} (lx) in rooms 202, 203, and 204, respectively, and outdoor illuminance E_{out} (lx).




Figure 3. Measured real values of illuminance E (lx) in SH on May 31, 2015 in rooms 202, 203, and 204 and outdoor illuminance E (lx).

2. Lighting control in SH using KNX technology

The actual lighting system for every room in SH is examined by using the DALI technology for dimming control and the KNX system for control by a closed-loop technology. The testing was performed on small lighting systems, the closed loop approach, which is adequate for illumination control to a constant illuminance E level, was used for the control.

2.1. Description of the KNX/DALI gateway system

The control options of the KNX/DALI gateway system (**Figure 4**) are not so extensive.

The sensor is connected directly to the KNX bus, whereby programming is facilitated. It should be noted that a bus-bar sensor must be selected in settings where information from the sensor needs to be transmitted to a large distance and hence, the hazard of data loss due to voltage decrease or interferences exists. The DALI ballasts are controlled by the KNX actuator (KNX/DALI Gateway N 141) and by one bus-bar sensor. The sensor at the ceiling sends information to the actuator, which evaluates light flux requirements in the master line.




Figure 4. Block diagram of lights control with using of the KNX components: system KNX/DALI gateway.

3. Proposed experiment

The aim of the experiment was to explore the dependence of the measured waveforms of illuminance E (lx) in the rooms 202, 203, and 204 on the outdoor illuminance E (lx) under the following conditions:

- The light in each room is turned off, the blinds are pulled up. The effect of the location of rooms 202, 203, and 204 (SH rotation) is compared from the perspective of the cardinal points at the outdoor illuminance $E_{\text{out}} > 10,000$ lx. The measurement took place on **September 07, 2014**.
- Light in rooms 202 and 204 is turned on, the blinds are pulled up. The light in room 203 is turned off. The automatic lighting control is set on the constant value of illuminance $E = 500$ lx in room 202. The automatic lighting control is set on the constant value of illuminance $E = 230$ lx in room 204. The effect of the location of rooms 202, 203, and 204 (SH rotation) is compared from the perspective of the cardinal points at the outdoor illuminance $E_{\text{out}} > 10,000$ lx. The measurement took place on **May 31, 2015**.

On the basis of the above-described conditions, a method for determining the optimal regression model to find the suitable mathematical description of states of operating and technical functions in SH was designed, in this case for lighting monitoring and control:

Step 1: calculating the correlation coefficients to determine the strength of dependence between the measured values of illuminance E (lx) in each room and outdoors.

Step 2: using linear regression to determine the regression line.

Step 3: selecting the best regression model describing the mathematical relationships between the measured quantities based on the calculated coefficient of determination R^2 (R -squared) value.

3.1. Correlation analysis: description

The measured data processing and obtaining the information about the strength of statistical dependence between the measured values of illuminance E (lx) in SH (202, 203, and 204 rooms) can be carried out by means of the method of correlation analysis. The force of (linear)

dependence between two measured nonelectrical quantities has been evaluated by means of the value of Pearson's correlation coefficient

$$R_{x,y} = \frac{\Sigma(x_i - \bar{x})(y_i - \bar{y})}{\sqrt{\Sigma(x_i - \bar{x})^2 \Sigma(y_i - \bar{y})^2}} \quad (1)$$

The correlation coefficient $R_{x,y}$ can take values from the closed interval $<-1, +1>$. The more the absolute value of the correlation coefficient approaches 1, the stronger the dependence of the random quantities.

3.2. Regression analysis: description

In terms of a mathematical description, this is a research of the relationship between two quantities, in which one of them, the so-called independent variable X (outdoor illuminance E (lx)), is to influence the other, the so-called dependent variable Y (measured illuminance E (lx) in each of the rooms 202, 203, and 204). Windows in rooms 203 and 204 are directed to the south and windows in room 202 are directed to the west (**Figure 1**). The results of selected individual measurements were processed into a plot of the fitted model with SW tool Statgraphics, which was used for a statistical analysis (**Figures 5–8**). The expected dependence between the studied variables, the so-called regression, was verified using this comprehensive statistical tool. The so-called linear regression was used which assumes a linear relationship between two quantities. Regression line equation can be written as:

$$Y_i = \beta_0 + \beta_1 x_i + e_i \quad (2)$$

The estimate of the regression line is written in one of the following ways:

$$\tilde{Y}_i = b_0 + b_1 x_i \quad (3)$$

$$\tilde{Y}_i = b_0^* + b_1(x_i - \bar{x}) \quad (\text{called deviation form of record}). \quad (4)$$

$$\tilde{Y}_i = \beta_0 + \beta_1 x_i + e_i' \quad (5)$$

where e_i denotes a residue, error.

Using the SW tool Statgraphics, linear regression model (ANOVA) conditions were verified. Each figure (**Figures 5–8**) shows prediction models (green lines) and single 95% confidence intervals in each plot of fitted models. It is possible to define the interval estimation in regression for the expected value (green lines—confidence limits). The confidence interval for each measurement is identified as the prediction interval. Each of the charts show the equation of the regression line and coefficient of determination R^2 indicating the quality of regression model.

$$R^2 = \frac{SS_R}{SS_R + SS_E} \quad (6)$$

where SS_R is the model sum of squares and SS_E is the error sum of squares.




Figure 5. Dependence of $E_{202}(I_x)$ in the room 202 on $E_{out}(I_x)$ —linear model, $R^2 = 0.527$ (September 07, 2014).




Figure 6. Dependence of $E_{202}(I_x)$ in the room 202 on $E_{out}(I_x)$ —logarithmic-Y square root-X model, $R^2 = 0.804$ (September 07, 2014).




Figure 7. Dependence of $E_{202}(I_x)$ in the room 202 on $E_{out}(I_x)$ —linear model, $R^2 = 0.7$ (May 31, 2015).




Figure 8. Dependence of $E_{202}(lx)$ in the room 202 on $E_{out}(lx)$ —reciprocal-Y model, $R^2 = 0.783$ (May 31, 2015).

4. Measured values

Based on the above-described conditions, the following values were measured and calculated.

Conditions a: The lighting is off: manual mode (blinds up); measured values: illuminance $E(lx)$ in rooms 202, 203, and 204 and outdoor illuminance $E(lx)$. Measurement day: **September 07, 2014**. The outdoor illuminance $E_{out} > 10,000(lx)$ (weather is clear).

In terms of evaluating the correlation analysis, it is to confirm the assumption that the measured waveforms of illuminance $E(lx)$ in rooms 203 and 204 have the greatest degree of similarity because the rooms are oriented to the south (**Table 1**). Comparing the correlation coefficients (**Table 1**) calculated from the measured illuminance $E(lx)$ values in 202 to the remaining rooms 203 and 204, the rotation of the room 202 to the other side of cardinal points (west) is apparent (**Figure 1**). **Figure 5** shows the plot of the fitted model for room 202, representing the linear regression model with $R^2 = 0.527$, it means that the model as fitted explains 52.7% of the variability of the illuminance in room 202.

Figure 6 shows the plot of the fitted model for room 202, representing the logarithmic-Y square root-X regression model with $R^2 = 0.804$.

Based on the calculated value of the coefficient of determination R^2 (**Table 2**), the logarithmic-Y square root-X model (Eq. (7)) (**Figure 6**) was design as the optimal model for individual rooms.

$$Y_i = e^{\beta_0 + \beta_1 \sqrt{X_i}} \quad (7)$$

	$E_{out}(lx)$	$E_{202}(lx)$	$E_{203}(lx)$	$E_{204}(lx)$
$E_{out}(lx)$		0.726	0.616	0.611
$E_{202}(lx)$	0.726		0.843	0.776
$E_{203}(lx)$	0.616	0.843		0.979
$E_{204}(lx)$	0611	0.776	0.979	

Table 1. Coefficients of correlation analysis to compare the measured waveforms of illuminance $E(lx)$ in rooms 202, 203, and 204 in SH on September 07, 2014.

Regression Models	R-Squared
Room 202 Logarithmic-Y square root-X	80.4%
Room 203 Logarithmic-Y square root-X	68.0%
Room 204 Logarithmic-Y square root-X	67.1%

Table 2. Comparison of room 202, 203, 204 regression models (7.9. 2014).

Conditions b: The lighting in rooms 202 and 204 is controlled on a constant illuminance (for room 202 $E_{const} = 500$ lx and room for 204 $E_{const} = 230$ lx): automatic mode (blinds up); the lighting was turned off in room 203 (**Figure 2**). Measured variables: illuminance E (lx) in rooms 202, 203, and 204 and outdoor illuminance E_{out} (lx) (**Table 3**). Measurement day: **May 31, 2015**. The outdoor illuminance $E_{out} > 10,000$ (lx) (weather is clear).

	E_{out} (lx)	E_{202} (lx)	E_{203} (lx)	E_{204} (lx)
E_{out} (lx)		0.837	0.862	0.763
E_{202} (lx)	0.837		0.845	0.792
E_{203} (lx)	0.862	0.845		0.802
E_{204} (lx)	0.763	0.792	0.802	

Table 3. Coefficients of correlation analysis to compare the measured waveforms of illuminance E (lx) in rooms 202, 203, 204 in SH (May 31, 2015).

Based on the calculated value of the coefficient of determination R^2 (**Table 4**), the logarithmic-Y square root-X model was design as the optimal model for rooms 203 and 204. However, the reciprocal-Y model was calculated as the optimal model for room 202 (**Table 4**).

Regression model	R-squared
Room 202 Reciprocal-Y	78.3%
Room 203 Logarithmic-Y square root-X	91.4%
Room 204 Logarithmic-Y square root-X	80.3%

Table 4. Comparison of room 202, 203, 204 regression models (31/05/2015).

The plot of the fitted model for room 202 with linear regression model is shown in **Figure 7**. The plot of the fitted model for room 202 with the reciprocal-Y regression model is shown in **Figure 8**.

5. Conclusion

This chapter described use of the regression analysis method to determine the regression model (linear regression model, reciprocal-Y regression model and logarithmic-Y square root-X regression model) of lighting control in SH with a potential use for the function of diagnosing the optimal settings for the corresponding comfort of interior lighting control

in SH rooms 202, 203, and 204 via the KNX technology. Based on the measured values, it was demonstrated that it is possible to determine a corresponding regression model of mathematical description of operational and technical function behaviors in SH under the specific conditions for the lighting control in this case. Since the P -value in the ANOVA table is less than 0.01, there is a statistically significant relationship between illuminance of the room and illuminance of outdoors at the 99% confidence level in each of cases. Since the P -value in the t -tests for both of parameters intercepts and slope is less than 0.01, there is not a reason to extract these parameters from models. Based on the experiments, the described regression models can be used to further classify and describe the behavior of operational and technical conditions in SH. A database for each of the measured quantities with a precise description of baseline conditions of the SH behavior will be presented with the next chapter. More modern methods for classification and identification [18–23] will be used for compare and optimization of the operational and technical functions control in SH.

Acknowledgements

This chapter has been elaborated within the framework of the project SP2016/146 of the Student Grant System, VSB-TU Ostrava, Czech Republic.

Author details

Jan Vanus^{1*}, Radek Martinek¹, Petr Bilik¹, Jan Zidek¹ and He Wen²

*Address all correspondence to: jan.vanus@vsb.cz

¹ Department of Cybernetics and Biomedical Engineering, Faculty of Electrical Engineering and Computer Science, VSB-Technical University of Ostrava, Ostrava, Czech Republic

² Hunan University, Changsha, China

References

- [1] D. N. Monekosso and P. Remagnino, "Data reconciliation in a SH sensor network," *Expert Systems with Applications*, vol. 40, pp. 3248–3255, Jun 15 2013.
- [2] O. Kwon, J. M. Shim, and G. Lim, "Single activity sensor-based ensemble analysis for health monitoring of solitary elderly people," *Expert Systems with Applications*, vol. 39, pp. 5774–5783, Apr 2012.
- [3] P. N. Dawadi, D. J. Cook, M. Schmitter-Edgecombe, and C. Parsey, "Automated assessment of cognitive health using SH technologies," *Technology and Health Care*, vol. 21, pp. 323–343, 2013.

- [4] A. Kavousian, R. Rajagopal, and M. Fischer, "Determinants of residential electricity consumption: Using smart meter data to examine the effect of climate, building characteristics, appliance stock, and occupants' behavior," *Energy*, vol. 55, pp. 184–194, Jun 15 2013.
- [5] A. Kavousian, R. Rajagopal, and M. Fischer, "Ranking appliance energy efficiency in households: Utilizing smart meter data and energy efficiency frontiers to estimate and identify the determinants of appliance energy efficiency in residential buildings," *Energy and Buildings*, vol. 99, pp. 220–230, Jul 15 2015.
- [6] F. McLoughlin, A. Duffy, and M. Conlon, "A clustering approach to domestic electricity load profile characterisation using smart metering data," *Applied Energy*, vol. 141, pp. 190–199, Mar 1 2015.
- [7] M. E. H. Dyson, S. D. Borgeson, M. D. Tabone, and D. S. Callaway, "Using smart meter data to estimate demand response potential, with application to solar energy integration," *Energy Policy*, vol. 73, pp. 607–619, Oct 2014.
- [8] D. Huang, M. Thottan, and F. Feather. Designing customized energy services based on disaggregation of heating usage, *IEEE Transactions on Smart Grid*, vo. 5, pp. 569–579, 2013.
- [9] G. Kalogridis, C. Efthymiou, S. Z. Denic, T. A. Lewis, and R. Cepeda, "Privacy for smart meters: towards undetectable appliance load signatures," *2010 IEEE 1st International Conference on Smart Grid Communications (SmartGridComm)*, pp. 232–237, 2010.
- [10] J. Vanus, P. Kucera, and J. Koziorek, "The software analysis used for visualization of technical functions control in smart home care," in *3rd Computer Science On-line Conference, CSOC 2014*, vol. 285, R. Silhavy, R. Senkerik, Z. K. Oplatkova, P. Silhavy, and Z. Prokopova, Eds., Berlin: Springer Verlag, pp. 549–558, 2014.
- [11] J. Vanus, P. Kucera, and J. Koziorek, "Visualization software designed to control operational and technical functions in smart homes," in *3rd Computer Science On-line Conference, CSOC 2014*, vol. 285, R. Silhavy, R. Senkerik, Z. K. Oplatkova, P. Silhavy, and Z. Prokopova, Eds., Berlin: Springer Verlag, pp. 559–569, 2014.
- [12] J. Vanus, P. Kucera, J. Koziorek, Z. Machacek, and R. Martinek, "Development of a visualisation software, Implemented with comfort smart home wireless control system," in *6th FTRA International Conference on Computer Science and its Applications, CSA 2014*, vol. 330, H. Y. Jeong, I. Stojmenovic, J. J. Park, and G. Yi, Eds., Berlin: Springer Verlag, pp. 580–589, 2015.
- [13] J. Vanus, P. Kucera, R. Martinek, and J. Koziorek, "Development and testing of a visualization application software, implemented with wireless control system in smart home care," *Human-centric Computing and Information Sciences*, vol. 4, p. 18, 2014.
- [14] J. Vanus, R. Martinek, P. Bilik, J. Koziorek, and A. Dracka, "Smart home remote monitoring using PI System Management Tools," in *8th International Scientific Symposium on Electrical Power Engineering, ELEKTROENERGETIKA 2015*, pp. 372–375, 2015.
- [15] T. Novak, J. Vanus, J. Sumpich, J. Koziorek, K. Sokansky, and R. Hrbac, "Possibility to achieve the energy savings by the light control in smart home," in *7th International*

Scientific Symposium on Electrical Power Engineering, ELEKTROENERGETIKA 2013, Stara Lesna, pp. 260–263, 2013.

- [16] J. Vanus, T. Novak, J. Koziorek, J. Konecny, and R. Hrbac, "The proposal model of energy savings of lighting systems in the smart home care," in *12th IFAC Conference on Programmable Devices and Embedded Systems, PDeS 2013*, Velke Karlovice, pp. 411–415, 2013.
- [17] J. Vanus, J. Koziorek, and R. Hercik, "Design of a smart building control with view to the senior citizens' needs," in *12th IFAC Conference on Programmable Devices and Embedded Systems, PDeS 2013*, Velke Karlovice, pp. 422–427, 2013.
- [18] J. Vanus and J. Koziorek, "Employment of dynamic time warping method for monitoring states in smart home," in *4th International Workshop on Computer Science and Engineering-Winter, WCSE 2014*, Hong Kong, China, 26–28 December, 2014.
- [19] C. J. C. Burges, "A tutorial on support vector machines for pattern recognition," *Data Mining and Knowledge Discovery*, vol. 2, pp. 121–167, Jun 1998.
- [20] A. K. Jain, R. P. W. Duin, and J. C. Mao, "Statistical pattern recognition: a review," *IEEE Transactions on Pattern Analysis and Machine Intelligence*, vol. 22, pp. 4–37, Jan 2000.
- [21] V. N. Vapnik, "An overview of statistical learning theory," *IEEE Transactions on Neural Networks*, vol. 10, pp. 988–999, Sep 1999.
- [22] J. P. Weir, "Quantifying test-retest reliability using the intraclass correlation coefficient and the SEM," *Journal of Strength and Conditioning Research*, vol. 19, pp. 231–240, Feb 2005.
- [23] S. Yan, D. Xu, B. Zhang, H.-J. Zhang, Q. Yang, and S. Lin, "Graph embedding and extensions: A general framework for dimensionality reduction," *IEEE Transactions on Pattern Analysis and Machine Intelligence*, vol. 29, pp. 40–51, Jan 2007.

IntechOpen

