

# We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,900

Open access books available

186,000

International authors and editors

200M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities



WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index  
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?  
Contact [book.department@intechopen.com](mailto:book.department@intechopen.com)

Numbers displayed above are based on latest data collected.  
For more information visit [www.intechopen.com](http://www.intechopen.com)



---

## **Application of Numeric Routine for Simulating Transients in Power Line Communication (PLC) Systems**

---

Afonso José do Prado, Luis Henrique Jus,  
Melissa de Oliveira Santos, Elmer Mateus Gennaro,  
André Alves Ferreira, Thainá Guimarães Pereira,  
Aghatta Cioqueta Moreira,  
Juliana Semiramis Menzinger,  
Caio Vinícius Colozzo Grilo,  
Marinez Cargnin Stieler and José Pissolato Filho

Additional information is available at the end of the chapter

<http://dx.doi.org/10.5772/intechopen.74753>

---

### **Abstract**

Applying numerical routines based on trapezoidal rule of integration (Heun's method for numerical integration), simple models of transmission lines are used to analyze and simulate the propagation of communication signals in PLC-type systems (power line communication systems). Such systems are shared by the same systems for the transfer of electrical power and signal transmission. For the mentioned routines, the main objectives are: simulate the propagation of electromagnetic transients in these systems and analyze the interference of such phenomena in the transmitted signal. Such simulations are performed with classical structures that represent infinitesimal units of transmission lines. Modifications in the structure of such units are analyzed to improve the results obtained by the mentioned simulations.

**Keywords:** waveguide, electromagnetic transient, eigenvalues and eigenfunctions, linear systems, numerical analysis, simulation, state space methods, numerical integration method, transmission line modeling

---

## 1. Introduction

Systems of conductors for signal transmission or power transmission, that are, in general, classified as waveguide systems, systems of protection, coordination and control of the main system, the waveguide system, are as important as the conductors that are used. For projecting these accessory systems, analysis of short-circuit levels, overvoltages, as well as the duration of transient phenomena are very important [1–9]. In several situations, it is not possible to perform tests related to the occurrence of transient electromagnetic phenomena in actual transmission systems [10]. One situation for this is when the systems are in the design phase and have not yet been built or fabricated. Another situation is where the system cannot be shut down for maintenance or testing, for example, in the case of transmission lines responsible for interconnecting great power plants to great consumer centers. Because the theory and equations related to the propagation of electromagnetic fields in systems of conductors can be related to power and signal transmissions, different transmission systems are modeled as transmission lines or waveguides [1–14]. For example, systems with low voltage, low power and very high frequency for signal transmission and systems with very high voltage, very high power and low frequency can be modeled as transmission lines or waveguides. In analyses of these types of electrical systems affected by electromagnetic transient phenomena, time-domain and frequency-dependent models are considered efficient and accurate for applications in this field [1–16]. Ways to improve these models have been researched yet, searching for increasing the accuracy of the results and the efficiency of the applied methods. For the analysis of the propagation of transient electromagnetic phenomena in electrical networks using transmission line theory, the waveguides can be decomposed into infinitesimal parts modeled by  $\pi$  circuits or T circuits [3–11, 17]. Simple numerical routines for this type of analysis can be good tools for undergraduate students to investigate and simulate these types of phenomena [11, 18–20] and to test improvements in the numerical model applied to the mentioned analyses. On the other hand, for more complex numerical or simpler numerical models, to a greater or lesser degree, respectively, numerical routines are influenced by numerical errors [1–23].

Considering the simplified representation of a transmission line by  $\pi$  circuit cascades, the solution of this system is obtained with the application of trapezoidal integration, and the results are affected by numerical oscillations or Gibbs' oscillations [1–27]. It is possible to minimize the influence of numerical oscillations or Gibbs' oscillations, in the obtained results, by means of structural modifications of these circuits [11, 17]. The proposed modification initially involves adding damping resistors ( $R_D$ ) in all  $\pi$  circuits [11, 17]. These resistors are introduced in parallel with the elements in a series of the  $\pi$  circuits (elements representing the longitudinal parameters of transmission lines or waveguides) [28]. However, in spite of decreasing the effects of numerical oscillations considerably, the incorporation of damping resistances in each circuit of the cascade increases the computational time to perform the analyses and simulations of electromagnetic phenomena propagation. So, an alternative structure for the  $\pi$  circuit cascade is proposed, which involves the absence of damping resistance in half of all  $\pi$  circuits, all of which circuits are grouped in the center of the cascade. In other cases, the different structures of  $\pi$  circuits, with and without damping resistance, are applied

alternately in the composition of the cascade used to represent transmission lines or waveguides for analysis and simulations of transient electromagnetic phenomena propagation [29–32]. If the damping resistances are not applied in each  $\pi$  circuit of the cascade that represents the waveguides or the transmission lines, the numerical simulation can be numerically unstable [28–32]. The results of several simulations that will be used to compare and determine which structure is adequate to reduce Gibbs' oscillations without compromising the computational time will be presented. In this case, it is considered cascades with classical  $\pi$  circuits and cascades with damping resistances applied in each  $\pi$  circuit. The results presented for these comparisons are based on output voltage versus time graphs and three-dimensional graphs that establish the relationship between the first voltage peaks with the number of  $\pi$  circuits and the damping resistance values during the first voltage reflection to the end of the line.


## 2. Trapezoidal rule

The trapezoidal rule or Heun's method is a numerical integration method based on the transformation of differential equations into their algebraic equivalents. The integral of a function is approximated by the first-degree function related to the original function (the area of a trapezoid) where the endpoints are approximated by points of intersection between the original and the first-degree functions. By improving approximation accuracy, a large range of independent variable values can be subdivided into equally small portions, called integration steps (**Figure 1**).

Applying the trapezoidal rule, the equation below is obtained:

$$\int_{t(k)}^{t(k+1)} f(t) dt \approx \frac{\Delta t}{2} [f(t_{k+1}) + f(t_k)] \quad (1)$$

The time step is



**Figure 1.** Schema of trapezoidal rule for numerical integration.

$$\Delta t = t_{k+1} - t_k \quad (2)$$

Using Eq. (1), Eq. (3) is obtained:

$$\int_{t(k)}^{t(k+1)} f(t) dt \approx y_{t+1} - y_t = \Delta y \quad \rightarrow \quad y_{t+1} = y_t + \frac{\Delta t}{2} [f(t_k) + f(t_{k+1})] \quad (3)$$

Considering a model of a physical system (or physical phenomenon),  $x$  is a vector composed by state variables of the mentioned system. Also, considering that the physical system is described by the first-order differential linear system, Eq. (4) is obtained:

$$\frac{dx}{dt} = Ax + Bu \quad \rightarrow \quad \dot{x} = Ax + Bu \quad (4)$$

In this case, the  $A$  matrix represents the system, the  $B$  matrix is related to independent inputs of the system, the  $u$  vector is the input vector, and the  $x$  vector is the vector of the state variables of the system. For numerical applications, Eq. (5) is considered:

$$\frac{\Delta x}{\Delta t} \approx \frac{dx}{dt}, \quad \text{if } \Delta t \rightarrow 0 \quad (5)$$

From Eqs. (3)–(5), for very small time step, Eq. (6) is obtained:

$$x_{t+1} = x_t + \frac{\Delta t}{2} [\dot{x}_{t+1} + \dot{x}_t] \quad \rightarrow \quad x_{t+1} = x_t + \frac{\Delta t}{2} [Ax_{t+1} + Bu_{t+1} + Ax_t + Bu_t] \quad (6)$$

Simplifying Eq. (6) and considering that  $I$  is the identity matrix, Eq. (7) is obtained:

$$\begin{aligned} x_{t+1} &= \left[ I - \frac{\Delta t}{2} A \right]^{-1} \cdot \left[ I + \frac{\Delta t}{2} A \right] x_t + \left[ I - \frac{\Delta t}{2} A \right]^{-1} \cdot \frac{\Delta t}{2} B [u_{t+1} + u_t] \\ x_{t+1} &= A_1 A_2 x_t + A_1 B_1 [u_{t+1} + u_t] \end{aligned} \quad (7)$$


In this case,  $A_1$ ,  $A_2$ , and  $B_1$  elements in Eq. (7) are

$$\begin{aligned} y_{t+1} &= \left[ I - \frac{\Delta t}{2} A \right]^{-1} \cdot \left[ I + \frac{\Delta t}{2} A \right] y_t + \left[ I - \frac{\Delta t}{2} A \right]^{-1} \cdot \frac{\Delta t}{2} B [u_{t+1} + u_t] \\ y_{t+1} &= A_1 A_2 y_t + A_1 B_1 [u_{t+1} + u_t] \end{aligned} \quad (8)$$

Using Eq. (7), it is possible to determine the next state ( $x_{t+1}$ ) of the analyzed system, if the current state ( $x_t$ ) is known. This characteristic is very important for numerical applications where the functions that describe the physical system are not known or do not exist.

### 3. Transmission line equivalent circuit model

Analyzing the propagation of waves in transmission lines or waveguides, these systems can be decomposed into infinitesimal portions that can be represented by  $\pi$  circuits. For representing



**Figure 2.** The generic unit of  $\pi$  circuits.

the whole system, there is a need to use a cascade with a large number of  $\pi$  circuits. The generic unit of  $\pi$  circuits is shown in **Figure 2**.

Based on the structure of  $\pi$  circuit and Kirchhoff's laws, the relations of voltages and currents for this generic unit are determined by Eq. (9):

$$\frac{di_k}{dt} = \dot{i}_k = \frac{1}{L}(v_{k-1} - R \cdot i_k - v_k) \quad \text{and} \quad \frac{dv_k}{dt} = \dot{v}_k = \frac{1}{C}(i_k - G \cdot v_k - i_{k+1}) \quad (9)$$

Each  $\pi$  circuit has two state variables: the transversal voltage ( $v_k$ ) and the longitudinal current ( $i_k$ ). For describing the whole transmission line or the waveguide, it is necessary to use an  $n$ -order linear numerical system. So, the  $x$  vector is

$$x = [i_1 \quad v_1 \quad i_2 \quad v_2 \quad \cdots \quad i_k \quad v_k \quad \cdots \quad i_n \quad v_n]^T \quad (10)$$

In this case, the structure of the  $A$  matrix is based on Eq. (9):

$$A = \begin{bmatrix} -\frac{R}{L} & -\frac{1}{L} & 0 & \cdots & \cdots & 0 \\ \frac{1}{C} & -\frac{G}{C} & -\frac{1}{C} & \ddots & \ddots & \vdots \\ 0 & \ddots & \ddots & \ddots & \ddots & \vdots \\ \vdots & \ddots & \frac{1}{C} & -\frac{G}{C} & -\frac{1}{C} & 0 \\ \vdots & \ddots & \ddots & \frac{1}{L} & -\frac{R}{L} & -\frac{1}{L} \\ 0 & \cdots & \cdots & 0 & \frac{2}{C} & -\frac{G}{C} \end{bmatrix} \quad (11)$$

Considering only one voltage source in the initial of the transmission line or the waveguide, the  $B$  vector is in Eq. (12). If other sources are connected to the system in different points, the  $B$  vector should be adequately changed:

$$B = \left[ \frac{1}{L} \quad 0 \quad \cdots \quad 0 \right]^T \quad (12)$$

If damping resistances are included in  $\pi$  circuits, this is shown in **Figure 3**. The relations of voltages and currents for the generic unit of  $\pi$  circuits are in Eq. (13):

$$\dot{i}_k = \frac{v_{k-1} - R \cdot i_k - v_k}{L} \quad \text{and} \quad \dot{v}_k = \frac{i_k - (2G_D + G)v_k + G_D(v_{k-1} + v_{k+1}) - i_{k+1}}{C} \quad (13)$$

Based on **Figure 3** and Eq. (12), the structure of the  $B$  vector is in Eq. (14). In this case, only one voltage source at the initial of the waveguide is considered:

$$B = [1/L \quad G_D/C \quad 0 \dots 0]^T \quad (14)$$

Also, based on **Figure 3** and Eq. (12), the structure of the  $A$  matrix is in Eq. (15). In this case, new non-null elements are included because of the application of damping resistances:


$$A = \begin{bmatrix} -\frac{R}{L} & -\frac{1}{L} & 0 & \dots & \dots & \dots & \dots & 0 \\ \frac{1}{C} & -\frac{(G+2G_D)}{C} & -\frac{1}{C} & \frac{G_D}{C} & \ddots & \ddots & \ddots & \vdots \\ 0 & \ddots & \ddots & \ddots & \ddots & \ddots & \ddots & \vdots \\ \vdots & \ddots & \frac{1}{L} & -\frac{R}{L} & -\frac{1}{L} & \ddots & \ddots & \vdots \\ \vdots & \ddots & \frac{G_D}{C} & \frac{1}{C} & -\frac{(G+2G_D)}{C} & -\frac{1}{C} & \frac{G_D}{C} & \vdots \\ \vdots & \ddots & \ddots & \ddots & \ddots & \ddots & \ddots & 0 \\ \vdots & \ddots & \ddots & \ddots & \ddots & \frac{1}{L} & -\frac{R}{L} & -\frac{1}{L} \\ 0 & \dots & \dots & \dots & 0 & \frac{G_D}{C} & \frac{2}{C} & -\frac{(G+2G_D)}{C} \end{bmatrix} \quad (15)$$

The damping resistance is determined by

$$R_D = k_D \frac{2L}{\Delta t}, \quad G_D = \frac{1}{R_D}, \quad k_D = \frac{R_D \Delta t}{2L} = \frac{\Delta t}{2LG_D} \quad (16)$$

The  $R$ ,  $L$ ,  $G$ , and  $C$  values are calculated by Eq. (17) where  $d$  is the line length and  $n$  is the number of  $\pi$  circuits:

$$R = R' \cdot \frac{d}{n}, \quad L = L' \cdot \frac{d}{n}, \quad G = G' \cdot \frac{d}{n}, \quad C = C' \cdot \frac{d}{n} \quad (17)$$



**Figure 3.** Introduction of damping resistances in  $\pi$  circuits.




## 4. Numerical computation


In **Figure 4**, the flowchart applied to obtain the results of electromagnetic transient phenomena simulations without the introduction of damping resistances is shown.

In case of **Figure 4**, the flowchart is based on Eq. (6) to Eq. (12). The simulations are carried out considering that the analyzed waveguide or the transmission line is connected to an independent step voltage source of 1 pu. The end line is opened, and, because of this, the value of the propagated voltage wave is doubled compared to the voltage value at the initial line. Using the flowchart of **Figure 4**, the parameter values applied to the obtained results are  $R' = 0.03 \Omega/\text{km}$ ,  $L' = 1.2 \text{ mH/km}$ ,  $G' = 0.5 \mu\text{S/km}$ ,  $C' = 10 \text{ nF/km}$ ,  $\Delta t = 50 \text{ ns}$ , and  $d = 5 \text{ km}$ .

In **Figure 5**, the flowchart related to the inclusion of damping resistances in the  $\pi$  circuits for representing the analyzed waveguide or the transmission line is shown. The values of  $R'$ ,  $L'$ ,



**Figure 4.** Flowchart for numerical simulations without application of damping resistances.



**Figure 5.** Flowchart for numerical simulations with applications of damping resistances.




$G'$ ,  $C'$ ,  $\Delta t$ , and  $n$  are the same that were used to simulations without damping resistances. The analyzed system is also connected to the 1 pu step voltage, and the end line is also opened.

## 5. Effects of the simulation accuracy without damping resistance

Applying the flowchart of **Figure 4**, the main obtained results are shown in **Figure 6**. For these results, the time step ( $\Delta t$ ) is 50 ns, and the number of  $\pi$  circuits is changed from 50 to 500 with step variation of 1 unit. In general, when the voltage waves are reflected the first time at the end line, the voltage values reach 2.5 pu, initially. This initial value is due to the influence of numerical oscillations or Gibbs' oscillations. These oscillations cause numerical errors of 25% because, in this case, the exact values should be 2 pu. While the reflected voltage wave is propagated to the line initial, after new reflection at the initial line, Gibbs' oscillations are being damped. In case of the second voltage wave reflection at the end line, the voltage values should be null ones. In this instant time, there are numerical problems again that are also represented by Gibbs' oscillations. So, the results obtained from numerical routine based on the flowchart without the application of damping resistances are highly influenced by numerical oscillations during abrupt changes at voltage related to the energization of the transmission line or the waveguide. For the systems modeled by the transmission line theory concepts, the step voltage source represents the main problems that introduce abrupt changes in voltages in the line.


The numerical routine described by the flowchart is simple. Despite this characteristic, the numerical simulations lead to results with errors of 25% independently that the number of  $\pi$  circuits is applied. The increase of the number of  $\pi$  circuits is not related to a correspondent decrease of the numerical errors and numerical oscillations in the obtained results. A proposed alternative is the introduction of damping resistances for decreasing numerical errors and Gibbs' oscillations in the obtained results. Next, both items show the results obtained with this alternative.




**Figure 6.** The step voltage wave propagation varying the number of circuits for the first reflection at the analyzed end line without the application of damping resistances.

## 6. Improvement of the simulation accuracy with damping resistance

Applying damping resistances and using the  $k_D$  factor as 2.5, the obtained results are shown in **Figure 7**. Comparing **Figure 7** to **Figure 6**, if the number of  $\pi$  circuits is increased, numerical oscillations or Gibbs' oscillations are decreased. So, considering a constant value for the  $k_D$  factor, if an adequate number of  $\pi$  circuits is applied, numerical oscillations can be minimized. Similar results can be obtained changing the value of the  $k_D$  factor. In this case, in **Figure 8**, the results are obtained using 200  $\pi$  circuits for different values of the  $k_D$  factor. Based on these results, the numerical oscillations are decreased if the factor is decreased. Because in this chapter the  $k_D$  is the integer, the lower value of  $k_D$  is 1, and the best reductions of numerical



**Figure 7.** The step voltage wave propagation varying the number of circuits for the first reflection at the analyzed end line with the application of damping resistances and  $k_D = 2.5$ .




**Figure 8.** The step voltage wave propagation varying the factor  $k_D$  for the first reflection at the analyzed end line with the application of damping resistances and  $n = 200$ .


oscillations are obtained for this value. Based on **Figures 7 and 8**, there are two parameters that can minimize numerical oscillations: the number of  $\pi$  circuits and the value of the  $k_D$  factor.

7. Effects of  $k_D$  factor variation

Applying damping resistances, from **Figures 9–15**, the number of  $\pi$  circuits is changed from 50 to 500 for different values of the  $k_D$  factor. In **Figure 9**, the results are related to  $k_D = 1$ . For this value of the  $k_D$  factor, the numerical oscillations are highly minimized. Low numerical oscillations are observed for the number of  $\pi$  circuits about 50. In **Figure 10**, with  $k_D = 2.5$ , the numerical oscillations reach higher values than the results shown in **Figure 9**, and they are related to a range from 50 to about 100 that is bigger than the range observed in **Figure 9**. In



**Figure 9.** Results for different quantities of  $\pi$  circuits and  $k_D = 1$ .



**Figure 10.** Results for different quantities of  $\pi$  circuits and  $k_D = 2.5$ .




Figure 11. Results for different quantities of  $\pi$  circuits and  $k_D = 5$ .




Figure 12. Results for different quantities of  $\pi$  circuits and  $k_D = 7.5$ .

Figure 10, the second overvoltage peak that is lower than the first overvoltage peak is also observed. Both overvoltage peaks are caused by numerical oscillations. Compared to Figure 9, in Figure 10, for the same time interval, the number of overvoltage peaks is increased showing that the damping of numerical oscillations is not effective as well as when the  $k_D$  factor is equal to 1. Based on Eq. (16), the  $k_D$  factor is related to the time step ( $\Delta t$ ), and the value of this factor is also related to the frequency of the oscillations that are significantly reduced by the application of damping resistances. So, increasing the value of the  $k_D$  factor, not all numerical oscillations are damped. Because of this, the overvoltage peaks are increased, and other lower overvoltage peaks arise.

Increasing the value of the  $k_D$  factor, the influence of damping resistances is decreased. So, the voltage peaks caused by Gibbs' oscillations are increased, if the  $k_D$  factor is increased. This




Figure 13. Results for different quantities of  $\pi$  circuits and  $k_D = 10$ .




Figure 14. Results for different quantities of  $\pi$  circuits and  $k_D = 12.5$ .

effect is observed in **Figures 11–15**. The highest voltage peak for each value of the  $k_D$  factor is about 2.5 pu. Another consequence is that the second voltage peak is increased, while the  $k_D$  factor is decreased. The influence of damping resistances for minimizing the numerical oscillations in proposed transmission line model is more effective for small values for the  $k_D$  factor, considering the lower limit as 1.

Analyzing the results from **Figures 9–15**, the highest voltage peak for each value of the  $k_D$  factor is related to the lowest number of  $\pi$  circuits. Increasing the number of  $\pi$  circuits for the same  $k_D$  factor value, the voltage peak values can be decreased. Changing adequately the  $k_D$  factor and the number of  $\pi$  circuits, Gibbs' oscillations can be minimized. The sets of  $k_D$  values and the numbers of  $\pi$  circuits that minimize the numerical oscillations can be determined by analyzing the first voltage peaks of a great number of simulations.






Figure 15. Results for different quantities of  $\pi$  circuits and  $k_D = 15$ .

## 8. Number of $\pi$ circuit variation

Setting the number of  $\pi$  circuits, the results are analyzed considering the  $k_D$  changing from 1 to 10. Applying 50 units of  $\pi$  circuits, the voltage peaks are not damped significantly if the  $k_D$  is changed. It is observed in **Figure 16**. For 100 units of  $\pi$  circuits, the voltage peaks are damped for values of the  $k_D$  factor from 1 to about 3 (**Figure 17**).

Considering 150 units of  $\pi$  circuits, the range of the  $k_D$  factor that the voltage peaks are damped is bigger than the previous results. It is shown in **Figure 18**. In this case, this  $k_D$  factor range is from 1 to about 4. For 200 units of  $\pi$  circuits, the higher limit of the mentioned range is increased to about 5 (**Figure 19**). If 250 units of  $\pi$  circuits are applied, the range is further increased and the higher limit is about 6 (**Figure 20**). Similar relations are observed in




Figure 16. Results for different values of the  $k_D$  factor and  $n = 50$ .




Figure 17. Results for different values of the  $k_D$  factor and  $n = 100$ .




Figure 18. Results for different values of the  $k_D$  factor and  $n = 150$ .




Figure 19. Results for different values of the  $k_D$  factor and  $n = 200$ .






Figure 20. Results for different values of the  $k_D$  factor and  $n = 250$ .

**Figures 21–23.** If the quantity of  $\pi$  circuits is increased, the range of the  $k_D$  factor that is related to the minimization of Gibbs' oscillations is increased. In this case, the increase of this quantity is directly related to the increase of the simulation time.

Still analyzing **Figures 21–23**, it is observed that the relation between the number of the  $\pi$  circuits and the influence of the  $k_D$  factor in minimizing the voltage peaks is not linear. There is a saturation point where the increase of the number of  $\pi$  circuits can no longer minimize significant Gibbs' oscillations and, consequently, the voltage peaks in obtained simulations. Because of this, another type of analysis is shown in **Figure 24**. In this case, the voltage peaks are related to the correspondent values of the  $k_D$  factor and the number of  $\pi$  circuits. In case of **Figure 24**, the results are obtained to a time step ( $\Delta t$ ) of 50 ns. A region where the numerical oscillations are critically damped and there are no voltage peaks can be observed. In this case, the voltage value is 2 pu and corresponds to the exact values that can be obtained using a numerical routine of Laplace's transformation. So, a specific type of analysis is related to the




Figure 21. Results for different values of the  $k_D$  factor and  $n = 300$ .




Figure 22. Results for different values of the  $k_D$  factor and  $n = 400$ .




Figure 23. Results for different values of the  $k_D$  factor and  $n = 500$ .





Figure 24. Voltage peaks related to the  $k_D$  factor and the number of  $\pi$  circuits for  $\Delta t = 50 \, \text{ns}$ .

application of three-dimensional graphics showing the influence of the  $k_D$  factor values and the number of  $\pi$  circuits on the voltage peaks obtained during the numerical simulations. It is shown in the next section.

## 9. Other analyses

Based on the results shown in the previous sections, it is concluded that the numerical oscillations and, consequently, the voltage peaks obtained by the proposed model are influenced jointly by two factors: the damping resistance value and the number of  $\pi$  circuits applied to the numerical simulations of electromagnetic phenomena in waveguides or transmission lines. Because of this, the analyses of this joint influence must be based on three-dimensional graphics. In **Figure 24**, the highest voltage peaks during the first wave reflection on the transmission end line or the receiving end terminal of the waveguide are shown. These peaks depend on the  $k_D$  factor and the number of  $\pi$  circuits considering the time step as 50 ns. In **Figures 25** and **26**, the time steps are 10 ns and 200 ns, respectively. These graphics are used for completing the analyses carried out in the previous sections.

Based on the last three sets of obtained results of this chapter (**Figures 24–26**), for a specific time step, there are sets of the number of  $\pi$  circuits and the  $k_D$  factor values adequate for minimizing Gibbs' oscillations and, consequently, the voltage peaks in simulations of electromagnetic transient phenomena in transmission lines using the numerical routine proposed in this chapter. The time step choice or determination is related to the fundamental frequency of the simulated phenomena. This choice or determination can be related to the type of the analyzed circuit. For example, transmission lines for power systems or waveguides for data transmission can be mentioned.



**Figure 25.** Voltage peaks related to the  $k_D$  factor and the number of  $\pi$  circuits for  $\Delta t = 10 \text{ ns}$ .




Figure 26. Voltage peaks related to the  $k_D$  factor and the number of  $\pi$  circuits for  $\Delta t = 200 \text{ ns}$ .

## 10. Conclusions

Modifications on the classical structure of  $\pi$  circuits for modeling transmission lines are presented. These modified  $\pi$  circuits are applied to obtain a cascade that represents the analyzed transmission lines. Based on the electromagnetic basic concepts, very long circuits for power transmission and circuits for data transmission can be analyzed using the theoretical bases of the transmission lines. So, a numerical routine for simulating electromagnetic transient phenomena in waveguides (transmission lines for power systems or data transmission) is obtained.

In the proposed numerical routine, damping resistances for minimizing Gibbs' oscillations or numerical oscillations are included. These oscillations are caused by the numerical integration method applied to the solution of the linear system that describes the waveguide. Applying this proposed numerical routine, several results of simulations varying the number of  $\pi$  circuits, the  $k_D$  factor, and the time step are obtained. These results are concentrated on three-dimensional graphics where the joint influence is shown.

Based on the obtained results, it is observed that there are ranges of the model parameters adequate for the minimization of numerical oscillations that influence these results. The main model parameters that influence the minimization of numerical oscillations are the number of  $\pi$  circuits and the  $k_D$  factor. The  $k_D$  factor is applied to calculate the value of damping resistances included in each  $\pi$  circuit of the mentioned cascade.

## Acknowledgements

The authors would like to thank the financial support by FAPESP (The São Paulo Research Foundation). The following processes are related to the results shown in this chapter: 2015/21390-7, 2015/20590-2, 2015/20684-7, 2016/02559-3, 2017/05988-5, 2017/05995-1, and 2017/23430-1.



## Author details

Afonso José do Prado<sup>1\*</sup>, Luis Henrique Jus<sup>1</sup>, Melissa de Oliveira Santos<sup>1</sup>,  
Elmer Mateus Gennaro<sup>1</sup>, André Alves Ferreira<sup>1</sup>, Thainá Guimarães Pereira<sup>1</sup>,  
Aghatta Cioqueta Moreira<sup>1</sup>, Juliana Semiramis Menzinger<sup>1</sup>, Caio Vinícius Colozzo Grilo<sup>1</sup>,  
Marinez Cargnin Stieler<sup>2</sup> and José Pissolato Filho<sup>3</sup>

\*Address all correspondence to: [afonsojp@uol.com.br](mailto:afonsojp@uol.com.br)

1 Campus of São João da Boa Vista, São Paulo State University (UNESP), São João da Boa Vista, São Paulo State, Brazil

2 Campus of Tangará da Serra, The University of Mato Grosso State (UNEMAT), Tangará da Serra, Mato Grosso State, Brazil

3 The University of Campinas (UNICAMP), Campinas, São Paulo State, Brazil

## References

- [1] Macías JAR, Expósito AG, Soler AB. A comparison of techniques for state-space transient analysis of transmission lines. *IEEE Transactions on Power Delivery*. April, 2005;**20**(2): 894-903
- [2] Macías JAR, Expósito AG, Soler AB. Correction to “a comparison of techniques for state-space transient analysis of transmission lines”. *IEEE Transactions on Power Delivery*. July, 2005;**20**(3):2358
- [3] Nelms RM, Newton SR, Sheble GB, Grigsby LL. Simulation of transmission line transients using a personal computer. *IEEE Conference Record of the 1988 Eighteenth Power Modulator Symposium*. 20–22 June 1988, Hilton Head, South Carolina, USA. pp. 229-232
- [4] Nelms RM, Sheble GB, Newton SR, Grigsby LL. Using a personal computer to teach power system transients. *IEEE Transactions on Power Systems*. August, 1989;**4**(3):1293-1294
- [5] Mamis MS, Koksai M. Transient analysis of nonuniform lossy transmission lines with frequency dependent parameters. *Electric Power Systems Research*. December, 1999;**52**(3): 223-228
- [6] Mamis MS. Computation of electromagnetic transients on transmission lines with nonlinear components. *IEEE Proceeding of Generation, Transmission and Distribution*. March, 2003; **150**(2):200-204
- [7] Mamis MS, Koksai M. Solution of eigenproblems for state-space transient analysis of transmission lines. *Electric Power Systems Research*. July, 2000;**55**(1):7-14
- [8] Mamis MS, Meral ME. State-space modeling and analysis of fault arcs. *Electric Power Systems Research*. September, 2005;**76**(1–3):46-51

- [9] Dommel HW. Electromagnetic Transients Program - Rule Book. Oregon; 1984
- [10] Dommel HW. EMTP Theory Book. 2<sup>a</sup> edition. Vancouver; April 1996
- [11] Prado AJ, Lessa LS, Monzani RF, Bovolato LF, Pissolato Filho J. Modified routine for decreasing numeric oscillations at associations of lumped elements. *Electric Power Systems Research*. July 2014;**112**(1):56-64
- [12] Brandão Faria JA. Overhead three-phase transmission lines – Non diagonalizable situations. *IEEE Transactions on Power Delivery*. October 1988;**3**(4)
- [13] Brandão Faria JA, Briceño Mendez J. Modal analysis of untransposed bilateral three-phase lines - a perturbation approach. *IEEE Transactions on Power Delivery*. January 1997;**12**(1)
- [14] Brandão Faria JA, Briceño Mendez J. On the modal analysis of asymmetrical three-phase transmission lines using standard transformation matrices. *IEEE Transactions on Power Delivery*. October 1997;**12**(4)
- [15] Morched A, Gustavsen B, Tartibi M. A universal model for accurate calculation of electromagnetic transients on overhead lines and underground cables. *IEEE Transactions on Power Delivery*. July 1999;**14**(3):1032-1038
- [16] Gustavsen B, Semlyen A. Combined phase and modal domain calculation of transmission line transients based on vector fitting. *IEEE Transactions on Power Delivery*. April 1998;**13**(2)
- [17] Chrysochos AI, Tsolaridis GP, Papadopoulos TA, Papagiannis GK. Damping of oscillations related to lumped-parameter transmission line modeling. In: *Conf. on Power Systems Transients (IPST 2015)*. 7. pp. 2015
- [18] Monzani RC, Prado AJ, Kurokawa S, Bovolato LF, Pissolato Filho J. Using a low complexity numeric routine for solving electromagnetic transient simulations. (DOI 10.5772/48507) in *Matlab - a fundamental tool for scientific computing and engineering applications*. Rijeka, Croatia: InTech - Open Access Publisher. 2012, pp. 463-484
- [19] Lessa LS, Prado AJ, Kurokawa S, Bovolato LF, Pissolato Filho J. The MatLab Software Application for Electrical Engineering Simulations and Power System Analyses (DOI 10.5772/48555) in *Matlab - a fundamental tool for scientific computing and engineering applications*. Rijeka, Croatia: InTech - Open Access Publisher. 2012. pp. 433-462
- [20] Prikler L, Hoidalén HK. ATPDraw Version 3.5 – Users' Manual. Trondheim, Norway; August 2002
- [21] Galvão RKH, Hadjiloucas S, Kienitz KH, Paiva HM, Afonso RJM. Fractional order modeling of large three-dimensional RC networks. *IEEE Transactions on Circuits and Systems – I: Regular Papers*. March, 2013;**60**(3):624-637
- [22] Gustavsen B. Avoiding numerical instabilities in the universal line model by a two-segment interpolation scheme. *IEEE Transactions on Power Delivery*. July, 2013;**28**(3):1643-1651

- [23] Moreno P, Ramirez A. Implementation of the numerical Laplace transform: A review. *IEEE Transactions on Power Delivery*. October, 2008;**23**(4):2599-2609
- [24] Nguyen TT, Chan HY. Evaluation of modal transformation matrices for overhead transmission lines and underground cables by optimization method. *IEEE Transactions on Power Delivery*. January, 2002;**17**(1):200-209
- [25] Marti JR. Accurate modelling of frequency-dependent transmission lines in electromagnetic transients simulations. *IEEE Transactions on PAS*. January 1982;**101**:147-155
- [26] Martí JR, Lin J. Suppression of numerical oscillations in the EMTP. *IEEE Transactions on Power Systems*. May 1989;**4**(2)
- [27] Lin J, Martí JR. Implementation of the CDA procedure in the EMTP. *IEEE Transactions on Power Systems*. May 1990;**5**(2)
- [28] Prado AJ, Besspalhuk KJ, Silva BF, Conceição KO, Cargnin-Stieler M, Gennaro EM, Pissolato Filho J. Influences of damping resistances on transient simulations in transmission lines. *Progress in Electromagnetics Research B*. 2017;**75**:27-39
- [29] Santos MO, Jus LH, Prado AJ, Gennaro EM, Pissolato Filho J. Influence of damping resistance in electromagnetic transients using alternate structures of circuits. *Progress in Electromagnetics Research Symposium - PIERS 2017*. 22–25 May 2017, St. Petersburg Russia
- [30] Prado AJ, Lessa LS, Assunção E, Teixeira MCM, Monzani RC, Pissolato Filho J. Laplace's analyses for application of p circuits" associations in digital simulations. *Progress in Electromagnetic Research Symposium - PIERS 2016*, 8–11 August 2016, Shanghai, China
- [31] Prado AJ, Conceição KO, Besspalhulk KJ, Silva BF, Gennaro EM, Cargnin-Stieler M, Pissolato Filho J. Minimization of Gibb's oscillations in transients" simulations using damping resistance. *Progress in Electromagnetic Research Symposium - PIERS 2016*, 8–11 August 2016, Shanghai, China
- [32] Jus LH, Moreira AC, Oliveira MO, Pereira TG, Prado AJ, Gennaro EM, Pissolato Filho J. Transmission lines model with different basic structures applied to transient electromagnetic simulations. *The 6th IASTED International Conference on Modelling, Simulation and Identification - MSI 2016*, v. 1, pp. 118–122, 16–18 August 2016, Campinas, Brazil



