We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,300

Open access books available

172,000

International authors and editors

190M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities

WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com

Capacity Estimation Methods Applied to Mini Hydro Plants

Rafael Peña and Aurelio Medina

*Universidad Michoacana de San Nicolás de Hidalgo
México*

1. Introduction

Mini hydro generation is one of the most cost-effective and reliable energy technologies in distributed generation systems to be considered for providing clean electricity generation. These systems constitute a viable alternative to address generation and electric power supply problems to isolated regions or small loads.

In particular, the key advantages that small hydro has over other technologies considered in distributed generation systems, such as, wind, wave and solar power are (BHA, 2005):

- A high efficiency (70 - 90%), by far the best of all energy technologies.
- A high capacity factor (typically >50%), compared with 10% for solar and 30% for wind.
- A high level of predictability, varying with annual rainfall patterns.
- Slow rate of change; the output power varies only gradually from day to day (not from minute to minute).
- It is a long-lasting and robust technology; systems can readily be engineered to last for 30 years or more.

It is also environmentally benign. Small hydro is in most cases “run-of-river”; in other words any dam or barrage is quite small, usually just a weir, and little or no water is stored. Therefore run-of-river installations do not have the same kind of adverse effects on the local environment as large-scale hydro plants.

There is no consensus on the definition of mini hydro plants. Some countries like Portugal, Spain, Ireland, and now, Greece and Belgium, accept 10 MW as the upper limit for installed capacity. In Italy the limit is fixed at 3 MW (plants with larger installed power should sell their electricity at lower prices); in France the limit was established at 8 MW and UK favours 5 MW. Hereunder will be considered as Mini Hydro any scheme with an installed capacity of 10 MW or less.

Today, among all the renewable energies, hydropower occupies the first place in the world and it will keep this place for many years to come. Figure 1 shows the electricity generation from renewable energies; it can be seen that the hydro generation represents the 94.3% of the total of the generation using renewable resources; from this percentage, the 9.3% is generated by mini hydro plants. Also, the market for small power plants is more attractive

than ever, due to the power market liberalization in the world, which opens the opportunity for the industry to generate electricity to full fill its basic needs.

Fig. 1. Electricity generation from renewable energy (BHA, 2005)

An important aspect on this type of systems is the planning, design and evaluation of the potential energy available in a selected place (Puttgen et al., 2003). The best geographical areas for mini hydro plants are those where there are steep rivers, streams, creeks or springs flowing year-round, such as in hilly areas with high year-round rainfall. To assess the suitability of a site for a mini hydro power system, a feasibility study should be made.

Feasibility studies show how the water flow varies along the years and where the water should be taken to obtain its maximum profit; they also show the power amount that can be obtained from the water flow, as well as the minimum and maximum limits of the profitable power.

There are other important factors that should be addressed when deciding if a mini hydro plant would work at a specific site:

- The potential for hydropower at the site.
- The requirements for energy and power.
- Environmental impact and approvals.
- Equipment options.
- Costs and economics.

Keep in mind that each micro-hydropower system cost, approvals, layout and other factors are site-specific and unique for each case.

In the literature concerning the design and selection of the main components of a mini hydro plant (Penche, 1998; Khennas et al., 2000; ITDG, 1996), the size of the generator is chosen based on the water flow time series organized into a relative frequency histogram, and with a pre-selected plant factor, whose value usually varies from 0.70 to 0.85 for this type of systems (ITDG, 1996). From this information, it is also possible to calculate the theoretical average power and the average annual generation that can be obtained from the site (e.g. river).

In this chapter, forecast methodologies based on data measurements from a monthly water flow time series are applied to predict the behaviour of the water for a particular river where it is desired to install the mini hydro plant. First, forecast techniques are discussed and then a example of the application of the techniques to the water flow time series is presented. The proposed procedure aims enhancing the estimation of the generator capacity as the historical data of water flow is now complemented with the results obtained via

forecast techniques (Peña et al., 2009). For completeness, a selection of the most important electro-mechanical elements of a proposed mini hydro plant is also provided.

2. Water Flow Time Series

In order to determine the hydro potential of water flowing from the river or stream, it is necessary to know the flow rate of the water and the head through which the water can fall. The flow rate is the quantity of water flowing past a point at a given time. Typical units used for flow rate are cubic metres per second (m³/s), litres per second (lps), gallons per minute (gpm) and cubic feet per minute (cfm). The head is the vertical height in metres (m) or feet (ft.) from the level where the water enters the intake pipe (penstock) to the level where the water leaves the turbine housing.

The measurements or historical data of water flow can be organized into a water flow time series. A time series is a series of measurements, observations, and recordings of a set of variables at successive points in uniform time intervals (Hamilton, 1994).

Fig. 2 shows the water flow time series used in this chapter. This historical data corresponds to measurements taken from the Cardel Hydrometric Station, in La Antigua River, Veracruz, México. The time series has 420 monthly observations, from the period of January, 1951 to December, 1985 (CONAE, 2005).

Fig. 2. Water flow time series

3. Capacity Estimation: Classic Method

Records of water flow variations along the years are taken in hydrometric stations located in the main rivers. These stations take data about the hydrologic situation of the area including the water flow variations of the river; this is periodically measured, in some cases on a day-to-day basis. The water flow records are very useful to allow forecasting the future behaviour of the river. This data is also taken into account to decide if a mini hydro plant can be installed in a specific place.

From historical records of water flow, a Flow Duration Curve (FDC) can be built. The flow duration curve is a plot that shows the percentage of time that the water flow in a river is likely to equal or exceed a specified value of interest (the area below the curve is a measure of the potential energy of the river or stream). For instance, the FDC can be used to assess the expected availability of water flow over time and the power and energy at a site and to decide on the “design flow” in order to select the turbine. Decisions can also be made on how large a generating unit should be. If a system is to be independent of any other energy or utility backup, the design flow should be the flow that is available 70% of the time or more. Therefore, a stand-alone system such as a mini hydro plant should be designed according to the flow available throughout the year; this is usually the flow during the dry season. It is possible that some streams could dry up completely at that time.

Figure 3 shows the FDC for the time series under study. From this figure it is possible to observe that for nearly 80% of the time the water flow is equal or below to $28.4 \times 10^5 \text{ m}^3$. Also, it shows that if a mini hydro plant is to be installed in this river and it is desirable to have it working 70% of the time, then a value of $42.28 \times 10^5 \text{ m}^3$ should be chosen as the design water flow.

Fig. 3. Flow duration curve

Another important graph derived from the historical data is the relative frequency histogram. The relative frequency is defined as the number of times that a value occurs in a data set. Figure 4 shows the relative frequency histogram calculated from the historical data under study. From this bar chart it is possible to *a priori* visualize the data concentration, and the minimum and maximum values of the time series, e.g. from Figure 4, it can be seen that the value with more repetitions in the time series is $24.2 \times 10^5 \text{ m}^3$.

Fig. 4. Relative frequency histogram

4. Forecast Techniques

As mentioned before the water flow time series is frequently used for the design and capacity estimation of mini hydro plants. However, records of these variables from a previously selected place are not always available or there is just a few historical data. Besides, climate changes around the world have provoked, for instance, that drought and rainy seasons are not as periodic as they used to be; this makes the water flow levels to change drastically from one season to another, and in some cases rivers even tend to dry-out.

The reasons given before and other unexpected events justify the application of forecast techniques to appropriately process the available hydro resources at a specific geographic site, so that an adequate capacity estimation of a mini hydro plant can be achieved (and also to know the future behaviour of a selected river).

In order to deal with the forecast problem, various forecast techniques have been used: Kalman Filters (Sorensen & Madsen, 2003), Box-Jenkins methodologies (Montañés et al., 2002), Neural Networks (Xie et al., 2006), etc. most of them providing satisfactory results. In this chapter, ARIMA (Zhou et al., 2004), Neural Networks (Azadeh et al., 2007), and Genetic Programming (Flores et al., 2005) methodologies are presented and then applied to the water flow time series to forecast the behaviour of the water flow in the years to come. The best forecast obtained with the application of these methods is then used to estimate the capacity of a proposed mini hydro plant.

4.1 ARIMA Model

The acronym ARIMA stands for “Auto-Regressive Integrated Moving Average”, whose model is a generalization of an auto-regressive moving average or ARMA model. These models are widely used in the time series forecast problem and they are usually part of the Box-Jenkins methodology (Montañés et al., 2002). The ARIMA model is generally referred as an ARIMA(*p*, *d*, *q*) model, where *p*, *d*, and *q* are values used to define the number of auto-regressive, integrated, and moving average terms of the model, respectively.

In order to describe the mathematics involved in an ARIMA model, it is important to define an ARMA(p, q) model for a data time series $X(n)$, where n is an integer index to indicate a specific data within the time series, then an ARMA(p, q) model is given by (Ramachandran & Bhethanabotla, 2000)

$$(1 - \sum_{i=1}^p \phi_i L^i) X(n) = (1 + \sum_{i=1}^q \theta_i L^i) \varepsilon_n \quad (1)$$

where L is the lag operator, ϕ_i are the auto-regressive parameters of the model, θ_i are the moving average parameters of the model, and ε_n are error terms. The error terms ε_n are usually known as white noise and they are assumed to be independent with zero covariances, and identically distributed sampled data from a normal distribution with zero average.

The ARIMA(p, d, q) model can be obtained integrating Equation (1). That is,

$$(1 - \sum_{i=1}^p \phi_i L^i) (1-L)^d X(n) = (1 + \sum_{i=1}^q \theta_i L^i) \varepsilon_n \quad (2)$$

where d is a positive integer that controls the level of differentiation. Note that if $d = 0$, this model is equivalent to an ARMA model.

There are three basic steps to the development of an ARIMA model (Brockwell & Davis, 2002):

- 1) *Identification/model selection*: the values of p , d , and q must be determined. The principle of parsimony, also known as principle of simplicity, is adopted; most stationary time series can be modeled using very low values of p and q .
- 2) *Estimation*: the θ and the ϕ parameters must be estimated, usually by employing a least squares approximation to the maximum likelihood estimator.
- 3) *Diagnostic checking*: the estimated model must be checked for its adequacy and revised if necessary, implying that this entire process may have to be repeated until a satisfactory model is found.

The most crucial of these steps is identification, or model selection. This step requires the researcher to use his or her personal judgment to interpret some selected statistics, in conjunction with a graph from a set of autocorrelation coefficients, to determine which model the data suggest is the appropriate one to be employed. In this respect the ARIMA model is an art form, requiring considerable experience for a researcher to able to select the correct model.

Using the R-Project software (R-Project, 2009), a model that allows the determination of each ARIMA parameters was implemented; 370 data points were used to obtain the model and the last 50 values of the time series were used to compare the forecast obtained by the model with the results from the historical time series.

For an ARIMA (3, 1, 2) model, e.g. with three auto-regressive parameters (AR_x), one integrator parameter ($INTG_x$) and two moving average parameters (MA_x), the coefficients shown in Table 1 were obtained.

AR ₁	AR ₂	AR ₃	MA ₁	MA ₂	INTG ₁
-0.1559	0.2239	0.0753	-0.5109	-0.4891	-0.4652

Table 1. ARIMA technique coefficients

The calculated forecast data obtained with the ARIMA model and the historic data are compared in Fig. 5. The forecasted data satisfactorily matches the original time series, however, the form of the curve for the obtained forecast tends to be periodic, that is, it fails to adequately reproduce the peaks taking place in the original time series.

Fig. 5. ARIMA forecast data

4.2 Neural Networks

A neural network is a computational model that closely resembles the neuron cell structure of the biological nervous system. Neurons in a neural network are linked between them, so information can be transmitted from one neuron to others. An artificial neuron is a device with many inputs and one output. The neuron has two modes of operation; the training mode and the using mode. In the training mode, the neuron can be trained to fire (or not), for particular input patterns. In the using mode, when a taught input pattern is detected at the input, its associated output becomes the current output. If the input pattern does not belong to the taught list of input patterns, the firing rule is used to determine whether to fire or not.

The firing rule is an important concept in neural networks and accounts for their high flexibility. A firing rule determines how one calculates whether a neuron should fire for any input pattern. It relates to all the input patterns, not only the ones on which the node was trained.

A simple firing rule can be implemented by using Hamming distance technique (Beale & Jackson, 1990). The rule goes as follows:

- Take a collection of training patterns for a node, some of which cause it to fire (the 1-taught set of patterns) and others which prevent it from doing so (the 0-taught set). The patterns not in the collection cause the node to fire if, on comparison, they have more input elements in common with the 'nearest' pattern in the 1-taught set than with the 'nearest' pattern in the 0-taught set. If there is a tie, then the pattern remains in the undefined state.

Neurons in a neural network are linked between them, so information can be transmitted from one neuron to others. Given a data training set the neural network can learn the historic data through a training process and, with a learning algorithm the weights of the neurons are adjusted; through this procedure, the neural network acquires the capacity to predict answers of the same type of phenomenon.

Activation functions are also needed in order to train the neural network; different activation functions are frequently used, including step, linear (or ramp), threshold, and sigmoid functions.

In this research, the back-propagation learning algorithm (the most commonly used), was employed where the neural network forms a mapping between the inputs and the desired outputs from the training set by altering the weights of the connections within the network (Hilera & Martínez, 2000).

Different types of neural networks have been developed depending on the characteristics and the type of application. Common applications of this computational model are: speech recognition, control systems, classification of patterns, identification of systems, time series forecast, etc. (Hilera & Martínez, 2000).

A general structure of the connections of a neural network can be observed in Figure 6. During the phase of training, the connections weights W_{ij} are iteratively calculated; these connections link the neurons of the inputs E_i with the neurons of the layer O_j . If an input is received, this is sent across the neurons of the layer, and the weights of the connections are then adjusted, generating an output S . This output is compared with the real input, generating an error, which is back-propagated from the output to the input; this iterative process is carried-out until the neural network is able to reproduce the input.

The mathematical approach of the neural network working is as follows: A neuron in the output layer determines its activity by following a two step procedure.

- First, it computes the total weighted input E_i , using the Equation:

$$E_i = \sum_j y_j W_{ij} \quad (3)$$

where y_j is the activity level of the j th neuron in the previous layer.

- Next, the neuron calculates the activity y_i , using a function of the total weighted input. Typically the sigmoid function is used:

$$y_i = 1 / (1 + e^{-E_i}) \quad (4)$$

Once the activities of all output neurons have been determined, the network computes the error err , which is defined by the expression:

$$err = (1/2) \sum_j (y_j - d_j)^2 \quad (5)$$

where d_j is the desired output of the i th neuron.

Now, the back-propagation algorithm can be applied; it consists of four steps:

- 1) Compute how fast the error changes as the activity of an output neuron is changed. This error derivative (EA) is the difference between the actual and the desired activity.

$$EA_i = (\partial err / \partial y_i) = y_i - d_i \quad (6)$$

- 2) Compute how fast the error changes as the total input received by an output neuron is changed. This quantity (EL) is the answer from step 1 multiplied by the rate at which the output of a neuron changes while its total input is changed.

$$EL_i = (\partial err / \partial E_i) = (\partial err / \partial y_i) \times (\partial y_i / \partial E_i) = EA_i y_i (1 - y_i) \quad (7)$$

- 3) Compute how fast the error changes as a weight of the connection into an output neuron is changed. This quantity (EW) is the answer from step 2 multiplied by the neuron activity level from which the connection emanates.

$$EW_{ij} = (\partial err / \partial W_{ij}) = (\partial err / \partial E_i) \times (\partial E_i / \partial W_{ij}) = EL_i y_j \quad (8)$$

- 4) Compute how fast the error changes as the activity of a neuron in the previous layer is changed. This crucial step allows back-propagation to be applied to multilayer networks. When the activity of a neuron in the previous layer changes, it affects the activities of all the output neurons to which it is connected. So, to compute the overall effect on the error, we add together all these separate effects on output neurons. But each effect is simple to calculate; it is the answer in step 2 multiplied by the weight on the connection to that output neuron.

$$EA_j = (\partial err / \partial y_j) = \sum_i (\partial err / \partial E_i) \times (\partial E_i / \partial y_j) = \sum_i EL_i W_{ij} \quad (9)$$

By using steps 2 and 4, we can convert the EAs of one layer of neurons into EAs for the previous layer. This procedure can be repeated to get the EAs for as many previous layers as desired. Once we know the EA of a neuron, we can use steps 2 and 3 to compute the EWs on its incoming connections.

Fig. 6. General structure of the connections in a neural network

For the case under consideration a neural network with 3 layers and 30 neurons for each layer was implemented in C language; 370 data from the Cardel Hydrometric station time series were used to train the neural network and 50 values were used for the validation of the obtained forecast.

Figure 7 shows the results obtained with this computational technique and the corresponding comparison against the historical time series. From this figure it is possible to

observe that the neural network is able to forecast future data more accurately than the ARIMA method.

Fig. 7. Neural network forecast data

4.3 Genetic Programming by ECSID Software

Genetic Algorithms (GA) (Holland, 1992) and Gene Expression Programming (GEP) (Ferreira, 2006) are evolutionary tools inspired in the Darwinian principle of natural selection and survival of the fittest individuals. These methods use an initial random population and apply genetic operations to this population until the algorithm finds an individual that satisfies some termination criteria.

In order to simulate the evolutionary process both GA and GEP follow the next steps:

- 1) *Initialization*: Creates an initial random population.
- 2) *Evaluation*: Evaluates all the individuals and test whether or not the best one satisfies the termination criteria.
- 3) *Selection*: Use fitness proportional selection and apply the genetic operations to this population.

GA uses a fixed chromosome structure, which can be an array of bits, numbers, characters, etc. To use GA the problem is codified as a fixed chromosome and then the problem is solved using an evolutionary process. The genetic operations more widely used are crossover, selection and mutation.

GEP is similar to Genetic Programming (GP) (Koza, 1992); it is an evolutionary algorithm that evolves computer programs. The basic idea behind GEP is a clever representation for the chromosomes (a string instead of a tree), which leads to an easier implementation.

ECSID stands for "Evolutionary Computation based System IDentification"; it is a program that makes mathematical models from an observation data set (Flores et al., 2005).

ECSID obtains a formula that models the training data set, using a slide window prediction method (Jie et al., 2004). The slide window prediction method uses a window of size 16; the

window contains the actual data, and the model computes the synthetic time-series and the prediction errors for that time window.

Equation (10) shows the general models generated by the software, where $f(i)$ represents the time series at instant i , $e(i)$ is the vector of prediction errors, h is the window size, and a , b are unknown coefficients to be find out by the software.

$$f(i+1) = \sum_{i=h}^{i-1} a_i f(i) + \sum_{i=h}^{i-1} b_i e(i) \quad (10)$$

In order to make a forecast with this program, 337 data were used to obtain a model that represents the time series, and 83 data for the validation of the forecast obtained with the model.

From the ECSID model, a forecast study was conducted, with the results compared against real data. The comparison is shown in Figure 8, where the predicted data tends to an irregular triangular waveform, which is repeated in constant oscillation periods of 12 data (one year). For the first 50 points, the model achieves an acceptable reproduction of the original time series under study.

5. Application to the Capacity Estimation of Mini Hydro Plants

With the results obtained from the previous section (forecast data) and the available historical data, it is possible to determine the design water flow Q_i for the turbines of the mini hydro plant. It is also necessary to know the plant factor pf , which is the percentage of time that the plant is expected to be generating electric power at full capacity. The typical plant factor for this type of hydro plants varies from 0.70 to 0.85 (ITDG, 1996).

The following procedure was used to determine the value of Q_i :

- A ten-year forecast is conducted using the time series; this period usually corresponds to the useful life of hydraulic turbines.
- The obtained forecast data are added to the historical data, in this way, a more complete set of data of the river water flow is available.
- A new flow duration curve can be built using the new data set.
- Different values of pf are now selected and the respective value of Q_i from the water flow duration curve is chosen.

A summary of the design water flow obtained for the new time series calculated from the different forecast techniques (at different typical plant factors), and the average monthly water flow Q_m is shown in Table 2; the water flow is in $1 \times 10^5 \text{ m}^3$. This Table illustrates that the neural network technique provided the most accurate results. The ARIMA and ECSID results suggest that the water flow in the river tends to be lower each year, that is, a smaller design water flow should be selected.

Fig. 8. ECSID forecast data

The theoretical average power P_m obtained from the river can be estimated using Equation (11) (IDAE, 1996):

$$P_m = 9.81Q_m H \eta \gamma \tag{11}$$

where H is the height (m); η total efficiency of the system (p.u.); and γ is the specific weight of water (1 000 kg/m³). The Average Annual Generation of the system AAG is determined by (Penche, 1998),

$$AAG = (9.81Q_i H \eta 8760 pf)/1\times10^6 \tag{12}$$

Forecast Technique	Q_m	Q_i			
		Plant factor (pf)			
		0.70	0.75	0.80	0.85
Historic data	147.894	42.283	32.874	28.398	24.414
ARIMA	115.733	31.326	27.356	23.161	19.488
Neural Network	144.854	40.501	32.793	28.228	23.948
ECSID	135.733	38.442	30.907	24.918	22.872

Table 2. Design water flow

For the case study, there are different places close to the Cardel hydrometric station with heights varying from 5 m to 15 m. These are locations where the construction of the civil work of the mini hydro plant can be built (CSVA, 2008). Equations (11) and (12) are applied to obtain the theoretical total generation of the system. The parameter η includes the effects of the losses in the whole system, e.g. for our case η is assumed to be 1.0 p.u.

Table 3 summarizes the power generation that can be obtained from this river based on the results achieved with the neural network method, considering a plant factor of 0.8, and a design water flow of $28.228 \times 105 \text{ m}^3$ at different heights.

	5 m	10 m	15 m
P_m	355.254 kW	710.509 kW	1.065 MW
AAG	5.283 GWh	10.567 GWh	15.851 GWh

Table 3. Average power and average annual generation of the system at different heights

It can be observed from Table 3 that the ideal height to be considered for the design and the selection of the mini hydro plant components is between 10 to 15 meters (CSVA, 2008) where the maximum power from the river can be obtained. For the case of study a capacity of 1 MW was selected which corresponds to the maximum height (15 m).

6. Selections of Electromechanical Equipment

Fig. 9(a) illustrates the high head scheme of a mini hydro plant; this scheme uses weirs to divert water to the intake, from where it is conveyed to the turbines, via a pressure pipe or penstock. Fig 9(b) shows the electrical diagram of a mini hydro plant. The basic electro-mechanical equipment in these plants comprises the turbines, generators, transformers and the interconnecting power line. An appropriate design and selection of the mini hydro plant components based on the forecast techniques and the results reported in Section 4 and 5, are described next.

6.1 Hydraulic Turbine

For the proposed case of study, the water flow design of $10.890 \text{ m}^3/\text{s}$ and a height of 15 m were selected. To know the specific characteristics of the selected turbine, it is necessary to have the charts, graphs and characteristics from the turbine manufacturer. In the Alstom’s web page (Alstom, 2009), a program that selects and presents the characteristics for the turbine-generator group used in a mini hydro plant can be accessed. Providing the water flow and height data, the program Mini Aqua Configurator (Alstom, 2009) shows a graph with the type of available turbines, as illustrated by Fig. 10, showing the exact position and the type of the selected turbine (square in the central part of the graph). The type of turbine to be selected for this case study can be Kaplan or Francis. The use of the Kaplan turbine is recommended since it is generally cheaper. The power generation estimated by the program for the turbine-generator group is 1.48 MW. Other relevant data are: 720 rpm, 88% of efficiency and 1320 mm for the diameter of the head turbine.

6.2 Generator

The selection of the generator for the mini hydro plant is mainly based on the turbine characteristics. Thus, a synchronous generator was selected with the following specifications: 1.5 MVA, 380 V, 60 Hz, 720 rpm and 0.9 power factor.

Fig. 9. Mini hydro plant: a) High head scheme, b) Electrical diagram

6.3 Transformers

For the proposed mini hydro plant, the use of three transformers is assumed; e.g. step-up, step-down transformers with a nominal capacity of 1.5 MVA and a transformer of 45 kVA for the self services in the plant. The proposed transformers have the following characteristics: 380 V / 13.2 kV to 60 Hz, Both the transformers will be connected in delta-wye grounded configuration.

Fig. 10. Diagram of the available turbines in Alstom for mini hydro plants (Alstom, 2009)

6.4 Interconnection Power Line

According to CFE (Comisión Federal de Electricidad, México) construction norms (CFE, 1995), for this type of system the following primary distribution arrangement is recommended with the following characteristics: 3 phases, star connected, with solid connection to ground at the substation site. A simple cross-arm post type (TS) will be used for the distribution line.

7. Conclusion

In this chapter, a procedure for estimating the capacity of distributed generation based on mini hydro plants has been presented. This procedure has been successfully applied for a practical case where this type of distributed generation can be installed.

The classic method used to estimate the capacity of a mini hydro plant was also introduced and then time series forecasting techniques were applied in order to enhance the historic data available. Based on the results of these forecast techniques and the available historical data, an estimation of the design water flow was performed, and a possible capacity for a mini hydro plant calculated.

The time series forecast analysis has been conducted using an ARIMA model, a neural network and Genetic Programming by means of the software ECSID. For each case study, the obtained forecast results have been validated against actual measured data. The forecast technique based on neural networks has proven to give the best results for the case under consideration. Also, the selection of the most important electro-mechanic components of a proposed mini hydro plant based on the selected design water flow has been described.

8. References

- Alstom. (2009). *Mini Aqua Configurator*. [Online]. Available: http://www.hydro.power.alstom.com/configurator/project_selection.html
- Azadeh, A.; Ghaderia, S.F. & Sohrabkhanian, S. (2007). Forecasting electrical consumption by integration of Neural Network, time series and ANOVA. *Applied Mathematics and Computation*, Vol. 182, No. 2, (March 2007), pp. 1753-1761, ISSN 0096-3003
- Beale, R.; Jackson, T. (1990). *Neural computing: an introduction*, IOP Publishing Ltd, ISBN 0-85274-262-2, Bristol, UK
- BHA. (2005). *A guide to UK mini-hydro developments*, The British Hydropower Association. London, UK
- Brockwell, P. & Davis, R. (2002), *Introduction to Time Series and Forecasting*, Springer-Verlag, ISBN 0-387-95351-5, New York, USA
- CFE. (1995). *Normas de Distribución, construcción de líneas aéreas (Distribution norms, construction of electric lines)*, Comisión Federal de Electricidad, Mexico
- CONAE. (2005). *Situación Actual de la Minihidráulica Nacional y Potencial en una región de los Estados de Veracruz y Puebla (Current Situation of the National Mini-hydro and the Potential Available for the States of Veracruz and Puebla, Mexico)*, Comisión Nacional de Ahorro de Energía, Mexico
- CSVA. (2008). *Consejo del Sistema Veracruzano del Agua*. [Online]. Available: <http://www.csva.gob.mx>
- Ferreira, C. (2006). *Gene Expression Programming: Mathematical Modeling by an Artificial Intelligence*, Springer-Verlag, ISBN 3540327967, Berlin, Germany
- Flores, J.J.; Graff, M. & Cardenas, E. (2005). Wind Prediction Using Genetic Algorithms and Gene Expression Programming. *Proceedings of AMSE 2005*, pp. 17-26, Morelia, Mexico, April 2005
- Hamilton, J.D. (1994). *Time series analysis*, Princeton University Press, ISBN 0-691-04289-6, New Jersey, USA

- Hilera, J.R. & Martínez, V.J. (2000). *Redes neuronales artificiales. Fundamentos, modelos y aplicaciones (Artificial Neural Networks, fundamentals, models and applications)*, Alfaomega Ra-Ma, ISBN 8478971556, Madrid, Spain
- Holland, J. H. (1992). *Adaptation in Natural and Artificial Systems*, University of Michigan Press, ISBN 0-262-58111-6, Massachusetts, USA
- IDAE. (1996). *Manual of renewable energies: Mini hydroelectric power stations*, Ministry of Economy, Madrid, Spain
- ITDG. (1996). *Manual de Mini y Microcentrales Hidráulicas; una guía para el desarrollo de proyectos (Mini and Micro-Hydraulic Plants; a project development guide)*, Intermediate Technology Development Group, Peru
- Jie, Z.; Changjie, T. Chuan, L. Anlong C. & Chang'an, Y. (2004). Time series prediction based on gene expression programming. *Proceedings of WAIM 2004*, pp. 55-64, ISBN 978-3-540-22418-1, Dalian, China, September 2004
- Khennas; Smail & Barnett, A. (2000). *Best practices for sustainable development of micro hydro power in developing countries*, World Bank / ESMAP, Madrid, Spain
- Koza, J.R. (1992). *Genetic Programming: On the Programming of Computers by Means of Natural Selection (Complex Adaptive Systems)*, The MIT Press, ISBN 0-262-11170-5, Massachusetts, USA
- Montañés, E.; Quevedo, J.R. Prieto, M.M. & Menéndez, C.O. (2002). Forecasting Time Series Combining Machine Learning and Box-Jenkins Time Series. *Proceedings of IBERAMIA 2002*, pp. 491-499, ISBN 978-3-540-00131-7, Seville, Spain, January 2002
- Penche, C. (1998). *Layman's book: on how to develop a small hydro site*, European Small Hydropower Association (ESHA), Brussels, Belgium
- Peña, R.; Medina, A., Anaya-Lara, O. & McDonald, J.R. (2009). Capacity estimation of a minihydro plant based on time series forecasting, *Elsevier Renewable Energy*, Vol. 34, No. 5, (May 2009), pp. 1204-1209, ISSN 0960-1481
- Puttgen, H.B.; MacGregor, P.R. & Lambert, F.C. (2003). Distributed generation: Semantic hype or the dawn of a new era? *IEEE Power and Energy Magazine*, Vol. 1, No. 1, (January-February 2003), pp. 22-29, ISSN 1540-7977
- Ramachandran, R. & Bhethanabotla, V.N. (2000). Generalized autoregressive moving average modeling of the Bellcore data. *Proceedings of LCN 2000*, pp. 654-661, ISBN 0-7695-0912-6, Tampa, USA, November 2000
- R-Project. (2009). *The R Project for Statistical Computing*. [Online]. Available: <http://www.r-project.org/>
- Sorensen, J.V.T. & Madsen, H. (2003). Water level prediction skill of an operational marine forecast using a hybrid Kalman filter and time series modeling approach. *Proceedings of OCEANS 2003*, pp. 790-796, ISBN 0-933957-30-0, San Diego, USA, September 2003
- Xie, J.; Tang, X. & Li, T. (2006). Low Power Design based on Neural Network Forecasting for Interconnection Networks. *Proceedings of WCICA 2006*, pp. 2979-2983, ISBN 1-4244-0332-4, Dalian, China, June 2006
- Zhou, M.; Yan, Z. Ni, Y. & Li, G. (2004). An ARIMA approach to forecasting electricity price with accuracy improvement by predicted errors. *Proceedings of IEEE Power Engineering Society General Meeting 2004*, pp. 233-238, ISBN 0-7803-8465-2, Denver, USA, June 2004

Distributed Generation

Edited by D N Gaonkar

ISBN 978-953-307-046-9

Hard cover, 406 pages

Publisher InTech

Published online 01, February, 2010

Published in print edition February, 2010

In the recent years the electrical power utilities have undergone rapid restructuring process worldwide. Indeed, with deregulation, advancement in technologies and concern about the environmental impacts, competition is particularly fostered in the generation side, thus allowing increased interconnection of generating units to the utility networks. These generating sources are called distributed generators (DG) and defined as the plant which is directly connected to distribution network and is not centrally planned and dispatched. These are also called embedded or dispersed generation units. The rating of the DG systems can vary between few kW to as high as 100 MW. Various new types of distributed generator systems, such as microturbines and fuel cells in addition to the more traditional solar and wind power are creating significant new opportunities for the integration of diverse DG systems to the utility. Interconnection of these generators will offer a number of benefits such as improved reliability, power quality, efficiency, alleviation of system constraints along with the environmental benefits. Unlike centralized power plants, the DG units are directly connected to the distribution system; most often at the customer end. The existing distribution networks are designed and operated in radial configuration with unidirectional power flow from centralized generating station to customers. The increase in interconnection of DG to utility networks can lead to reverse power flow violating fundamental assumption in their design. This creates complexity in operation and control of existing distribution networks and offers many technical challenges for successful introduction of DG systems. Some of the technical issues are islanding of DG, voltage regulation, protection and stability of the network. Some of the solutions to these problems include designing standard interface control for individual DG systems by taking care of their diverse characteristics, finding new ways to/or install and control these DG systems and finding new design for distribution system. DG has much potential to improve distribution system performance. The use of DG strongly contributes to a clean, reliable and cost effective energy for future. This book deals with several aspects of the DG systems such as benefits, issues, technology interconnected operation, performance studies, planning and design. Several authors have contributed to this book aiming to benefit students, researchers, academics, policy makers and professionals. We are indebted to all the people who either directly or indirectly contributed towards the publication of this book.

How to reference

In order to correctly reference this scholarly work, feel free to copy and paste the following:

Rafael Pena and Aurelio Medina (2010). Capacity Estimation Methods Applied to Mini Hydro Plants, Distributed Generation, D N Gaonkar (Ed.), ISBN: 978-953-307-046-9, InTech, Available from: <http://www.intechopen.com/books/distributed-generation/capacity-estimation-methods-applied-to-mini-hydro-plants>

InTech Europe

University Campus STeP Ri
Slavka Krautzeka 83/A
51000 Rijeka, Croatia
Phone: +385 (51) 770 447
Fax: +385 (51) 686 166
www.intechopen.com

InTech China

Unit 405, Office Block, Hotel Equatorial Shanghai
No.65, Yan An Road (West), Shanghai, 200040, China
中国上海市延安西路65号上海国际贵都大饭店办公楼405单元
Phone: +86-21-62489820
Fax: +86-21-62489821

IntechOpen

IntechOpen

© 2010 The Author(s). Licensee IntechOpen. This chapter is distributed under the terms of the [Creative Commons Attribution-NonCommercial-ShareAlike-3.0 License](https://creativecommons.org/licenses/by-nc-sa/3.0/), which permits use, distribution and reproduction for non-commercial purposes, provided the original is properly cited and derivative works building on this content are distributed under the same license.

IntechOpen

IntechOpen