We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,300

Open access books available

172,000

International authors and editors

190M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities

WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com

Membrane Separation Process in Wastewater Treatment of Food Industry

Claudia Muro¹, Francisco Riera² and María del Carmen Díaz¹

¹*Institute Technological of Toluca,*

²*University of Oviedo,*

¹*México*

²*Spain*

1. Introduction

Wastewater derived from food production is highly variable, depending on the specific types of food processing operations (e.g., fruit, vegetable, oils, dairy, meat, and fish).

Advances in membranes technology have showed many advantages for wastewater treatment of food industry. By implementing membranes, the separated substances and clean water are often recoverable in a chemically unchanged form and are therefore easily re-used. Maximum benefits are obtained when one or both the output streams from the membrane system are recycled or re-used, thereby reducing process materials requirement and minimizing waste disposal costs.

This chapter reviews the development and applications of membrane processes in wastewater treatment of food industry. Particular focus is given to membrane's special abilities to wastewater treatment for water regeneration and various re-uses purposes. Influence of engineering aspects is analyzed, specially operating conditions near critical flux to improve processes in wastewater treatment. Detailed discussions are provided with respect to constituents of concern in water reuse applications including recovery of other products with value for food industry.

2. Wastewater of food industry volume and quality

The types of food production processes (e.g., fruit, vegetable, oils, dairy, meat, fish, etc.) vary widely, with associated differences in the specific wastewater contaminants. The characteristics and generation rates of food wastewater are highly variable, depending on the specific types of food processing operations, including wastewater from activities of food cleaning (sanitizing, peeling, cooking, and cooling); mechanically activities (conveyor medium to transport food materials throughout the process) and clean production equipment between operations. In addition, one important attribute is the general scale of the operations, since food processing extends from small, local operations.

Food processing can be divided into four major sectors: Meat, poultry and seafood; fruit and vegetables; dairy and beverage. Table 1 shows the wastewater volume and pollution charge of some food industries.

Feed processing	Wastewater (m ³ ton ⁻¹) of product	COD (mgO ₂ .L ⁻¹)	BOD ₅ (mgO ₂ .L ⁻¹)
Meat processing			
- Scalding tube	0.3	1800	1 400
-Chiller showers	1.7	150	140
- Cooling tanks	0.7	550	500
Fruit juice			
-Orange	5.0	11200	8 100
-Apple	1.2	2000	1 400
-Tomato wastewater ¹		1200	
-Fruit Juice (general) ²		2500-7000	
Vegetable processing			
-frozen carrots	30	5000	4 500
-Olive mill ³		100 000-200 000	
Potato starch			
-Shower	0.7	3 000	2 500
Starch rinsing	1.5	7 800	6 500
Beer production	4.2	2 500	1 800
Alcohol plant		900-1 200	
Fish industry			
- Unloading fish ⁵		5 000-7 000	
-Brines ⁶		4 000-14 000	
-Cooked fish ⁷		4 000-20 000	
Dairy industry			
-Whey	90	65 000	42 000
-End pipe wastewater	1.5	1 800	860
-Flash cooler condensates		100-570	
-Bottle rinsing ⁸		50-1000	
-Caustic solutions ⁹		8 000-10 000	

*adapted from ¹Iaquinta et al., 2009; ²Noronha et al., 2002; ³Mantzavinos & Kalogerakis, 2005; ⁴Madaeni & Mansourpanah, 2006; ⁵Matthiasson, 1983; ⁶Kuca & Szaniawska, 2009; ⁷Walha et al., 2009; ⁸Scharnagl et al., 2000; ⁹Gésan-Guiziou et al., 2007

Table 1. Wastewater from food industry

Primary and secondary treatments are often used to decompose the high organic contents of wastewater of food industry by aerobic and anaerobic fermentation processes. After of traditional treatment of wastewater, general requirements are covered by regulations of each country, usually complemented by consent limits based on avoidance of pollution. Discharge licenses may include maxima for flow, temperature, suspended solids, dissolved solids, BOD₅, nitrogen, phosphorous and turbidity. According at quality of water, in most cases, final disposal of treated waste water is into a water course where it will be diluted by the existing flow. However, subsequently one advanced process of effluent treating can be an option desirable to recycle water within a factory of food processing.

3. Membrane process

Membrane filtration is a process used to separate dissolved substances and fine particles from solutions. Membrane acts as a semipermeable and selective barrier that separates particles based on molecular or physical size. Solutes smaller of solution than the membrane pore size are able to pass through the membrane as permeate flux while particles and

molecules larger than the membrane pore size are retained. The two fluxes at outlet of membrane are important because this process has a high efficiency in the separation.

The majority of commercial membranes are made usually of organic polymers (polysulfones and polyamides) and inorganic materials (ceramic membranes based on oxides of zirconium, titanium, silicium and aluminum).

The membranes are implemented in several types of modules. The membrane configuration determines the manner in which the membrane is packed inside the modules. Four main types of membrane configurations are used in the industry. These are: plate-and-frame, spiral wound, tubular and hollow-fiber configurations. The membrane geometry is planar in the first two and cylindrical in the two others. Figure 1 shows schematically a typical hollow fiber module (Okokchina, 2010).

Fig. 1. Scheme of the hollow fiber membrane module with crossflow. A large surface/ volume ratio is expected for these modules.

The membrane system is operated in a cross-flow feed mode. The concentrated stream passes parallel to the membrane surface as opposed to perpendicular flow that is used traditionally in filtration. This operating mode allows that accumulation of solute molecules at the membrane surface decreases and the permeate flux remains constant for a long time due to decreased hydrodynamic resistance at the membrane surface by cross-flow induced hydraulic turbulence. Flow direction is usually inside-out, i.e. the concentrate flux inside the fibers and the permeate flux is collected at the shell-side. It is often possible to reverse the flow (outside-in) for cleaning and unclogging of the membrane. Cylindrical configuration provides the possibility of maintaining high tangential velocity in the feed stream and is therefore particularly suitable for applications where the feed contains a high proportion of suspended solids or must be strongly concentrated.

The choice for a certain kind of membrane system is determined by a great number of aspects, such as costs, risks of plugging of the membranes, packing density and cleaning opportunities. The effects of the feed properties, the membrane properties, and the filtration conditions are obviously very important for the success of a membrane filtration process. Principal limitation of membrane lies in membrane fouling which is mainly associated with the deposition of a biosolids cake layer onto the membrane surface (McCutcheon & Elimelech, 2006; Mi & Elimelech, 2008). However, several alternatives have been implemented to enhance this problem (Al-Akoum et al., 2002; Jaffrin et al., 2004).

3.1 Membrane applications in food industry for wastewater treatment

Membrane separation process has special recognition in food wastewater treatment, applied to the end of conventional treatment systems (Vourch et al., 2008). The process is used

primarily to reduce the volume of the food wastewater that is achieved by recovering of two fluxes: permeate water flux having the majority of the original volume, and concentrated flux in a lesser volume (constituents of effluents retained).

The membranes used in food wastewater treatment differ widely in their structure and function. Mainly they are operated in four membrane processes: microfiltration (MF), ultrafiltration (UF), nanofiltration (NF) and reverse osmosis (RO). Solvent permeability and separation selectivity are the two main factors characterizing at these membranes. Transport mechanisms and operating membrane conditions can also explain the pass of species through membranes. Particle size is practically the sole criterion for describe the permeation or rejection of membranes. However, microporous membranes (NF and RO) have ability of separate particles at molecular level and their selectivity is mainly based on the chemical nature of the species.

Several works have been focused on these factors to explain separation selective of residues of food wastewater. Effluents treatment of dairy industry by RO and NF membranes are reported in many investigations, however, a strong development and growth of membrane technology can be observed in the results from the other food industries (Turano et al., 2002). Food industry standards specify that, spent process water intended for reuse (even for cleaning purposes) must be at least of drinking quality. Regulations for other applications, such as boiler make-up water or warm cleaning water, are even more stringent. There has been a study on the possibilities for reuse of vapor condensate in a milk processing company (dried milk production) as boiler make-up water (Hafez et al., 2007), and the reuse of chiller shower water in a meat processing company (sausage production) as warm cleaning water (Mavrov & Bélières, 2000).

3.2 Membrane characteristics

Generally membranes are characterized by pore flow or molecular weight of particle that is retained or is filtered by the membrane. However, important membrane properties such as structure, porosity, thickness, wettability surface and operating conditions, are also studied because affect rejection of solutes. The electrostatic repulsion between the membrane surface and the contaminant may be particularly analyzed to enhance waste solute retention and to increase water flux.

The smallest particle size present in the feed is very important for the selection of membrane pore size. However, currently the feed properties can be changed by pretreatments such as pH adjustment, thermal treatment, addition of chemicals, and pre-filtration. The pH adjustment (Luo et al., 2010) and thermal treatment can decrease the precipitation of certain substances. In addition, chemicals can be added to the feed to increase the particle size through aggregation, and the retention of specific substances can be enhanced through micellation or complexation (Wu et al., 2007). The salt concentration of the feed and the valence of the salt present can also be important to select membrane type (Muro et al., 2009; Lefebvre & Moletta, 2006)

3.2.1 Pore-flow and material membranes

Membrane pore flow is differentiated by the size of particles diameter that they can separate (micrometers, μm) and nominal molecular weight cutoff MWCO (kilo Daltons), which is a performance-related parameter, defined as the lower limit of a solute molecular weight for which the rejection is 95-98% (Boerlage et al., 2004). In theory, compounds having a molecular weight greater than the molecular weight cut off (MWCO) will be retained by the

membrane and compounds with molecular weights less than the MWCO will pass through the membrane as permeate. Table 3 shows size range of particles retained with range of MWCO membranes for treatment of wastewater of food industry.

Membrane Process	MWCO membrane (kilo Daltons range)	Retained diameters particle (μm range)	Retained solutes	Application in effluents treatment of food industry
MF	100-500	10^{-1} -10	Bacteria, fat, oil, grease, colloids, organics microparticles	Oil, Cereal, Dairy, Beverage
UF	20-150	10^{-3} – 1	Proteins, pigments, oils, sugar, organics microparticles	Dairy, Cereal, Oil, Tomato puree, Beer, Wine, Fish, Meat, Pickled vegetables
NF	2-20	10^{-3} – 10^{-2}	Pigments, sulfates, divalent cations, divalent anions, lactose, sucrose, sodium chloride	Olive oil, Dairy, Beverage, Meat canning, Pickled vegetable
RO	0.2-2	10^{-4} - 10^{-3}	Salts, sodium chloride and inorganic ions	Dairy, Cereal, Fish, Meat, Pickled vegetables

Table 3. Typical range of application of MWCO, diameter particle and retained solutes type by membrane process in wastewater treatment of food industry.

Retention is obviously affected by the pore size due to the sieving effect, especially when using MF and UF membranes. With tighter (NF and RO) membranes retention will be governed more and more by the electrostatic forces as well as by other interactions between membranes and solutes. Thus MWCO is only a rough indication of the membrane’s ability to remove a given compound as molecular shape because polarity and interaction with the membrane affect rejection (Guizard & Amblard, 2009).

Respect to pore diameter, it has frequently been seen that the membrane with the most open pores does not usually give the highest permeate flux in filtration process. Porosity (ratio of void space to total membrane volume in porous membrane) and pore size distribution may influence the apparent size of particles retained. Typical microporous membranes have average porosities in the range 30%–70%. Porosity can also be measured by analyzing processed images obtained from microscopic analyses such as scanning electron microscopy (SEM). Figure 2 shows SEM image of an asymmetric porous structure of a ceramic membrane. It may be noted that the membrane has fine pores through which raw water is filtered (Figure 2a). The most of ceramic membrane elements are constructed from supported multiple ceramic layers constituting an asymmetric porous structure.

Carbon macroporous material is used as support for ceramic membrane deposition (Figure 2b and 2c). Multiple layers are usually resulting from residual spaces created between ceramic particles during sintering. The bottleneck geometry is representative of pores resulting from sintering of almost spherical particles, for example, this is the case of porous structures obtained with titania, zirconia (Guizard et al., 2002; Guizard & Amblard, 2009). The porous sites are uniformly distributed in the membrane and effective diameter of the membrane pore can be determined assuming pores are circular in shape. However, pore geometry (tortuosity; τ) can also affect the retention of molecules by a membrane. Tortuosity reflects the length of the average pore compared to the membrane thickness. Cylindrical

pores at right angles to the membrane surface have a tortuosity of one, that is, the average length of the pore is the membrane thickness (Cho et al., 2000; Zhao et al., 2000; Vrijenhoek et al., 2001).

Fig. 2. SEM image of cross section of a ceramic membrane porous structure of MF, with cut off of 300 kDa and 5 μm pore size, used in wastewater treatment of food industry (From Escobar. PhD thesis, Institute Technological of Toluca, México, 2010)

Chemical composition, hydrophilicity/hydrophobicity, charge, and morphology have also significantly effect on permeability and stability of the membrane (Khayet et al., 2005). Particularly, ceramic membranes have a composite structure, which is used to increase the permeability for small pore size membranes by decreasing the overall hydraulic resistance (Peng et al., 2005; Yu et al., 2006) while polymeric membranes can be modified to make them more hydrophilic and achieve less fouling and better cleaning efficiency.

3.2.2 Surface pore charge. Isoelectric point

Membrane charge affects membrane efficiency in food wastewater treatment, particularly when low cutoff membranes are used for treatment effluents with high salts concentration. The charging occurs due to, for instance, dissociation of functional groups, adsorption of ions from solution, and adsorption of polyelectrolytes, ionic surfactants, and charged macromolecules. Generally, membrane materials carry a negative charge or are modified to have a negative charge because natural organic matter in water is negatively charged at neutral pH, due to phenolic and carboxylic functional groups (Kaeselev et al., 2002). A negatively charge membrane, therefore, prevents rapid deposition of foulants on the membrane surface by charge repulsion. An increase in the flux of a relatively dense membrane at a high pH may result from an increase in membrane hydrophilicity due to the dissociation of the functional groups in the membrane structure (Schaepe & Vandecasteele, 2001; Zhao et al., 2005). Many polymeric membranes are amphoteric, having both negatively and positively charged functional groups in the polymer matrix. Ceramic membranes can also show in water amphoteric behavior and thus their surface charge is pH dependent (Cho et al., 2000).

Membrane charge, as well as hydrophilicity property, can be predicted based on known membrane chemical structure. However, membrane surface/pore charge can be measure by electrical potential (Martín et al., 2003). When the membrane contains strongly acidic groups, the dissociation of the groups occurs immediately at a low pH, and the zeta

potential can be expected to be strongly negative even at low pH values (pH 2–3); while when the membrane contains weakly acidic groups, the zeta potential can be expected to become more negative from the point the groups start to dissociate to the point where the groups are totally dissociated. Similarly, strongly basic groups give positive potentials in most of the pH range, while weakly basic groups have no positive charges at pH values higher than 8 (Kim et al., 2005).

The isoelectric point (IP) (pH where net charge is zero) of a membrane is also a referent to determinate the behavior of their surface charge, depending on the pH of the wastewater in contact with the membrane. (Cheng et al., 2008). For example, typically NF polymeric membranes are negatively charged at neutral pH, with IP around pH 3–4, while ceramic membranes have a IP around pH 6–7

The IP of a membrane can be evaluated from the pH dependence of the zeta potential (Martín et al., 2003). However other experiments can also describe this parameter. Figure 3 shows isoelectric point of a ceramic membrane of zirconium and titanium oxide.

Fig. 3. Isoelectric point of a ceramic membrane of UF. (a) pH of permeate water is measured during an operation time range. (b) pH differential is determinate when pH feed solution is adjustment at 4–8 range, intersection of line with horizontal axe denotes isoelectric point at 6.2. (c) The values of zeta potential are measured in dependence with pH of ionic solution.

Figure 3a, denotes pH determination of pure water during water filtration by membrane of UF. In this membrane the pH value of permeate does not change with operation time. It shows that isoelectric point is around pH 6. Figure 3b shows the pH differential permeate water dependent of pH feed solution. Intersection of line with horizontal axe denotes isoelectric point at pH 6.2 for the same ceramic membrane. Figure 3c shows the values of zeta potential and pH of ionic solution; the values were measured through the pores of ceramic membrane. Intersection line with pH axis, indicates that isoelectric point is 6.2.

4. Influence of engineering aspects in food industrial wastewater treatment

Systematic studies of membrane applications in food wastewater treatment are focused on membrane functionality and performance filtration, under different operation condition. Several researches are specifically focused on optimizing crossflow hydrodynamics and/or membrane filter geometry to increment performance of water flux and maximum rejection or recovering species from effluents. Hydrodynamic factors affecting the membrane functionality, are cross-flow velocity (v) and transmembrane pressure (TMP). Permeate

flux can increase or decrease due to simultaneous influence of these variables. Temperature, dilution and pH are also variables involved in the membrane efficiency in membranes filtration. Permeate flux increases with increasing feed temperature due to a decrease in viscosity and/or due to an increase in solubility of suspended solids (Galambos et al., 2004). The exception is the presence of calcium and magnesium salts that might precipitate when temperature is increased. This problem can be avoided at least in some cases through feed pretreatment (Sarkar et al., 2006). The pH has a significant influence on the permeation rate especially around the isoelectric point of certain colloids where they tend to destabilize and precipitate. It also has an effect because of the changes in surface charge of the membrane either due to the amphoteric nature of the surface or due to the specific adsorption of species as presented earlier (Vourch et al., 2008).

4.1 Cross-flow velocity

A hydrodynamic variable of membranes in cross-flow filtration systems is essentially the velocity at which the feed flow is passed across the surface of the membrane. Crossflow velocity (ν) is linear velocity (m/s⁻¹) of the feed flow circulating tangentially across the membrane. This parameter is described by relation of feed flow rate (Q_w ; m³/s⁻¹) and the cross sectional area of feed membrane (A_s ; m²).

Turbulent flow conditions are recommended to maintain the flow tangential to the membrane, thereby reducing the phenomenon of concentration polarization and, consequently, the accumulation of solute near the membrane and inducing acceptable permeate flux for long time. Shear effects induce hydrodynamic filtration of the particles from the boundary layer back into the bulk, with a positive effect on the permeate flux. However, as feed concentration increases, it becomes more difficult to maintain a high recirculation velocity due to an increase in feed viscosity (Muro et al., 2009). In addition, if foods waste water containing macromolecular solutions with flexible solutes, thus also a high velocity can cause deformation of the polymer chains, which favors certain macromolecules that pass through the pores.

The hydrodynamics flow can also be characterized by calculating the Reynolds (Re) number by equation (1).

$$Re = \nu \frac{d_h}{\mu} \quad (1)$$

Where ν is crossflow velocity, d_h hydraulic diameter of membrane module and μ the dynamic viscosity of fluid.

Normally, $Re > 2100$ guarantees a turbulent flow in the module and a minimum thickness for the concentration polarization layer. Prevention of reversible fouling layer formation is sufficiently achieved by a crossflow velocity of around 2.0 ms⁻¹ in UF membranes (McKeown et al., 2005). In practical applications, one has to keep in mind that the permeate flux will be determined by the combination of crossflow velocity and TMP (See Figure 5).

4.2 Transmembrane pressure

The driving force for transport behind membrane process MF, UF, NF and RO, is the pressure difference between feed and permeate flux of the membrane (TMP; bar, psi). TMP is defined as the difference in pressure between the filtrate side of the membrane and the permeate side of the membrane. The average TMP is in general calculated as follows:

$$TMP = \frac{P_i + P_0}{2} - P_p \tag{2}$$

Where P_i is pressure at the inlet of the membrane module; P_0 is pressure at the outlet of the membrane module and P_p is permeate pressure.

The permeate flux depends directly on the applied TMP for a given surface area under uniform operational conditions. The flux of the pure water is linearly pressure dependent. However when food wastewater is treated by membrane system the flux is more complex. The behavior depends of wastewater composition, membrane type and crossflow velocity. In food wastewater treatment, one has to keep in mind that the permeate flux will be determined by the combination of crossflow velocity and TMP, due to contaminants (Sarkar et al., 2006; Blöcher et al., 2002; Oktay et al., 2007; Avula et al., 2009).

Figure 4a and 4b show the effect of crossflow velocity and TMP on permeate flux using two membranes of different MWCO (300 kDa and 15 kDa). The experiments were performed by Escobar, 2010. The results indicated that the flux enhancement caused by increasing crossflow velocity was particularly pronounced at range values of the TMP (3-5 bar) and crossflow velocity of 3 ms⁻¹. Fouling occurred over a range of TMPs of 5-6 bar and crossflow velocities at 3.5 ms⁻¹. The permeate flux decreased with time during the development of the fouling layer, but once the fouling layer was established, the permeate flux became constant for a given set of experimental conditions. Therefore these results indicate that at moderate values of TMPs and high flow rates at the membrane surface are operating conditions that conduce at high permeate fluxes in these experiments. Besides, figure 4c shows an overall positive effect of enhanced flow hydrodynamic conditions (TMP = 4 bar) on the average permeate flux, although in the turbulent regime (Re>3,000) a weaker correlation and more data scattering were observed. Therefore a clear correlation between the 3 h flux and Re in the transient regime (Re<3000) could be expected.

Fig. 4. Effect of crossflow velocity and TMP on the 3 h permeate flux in wastewater treatment of a cereal industry using membranes of MF and UF (a) 300 kDa. (b) 15 kDa. (c) The interdependence between average flux and hydrodynamic conditions for two membranes in a wide range of Re numbers at TMP = 4 bar (From Escobar 2010. PhD thesis, Institute Technogical of Toluca).

Particularly, operational membrane conditions in wastewater treatment show moderate TMP and high flow rates at the membrane surface are conducive of high permeate fluxes in

the MF and UF. An increase in TMP is required to maintain a particular water flux (constant-flux operation) independently of the membrane type and MWCO. However, an increasing flux could lead to an increase in polarization and fouling, which will limit the permeate flux (Abbasi et al., 2011; Simate et al., 2011).

High pressure can also allow membrane compaction, ultimately resulting in the formation of a denser membrane with smaller pores, or one possible enlargement of membrane pores with time, which enables particles to penetrate through the membrane matrix. Choi et al., (2005) showed clearly that pore sizes are modified in the membrane matrix increased with increasing TMP.

4.3 Permeate flow rate

The functionality of a membrane in wastewater treatment is determined by water permeation capacity and retention of solutes. Although permeate flux depends of the characteristics of the membrane and quality of wastewater, the average pore size and pore-size distribution is important since it will give an indication of which transport mechanism can be expected to be dominant for a given specie mixture in a defined material and at given process conditions. There are two theory models to describe the mechanism of permeation in membrane process; one is the solution-diffusion model, in which permeants are diffused through the membrane down a concentration gradient. The other model is the pore-flow model, in which permeants are transported by pressure-driven convective flow through tiny pores. Separation in this case, occurs by excluding of some particles of the pores in the membrane. Fick's law describes the mass flux through an area perpendicular to the flow direction (Miyoshi, 1998):

$$\frac{dV_i}{A dt} = J_{pi} = -D_i K_i \frac{dC_i}{dx} \quad (3)$$

Where J_{pi} is the linear fluid velocity (ms^{-1}) of component (i) or permeability flux ($\text{Lm}^{-2} \text{h}^{-1}$). The diffusion coefficient D_i (ms^{-1}) reflects the mobility of individual molecules in membrane material and the molecule sorption coefficient K_i reflects the number of molecules dissolved in the membrane material. The product $D_i K_i$ is membrane permeability and is a measure of the membrane's ability to permeate species. dC_i/dx is the concentration gradient (molL^{-1}) for component (i) over the length x (m). V_i is the volume of substance (i) transferred (L), t is time (h) and A is perpendicular area (m^2).

Permeability flux $J_{pi} = V_i/At$ is obtained by equation integration (3) and applied for $dx = x$ (membrane thickness or membrane resistance for the pure water transport). C_{i0} and C_{if} are the concentration of component (i) on the feed side and concentration of component (i) on the permeate side respectively. Solution-diffusion model is often used to describe the transport in RO membranes.

$$\frac{V_i}{At} = -L_p \frac{\Delta P}{x} \quad (4)$$

L_p is the hydraulic permeability coefficient ($\text{Lm}^{-2} \text{bar h}^{-1}$); ΔP is gradient pressure TMP (bar) in membrane system. Information about porous structure and viscosity of the filtrated liquid is contained in L_p factor.

Membrane resistance (x) is a measure of the hydraulic resistance to flow through a pore channel. However, when wastewater is fed, increment of TMP can cause a decreasing of

membrane permeability because of hydraulic resistance increment by the fouling phenomena. Increment of crossflow velocity, dilution of wastewater, change of temperature of feed and using turbulence promoters such as backflow techniques, feed pulsation and rotation of filter elements, are hydrodynamic methods to increment permeate flux and reduce the hydraulic resistance due to fouling (Jaffrin et al., 2004; Luo et al., 2010).

4.4 Selectivity factor

The best measure of the ability of a membrane to separate molecules (i) of wastewater, is the ratio of their permeability α_i , called the membrane selectivity, which can be written in terms of the apparent sieving coefficient:

$$\alpha_i = \frac{C_{ip}}{C_{if}}$$

(5)

C_{ip} is concentration of specie (i) in the permeate flux and C_{if} is the concentration of specie (i) in the feed flow.

The selectivity of a membrane depends on its ability to transmit different species to different extents. Factors that affect solute transmission are solute type, membrane type, solution pH, solution ionic strength, the permeate flux, and the hydrodynamic conditions on the feed side. Membrane selectivity is most often expressed as the membrane retention, R , toward the species to be separated. R is dimensionless parameter, with variation range of 0-100 %.

$$R = \frac{C_{if} - C_{ip}}{C_{if}} = (1 - \alpha_i)$$

(6)

Membrane/Cutt off (kDa)	Ions concentration (mgL ⁻¹) in water permeate							
	Na ¹⁺		K ¹⁺		Ca ²⁺		Fe ³⁺	
	TMP (bar)							
	4	5	4	5	4	5	4	5
MF/150	140	148	23.0	25.1	16.2	16.2	6.4	9.9
UF/15	133	135	22.2	20.1	13.1	13.0	5.7	2.1

Table 4. Effect of (TMP) on the permeability of some ions by MF y UF membranes

Rejection of neutral organic solutes generally increases with the molecular weight (or diameter) of the solute. Species will be retained by the membrane according to their size (sieving effect). For a mixture of multivalent and monovalent co-ions in the feed, multivalent co-ions are retained due to their higher electrical charge, while a part of monovalent co-ions pass through the membrane with counter ions to fulfill charge equilibrium criterion on both sides of the membrane (Lefebvre et al., 2003). However, the absolute values of the salt rejection vary over a wide range; the ranking for the different salts is the same for all membranes (Rautenbach & Albrecht, 1989). A high TMP value also affects the selectivity of some ions species. Table 4 shows the effect of TMP conditions on permeability of some ions by two ceramic membranes (Muro et al., 2009). Ions were identified in wastewater of a food industry. The experiments were performed to determine

the effect of pressure increment on selectivity of these membranes for these ions. The results indicate that for all PTM values, the ions Fe^{3+} and Ca^{2+} were slightly declined, while ions Na^+ and K^+ , were filtered by both membranes.

For other hand, exceptional selectivity for a number of important separations in wastewater treatment of food industry are mentioned in several reports (Vourch et al., 2008; Muro et al., 2010, Escobar et al., 2011; Simate et al., 2011).

Figure 4a and 4b show the difference between selectivity of two ceramic membranes of MF (300 and 150 kDa) and one of UF (50 and 15 kDa) for various TMP values. The data were obtained by experimental study of organics species in micelles with two colorants (a) Brilliant blue. (b) Tartrazine. Membranes denote a low selectivity for the colorants and a high permeability for water. Particularly, membrane of 15 kDa shows the lowest selectivity for two colorants for all TMP values. SEM image denotes, particles deposited on membrane surface, showing a low selectivity of a membrane of 300 kDa for tartrazine colorant.

5. Critical flux conditions

During membrane filtration process are identified three regimens in accordance to the critical flux theory (Field, 1995). Figure 6 shows a typical flux profile by three membranes.

Fig. 5. Difference between selectivity of ceramic membranes for two colorants from wastewater of a food industry (Muro et al., 2009). (a) brilliant blue. (b) tartrazine. (c) SEM image of a ceramic membrane of MF. White small particles of tatrazine may be seen on membrane surface.

Subcritical regime is the first stage of filtration, where flux varies linearly and reversibly with TMP, a high crossflow velocity is employed to increase capacity of permeation and a critical pressure is achieved in the end of this regime Processes where high water purity is required are carried out regime I, because membrane selectivity is optimal. The flux in regime II is independent of TMP, which can be described by an equilibrium stage, where the transport of particles toward the membrane is balanced with the transport of particles toward the bulk flow. At high TMP values, the permeate flux is not significantly affected by increases in pressure. This limiting flux or critical flux increases with increasing crossflow velocity, because materials deposited on the membrane by mass transport are removed by

the wall shear force. For soluble species and fine colloids, the critical flux can be considered as the flux below which the wall concentration does not initiate fouling (Cho & Fane, 2000). Choi et al., 2005). High capacity of the concentration of species from wastewater can also be achieved in this regime and the critical flux may either be identical to the clean water flux at the same TMP (Hwang et al., 2006). However, outside the limiting flux, operation at sustained permeability and selectivity is not possible due to the accumulation and compaction of the fouling layer on the membrane. Finally flux decline in time-dependent with high pressure above the critical TMP, are identified in regime III due to increment membrane fouling. Their removal is necessary for stable membrane operation (Espinasse et al., 2002).

Fig. 6. Critical flux regimes in membranes of 300, 150 and 15 kDa: (I) Subcritical operation (II) Critical operation (III) Decline flux.

The critical flux value depends largely on the hydrodynamic conditions in the process, the membrane pore size, and the feed physicochemical condition (Mänttari & Nyström, 2000). Appropriate manipulation of these parameters, specifically the hydrodynamic condition, may lead to increment of flux and the reduction or even the elimination of both reversible and irreversible fouling of the membrane. The critical flux can be experimentally identified through constant flux filtration experiments by incrementing the flux until the TMP is no longer steady.

6. Membrane fouling control in food industry for wastewater treatment

Fouling is the most important issue affecting the development of membrane filtration-as it worsens membrane performance and shortens membrane life (Boerlage et al., 2004). Membrane fouling by food wastewater filtration is attributed to deposition of species from effluents onto the membrane surface or within membrane porous, it causes a permeate flux decline with time because the filtration resistance is significant increased (Foley, 2006). Fouling studies on membranes are based in proteins deposition and their interaction in membranes surface. Polydispersity of naturally occurring macromolecules such as polysaccharides and humic substances, have also added a particular complexity on investigation to the fouling membrane mechanisms. Advances in understanding fouling of

other species such as bacteria, yeast, emulsions, suspensions, salts and colloids from food wastewater have occurred in microfiltration and ultrafiltration literature (Chan et al., 2002; Foley et al., 2005; Hughes & Field, 2006; Cheng et al., 2008).

There are two form of membrane fouling: the fouling layer that is readily removable from the membrane, it is often classified as polarization phenomena or reversible fouling and is removed by physical procedures. Internal fouling caused by adsorption of dissolved matter into the membrane pores and pore blocking is considered irreversible, which can be removed by chemical cleaning and other methods (Hughes & Field, 2006).

Several aspects such as pretreatment of feed solution (example add flocculants before filtration), membrane surface modification, operating conditions and heavy cleaning procedures such as high temperature, while using caustic, chlorine, hydrogen peroxide, ozone, and strong inorganic acids are carried out on the membrane plant in operation to decrement fouling problem. Hydrodynamic methods used for performance enhancement of membrane filtration as back-pulsed (permeate flow reversal technique), creation of pulsed flow in membrane module, TMP pulsing, creation of oscillatory flow, generation of Dean vortices in membrane module, generation of Taylor vortices in membrane module and use of gas-sparging, have also been developed to reduce membranes fouling (Parck, 2002; Choi et al., 2005; Luo et al., 2010). Specifically, rapid accumulation of foulants, is usually referred to the critical flux (Chan et al., 2002). For single particles deposition, the critical flux occurs at a particular hydrodynamic condition (Espinasse et al., 2002). Critical flux condition can be determined by adsorption process, a slow increase in membrane resistance is always detected by the kinetics of this adsorption, particularly for proteins (Hughes & Field, 2006; Vyas et al., 2002; Ognier et al., 2002). For complex fluid systems, one common practice to experimentally determine the critical flux value is to incrementally increase the flux for a fixed duration. This leads to relatively stable TMP at low fluxes (indicating little fouling), and an ever increasing rate of TMP rises at fluxes beyond the critical flux values (Knutsen and Davis, 2006). In fluids with both macromolecules and particulates, membrane fouling takes place even at low flux rates, but changes dramatically when critical flux is reached. Although rigorous mathematical expressions to determinate membrane fouling, have been reported (Rögener et al., 2002b; Lefebvre et al., 2003), experimental critical flux determination remains an efficient approach to assess the fouling behavior of a given filtration system and to compare different operating conditions (Clech et al., 2006).

7. Optimization membrane process in food industry for wastewater treatment

In order to use membranes filtration as an efficient separation technique and economically interesting, the process optimization is essential. The purpose of the optimization process is the achievement of the highest possible flux production for a long period of time, with acceptable pollution levels.

A well chosen wastewater pretreatment and a proper selection of membrane in relation to the species properties from effluents can be used to assess and predict the optimal flux during filtration. However, the control of the feed pH, ionic strength and temperature is often necessary in order to maximize removal of food production residues.

Optimization methods and statistical designs are widely employed in various field of science from chemistry to engineering to enhance the membrane processes. Particularly, Response Surface Methodology (RSM) is a sequential form of experimentation used to help

predict or optimize process. The variables are integrated in a mathematical-statistical model to express the possible simultaneous influence of membrane characteristics, fed composition and operating conditions on water flux performance. Several membrane processes and operating conditions have been reported in the treatment of food wastewater (Stoller and Chianese, 2006; Iaquina et al., 2009; Escobar et al., 2011)

Table 5, summarize some results that describe the treatment wastewater optimization from production of these food. The permeate water fluxes are different in optimization process, due to membrane type used, membrane area and fed wastewater quality.

Reference	Food wastewater	Membrane process/membrane area (m ²)	Optimum conditions	Maximal permeate flux (Lh ⁻¹ m ⁻²)
Stoller and Chianese, (2006)	Olive oil	UF/32 NF/32	Oil concentration, feed flow velocity, temperature, critical flux, membrane type	415.8 222.0
Iaquina et al., (2009)	Tomato puree	NF/2.51	Fed concentration, conductivity, temperature, , feed flow velocity, transmembrane pressure	8.21
Escobar et al. (2011)	Cereal	UF/0.56	Transmembrane pressure, membrane type, dye concentration (brilliant blue and tartrazine), flow velocity, filtration time	19.5

Table 5. Membrane conditions in treatment food wastewater optimization

8. Recovery of food industrial effluents by membrane process and water reuse

The drivers for implementation of water reuse practices in food industries is essential due to increasing demands on declining freshwater supplies, severe water shortages and dry periods, and the fact that water quality discharge regulations have become stricter. In addition, environmental and economical aspects are incentives to treat food wastewater with water reuse purpose (Casani et al., 2005).

Food industry looks at membrane processes for wastewater treatments to produce purified water for recycle or reuse due to their characteristics as techniques that can be implemented in any food plant and because they can be combined with other unit operations (hybrid processes (Sarkar et al, 2006). Table 6 summarizes some important results of recycling water and cleaning effluents by membrane technology.

Typical wastewaters in food industries come from different parts of the plant and they are submitted to a wide fluctuation in flow and composition depending on the type of food industry and size and even, on the moment in which the plant is working (different steps of “cleaning in place”, heating, sterilization, etc.). They do not contain toxic compounds (except in wastewater from washing fruits and vegetables in which pesticides can be a water contaminant) but they are characterized by high values in biological oxygen demand (BOD) and chemical oxygen demand (COD) as well as total dissolved solids (TSS) in some cases. Those high contents come from organic (proteins, carbohydrates, fats) and inorganic (salts, additives, dyes) compounds.

Reference	Industry/wastewater source	Combined membrane treatments	Water recycling
Chmiel at al., (2003)	Dairy/Vapor condensates from concentration and drying steps	Cartridge filtration-NF-RO-UV-oxidation	Drinking
Mavrov et al., (1997), (2000); Chmiel et al., (2000); Čuda et al., (2006); Vourch et al., (2008)		Two NF steps	Water use in boilers
Koo et al., (2011)	Dairy/Flash coolers	Cartridge filtration-NF-UV	Boiler make up water
Rögener et al., (2002a), (2002b), (2002c); Tay & Jeyaseelan, (1995)	Milk/ Bottles machines, chess processing	UF and RO	Unspecified
Scharnagl et al., (2000); Muro et al., (2010)		MF, UF, NF	
Mavrov and Bélières, (2000); Braeken et al., (2004); Simate et al., (2011); Cornelissen, (2002); Blöcher et al., (2002)	Beverage/bottle rinsing, brewing room , bright beer reservoir	MBR-NF, RO	Unspecified
Rajkumar et al., (2010); Muro et al., (2009)	Fruit and vegetable processing/rinsing beans, cereal processing	MF, UF, NF, RO	Rinsing beans
Iaquinta et al., (2006), (2009); Mänttäri & Nyström, (2000)	Tomato/cleaning, sorting and moving the processed	NF	Unspecified
Noronha et al. (2002); Blöcher et al., (2002)	Fruit juices/ bottle washing, fruit processing, juice production and cleaning of tanks, pipes	NF	Drinking
Turano et al. (2002) Mohammadi & Esmaelifar, (2004); Galambos et al., (2004); Akdemir & Ozer, (2009); Mantzavinos & Kalogerakis, (2005); Rajkumar et al., (2010)	Vegetable oil/olive mill, washing,	MF, UF, NF, RO	Drinking
Fähnrich et al., (1998); Cui & Muralidhara, 2010; Cheryan, 1998; Afonso and Bórquez (2002a); Bohdziewicz et al. (2002), (2003), Bohdziewicz & Sroka, (2005a), (2005b), (2006), Kuca & Szaniawska, (2009); Walha et al., (2009); Dumay et al., (2008).	Meat and seafood/ slaughterhouse fish and crustaceans and tuna cooking	Two NF steps-UV SBR, MBR, UF and RO in different combinations	Drinking

Table 6. Promising applications of membranes in wastewater treatment of food industry

8.1 Recovery of cleaning-in-place solutions

Special attention can give at the recovery cleaning solutions from wastewater of food industries. A large amount of acids and alkalis in cleaning and sanitizing steps are used in dairy industry. The consumption of NaOH, HNO₃ and detergents/disinfectants in a dairy industry that processes 1.5 million liters of milk per day is around 3 500, 1 000 and 1 000 kg per day respectively (Fernández et al., 2010). More than 40% of the total pollution caused by a dairy industry comes from their cleaning in place units (Henk, 1993). Particularly, the cleaning in place (CIP) used in food industries consists in a number of steps that depends on the type of product, but the final waste streams collected from each of these stages are usually treated together and show COD values of 400-600 mgO₂.L⁻¹ (Daufin et al., 2001).

There are a number of works describing how to recover contaminated cleaning solutions by membranes (Choe et al., 2005; Fernández et al., 2010; Gésan-Guizieu et al., 2002, 2007; Merin et al., 2002; Räsänen et al., 2002). Dresch et al. (2001) pointed out the NF technology as a promising technique compared to decantation, centrifugation and microfiltration (0.1 μm cut-off) for the regeneration of waste NaOH solutions from an industrial CIP system. However, Gésan-Guizieu et al. (2007) reported that MF could be more adequate operation based on that the surfactant contained in the spent detergent is only slightly rejected by the membrane and costs of MF operation are much lower (lower TMP) compared to UF and NF costs, in spite of that the COD permeate when using MF was much higher and its possible uses can be limited.

When using NaOH or HNO₃ solutions in alkaline and acid cleaning steps, their recovery in the permeate is not very difficult, because the rejection of these compounds on an ultrafiltration or even in a NF are very low, obtaining a permeate stream than can be reused in the CIP and being the rest of foulants retained by the membrane. However, when the cleaning agent is composed by other chemicals (antiscalants, anionic/cationic detergents, antifoaming compounds, surfactants, etc.) their recovery in the permeate stream is not so evident (Wendler et al., 2002). The use of MF, UF or NF techniques depends on if surfactants want to be recovered in the permeate or in the concentrate streams. If surfactants are below their critical micelle concentration (CMC) they will not be retained by any of these techniques, but if they are above CMC, MF and UF techniques retain these components and the permeate stream will lose its cleaning properties. Some works based on NF processes with the aim of surfactants recovery in the permeate stream have been published in the last years (Boussu et al., 2007, Forstmeier et al., 2002; Kaya et al., 2006, 2009). In those cases permeate flux and surfactant rejection are strongly dependent on the membrane material (membrane isoelectric point - IEP) and feed conditions (pH, concentration, etc.) due to that NF processes are not only governed by steric reasons and charge interaction between solutes and membrane surface plays an important role in transmission and membrane selectivity.

Diluted caustic and acidic washing solutions (showing COD between 8 000 and 10 000 mgO₂.L⁻¹) can be recovered by NF membranes with molecular weight cut off (MWCO) between 150 and 300 Da. Permeate flow rates are moderate (between 7 and 12 Lh⁻¹m⁻²) at pressures around 0.9 MPa (Räsänen et al., 2002). NF shows robust performance for the recovery of caustic solutions when faced with large variations of solution composition, as it happens at industrial CIPs (Dresch et al., 1999; Gésan-Guizieu et al., 2002). In some published research, transmission of NaCl higher than 99% was measured when variable feed composition (COD between 100 and 11 000 mgO₂.L⁻¹) and suspended matter between 0.4 and 5.6 gL⁻¹ was nanofiltered with ceramic membranes of 1 000 MWCO obtaining high permeate flow rates (40-110 Lh⁻¹m⁻²) at 70°C and 0.4 MPa transmembrane pressure.

Regarding to the acidic detergents used in food industries CIPs, some results have been published (Novalic et al., 1998). Two HNO_3 spent solutions were investigated with NF. Higher COD cleaning solution of $18\,500\text{ mgO}_2\cdot\text{L}^{-1}$ was obtained after a cleaning step without previous alkaline step. The other solutions was lower in COD ($1\,800\text{ mg O}_2\cdot\text{L}^{-1}$) and was obtained after a previous alkaline cleaning step. Two effluents were nanofiltered at $50\text{ }^\circ\text{C}$ and 3.0 MPa and at maximum recovery rate of 75%.

In other studies, several salts ($\text{Ca}(\text{NO}_3)_2$ and $\text{Mg}(\text{NO}_3)_2$) were analyzed in the cleaning solution. However low COD solution essayed was nanofiltered at a rate of $40\text{ Lh}^{-1}\text{m}^{-2}$ and final COD was low ($450\text{ mgO}_2\cdot\text{L}^{-1}$). Kaya et al. (2009) used NF ($1\,000\text{ Da}$ cut-off) to treat a detergent composed by anionic and nonionic surfactants, dyes and salts from a dishwasher detergent. Maximum fluxes (around $120\text{ Lh}^{-1}\text{m}^{-2}$, $25\text{ }^\circ\text{C}$, 1.2 MPa) were obtained at pH of 5, near to the membrane IEP. However, surfactants have hydrophobic interactions with anionic dyes (tartrazine) what explains higher rejection than expected (Kartal & Akbas, 2005; Zahrim et al., 2011). Authors found also strong influence of temperature and pH on the flux decay along the experiments. Initial higher fluxes at higher temperatures (40°C) rapidly decay due to pores blocking by surfactant monomers and rejections reduces with temperatures due to an increase in solutes diffusion or expansion of membrane structure a higher temperatures (organic membranes).

For other hand, large dairy companies (food companies in general) are changing the conventional cleaning agents for those novel single-phase detergents. These new formulations are expensive but CIP steps are shorter and only have one or two steps (cleaning and disinfection). Single-phase detergents are designed by detergent companies and formulations are not available but alkalis or acids, surfactants, complexant agents and de-foamers usually are included. Recovery of these detergents is not easy because all the components should be permeate through the membrane and to should separate from the rest of foulants, what might be retained. Some authors have been studied the recovery of these detergents by NF processes using a spent single-detergent from a milk company (Fernández et al., 2010). In spite of that NF membrane (200 Da cut-off) maintains constant permeate flux rate (around $45\text{ Lh}^{-1}\text{m}^{-2}$) at 0.9 MPa , 70°C and 75% recovery rate after 1800 hours running, infrared studies demonstrated that some compounds present in the fresh single phase detergent are partially retained by the membrane.

8.2 Recovering of the other valuables constituents of wastewater of food industry

An overview of types and applications of membrane separation techniques to recover of proteins and functional compounds from wastewater cheese and fish processing are showed in this section.

Chollangi & Hossain (2007) evaluated the fractionation of dairy wastewater into lactose-enriched and protein-enriched streams using ultrafiltration membrane technique. Three membranes of MWCO of 3, 5 and 10 kDa of regenerated cellulose material were used to determine the efficiency of the process. The performance was determined under various processing conditions that include the operating temperature and TMP across the membrane and the concentration of lactose in the feed solution. It was found that the 3, 5 and 10 kDa membranes provided 70–80%, 90–95% and 100% recovery of lactose in permeate, respectively from made-up solution of pure lactose. The 10 kDa membrane results showed a 100% recovery of lactose from wastewater sample. Muro et al. (2010) worked with residual whey from a cheese industry, it was fractioned to recover proteins, lactose and

minerals by membranes process in filtration stages: UF and NF. The results of membrane process to treatment of whey depended on the operating conditions, but the temperature effect was greater in the ultrafiltration process. 80% of proteins from whey were recovered with the membrane of 15 kDa operating to 2.4 Lh⁻¹ to 30°C and 1.5 bar. The NF process showed that the transmembrane pressure affect lactose rejection, obtaining itself 70% of yield with the membrane of 0.150 kDa, using a flow of Lh⁻¹ to 25 °C and 1.8 bar.

Respect to wastewaters from fish processing, effluents contain a large amount of potentially valuable proteins. These proteins can be concentrated by means of ultrafiltration (UF) and recycled into the fish meal process, improving its quality and the economic benefits from the raw material, whereas the treated water can be discharged into the sea or reused in the plant. An extensive review of the application of pressure-driven membrane separation processes in the treatment of seafood processing effluents and recovery of proteins therein was presented by Alfonso & Bórquez, (2002b). Two effluents from a fish meal plant located in Talcahuano, Chile, were characterized. A mineral tubular membrane, Carbosep M2 (MWCO = 15 kDa) was used in the UF experiments. The operating conditions were optimized in total recirculation mode, and the subsequent concentration experiments were carried out at 4 bar pressure, 4 ms⁻¹, crossflow velocity, ambient temperature and natural pH. The results show that UF reduces the organic load from the fish meal wastewaters and allows the recovery of valuable raw materials comprising proteins. Dumay's work focuses on the treatment of washing waters coming from surimi manufacturing using ultrafiltration technology at a laboratory scale. Four membrane materials (poly-ether sulfone, polyacrilonytrile, poly vinylidene fluoride and regenerated cellulose) and 5 MWCO (from 3 to 100 kDa) were studied at bench laboratory scale using the pilot Rayflow® 100, commercialised by Rhodia Orelis. The investigation deals with the ability for membranes to offer a high retention of biochemical compounds (proteins and lipids) (Dumay et al., 2008).

9. Conclusions

Wastewaters produced in the food industry depend upon the particular site activity. Animal processors and rendering plants will generate effluents with different characteristics to those from fruit/vegetable washers and edible oil refiners (suspended/colloidal and dissolved solids, organic pollution and oil and greases as well as microbial contamination).

MF and UF systems can reduce suspended solids and microorganisms, whilst UF/RO combinations can also remove dissolved solids and provide a supply of process water and simultaneously reducing waste streams. UF systems can get more than 90% reduction in BOD and less than 5 mg.L⁻¹ in residual solids and less than 50 mg.L⁻¹ in grease and oil. NF systems are being used in a number of applications thank to the quick development in new membrane materials. In case of RO process, BOD removal rate of 90-99% is possible providing a low cost controlled source of bacteria-free water.

The favourable characteristics (modular) of membrane technologies allow to use different techniques as it has be seen all along this chapter. These hybrid processes can include traditional techniques as centrifugation, cartridge filtration, disinfection and different membrane techniques building a "cascade design" very used in many of the applications reviewed. The risk of membrane damage due to the contact with particles, salt conglomerates, chemicals or others substances must be minimized to prevent short

membrane life. Operation parameters must be carefully selected to obtain good results, especially not to overpass maximum temperature and transmembrane pressures recommended by membrane manufacturers. From the point of view of each particular process, to work at permeate flow rates below critical flux will assure longer runs. Membrane operating optimization is another aspect of paramount importance.

It seems likely that the application of membrane systems in the food industry will continue growing rapidly. In particular, wastewater treatments will become more important in the next years because of the increasing cost of mains water and effluent sewer disposal. A membrane wastewater treatment system can be a major contribution to a food sector and its introduction may feature as part of the continuous improvement plans within an environmental management system.

10. References

- Abbasi, M.; Sebzari, M.; Salahia, A.; Abbasi, S. & Mohammadi, T. (2011). Flux Decline and Membrane Fouling in Cross-Flow Microfiltration of Oil-In-Water Emulsions. *Desalination and Water Treatment*, Vol.28, No.1-3, (April 2011), Pp. 1-7, ISSN 00119164
- Afonso, M. & Bórquez, R. (2002a). Review of the Treatment of Seafood Processing Wastewaters and Recovery of Proteins Therein by Membrane Separation Processes - Prospects of the Ultrafiltration of Wastewaters from the Fish Meal Industry. *Desalination*. Vol. 142, No. 1, Pp. 29-45, ISSN 0011-9164
- Afonso, M. & Bórquez, R. (2002b). Nanofiltration of Wastewaters from the Fish Meal Industry. *Desalination*. Vol.151, No. 2, Pp. 131-138, ISSN 0011-9164
- Akdemir, E.O. & Ozer, A. (2009). Investigation of Two Ultrafiltration Membranes for Treatment of Olive Oil Mill Wastewater. *Desalination*, Vol.249, No. 2, (December 2009), Pp. 660-666, ISSN 00119164
- Al-Akoum, O., Mercier-Bonin M., Ding, L.; Fonade, C.; Aptel, P. & Jaffrin M. (2002). Comparison of Three Different Systems Used for Flux Enhancement: Application to Yeast Crossflow Filtration of Yeast Suspensions. *Desalination*, Vol.147, (September 2002), Pp. 31-36, ISSN 00119164
- Avula, R.Y.; Nelson, H.M. & Singh, R.K. (2009). Recycling of Poultry Process Wastewater by Ultrafiltration. *Innovative Food Science and Emerging Technologies*, Vol.10, No.1, (January 2009), Pp. 1-8, ISSN 14668564
- Blöcher, C.; Noronha, M.; Fünfrocker, L.; Dorda, J.; Mavrov, V.; Janke, H.D. & Chmiel, H. (2002). Recycling of Spent Process Water in the Food Industry by an Integrated Process of Biological Treatment and Membrane Separation. *Desalination*, Vol.144, No.1-3, (September 2002), Pp. 143-150, ISSN 00119164
- Boerlage, S. F. E.; Kennedy, M.; Tarawneh, Z.; Faber, R. D.; & Schippers, J. (2004). Development of the MFI-UF in Constant Flux Filtration. *Desalination*, Vol.161, No.2, (February 2004), Pp. 103-113, ISSN 00119164
- Bohdziewicz, J. & Sroka, E. (2005a). Treatment of Wastewater from Meat Industry Applying Integrated Membrane Systems. *Process Biochemistry* Vol., 40, No. 3-4, (March 2005), Pp. 1339-1346, ISSN 00329592
- Bohdziewicz, J. & Sroka, E. (2005b). Integrated System of Activated Sludge-Reverse Osmosis in the Treatment of the Wastewater from Meat Industry. *Process Biochemistry*, Vol. 40, No. 5, (April 2005), Pp. 1517-1523, ISSN 13595113

- Bohdziewicz, J. & Sroka, E. (2006). Application of Hybrid Systems to the Treatment of Meat Industry Wastewater. *Desalination*, Vol., 198, No. 1-3, (October 2006), Pp. 33-40, ISSN 00119164
- Bohdziewicz, J.; Sroka, E. & Korus, I. (2003). Application of Ultrafiltration and Reverse Osmosis to the Treatment of the Wastewater Produced by the Meat Industry. *Polish Journal of Environmental Studies*, Vol.12, No. 3, Pp. 269-274, ISSN 12301485
- Bohdziewicz, J.; Sroka, E. & Lobos, E. (2002). Application of the System Which Combines Coagulation, Activated Sludge and Reverse Osmosis to the Treatment of the Wastewater Produced by the Meat Industry. *Desalination*, Vol. 144, No. 1-3, (September 2002), Pp. 393-398, ISSN 00119164
- Boussu, K.; Kindts, C.; Vandecasteele, C. & Van Der Bruggen, B. (2007). Surfactant Fouling of Nanofiltration Membranes: Measures and Mechanism. *A European Journal of Chemical Physics and Physical Chemistry*, Vol.8, No.12, (August 2007), Pp. 1836-1845, ISSN 14394235
- Braeken, L.; Van Der Bruggen, B. & Vandecasteele, C. (2004). Regeneration of Brewery Waste Water Using Nanofiltration. *Water Research*, Vol. 38, No. 13, (July 2004), Pp. 3075-3082, ISSN 00431354
- Casani, S.; Rouhany, M. & Knøchel, S. (2005). A Discussion Paper On Challenges and Limitations to Water Reuse and Hygiene in the Food Industry. *Water Research*, Vol.39, No.6, (March 2005), Pp. 1134-1146, ISSN 00431354
- Chan, R.; Chen, V. & Bucknall, M.P. (2002). Ultrafiltration of Protein Mixtures: Measurement of Apparent Critical Flux, Rejection Performance, and Identification of Protein Deposition, *Desalination*, Vol.146, No. 1-3, (September, 2002), Pp. 83-90, ISSN 00119164
- Cheng J.; Li Y.; Chung T.; Chen S. & Krantz W. (2008). High-Performance Protein Separation by Ion Exchange Membrane Partitioned Free-Flow Isoelectric Focusing System. *Chemical Engineering Science*, Vol.63, No.8, (April 2008), Pp. 2241-2251, ISSN 00092509
- Cheryan, M. (1998). *Ultrafiltration and Microfiltration Handbook*, Technomic, ISBN 1-56676-598-6, Lancaster, USA
- Chmiel, H.; Kaschek, M.; Blöcher, C.; Noronha, M. & Mavrov V. (2003). Concepts for the Treatment of Spent Process Water in the Food and Beverage Industries. *Desalination*, Vol.152, No.1-3, (February 2003), Pp. 307-314, ISSN 00119164
- Chmiel, H.; Mavrov, V. & Bélières, E. (2000). Reuse of Vapour Condensate from Milk Processing Using Nanofiltration. *Filtration&Separation*, Vol.37, No.3, (April 2000), Pp.24-27, ISSN 00151882
- Cho, B.D. & Fane, A.G. (2000). Fouling Transient in Nominally Sub-Critical Flux Operation of A Membrane Bioreactor. *Journal of Membrane Science*, Vol.209, No.2, (November 2002), Pp. 391-403, 03767388
- Cho, J.; Amy, G., & Pellegrino, J. (2000). Membrane Filtration of Natural Organic Matter: Factors and Mechanism Affecting Rejection and Flux Decline With Charged (UF) Membrane. *Journal of Membrane Science*, Vol.164, No.1-2, (January 2000), Pp. 89-110, ISSN 03767388
- Choe, E.K.; Son, E.J.; Lee, B.S.; Jeong, S.H.; Shin, H.C. & Choi, J. S. (2005). NF Process for the Recovery of Caustic Soda and Concentration of Disodium Terephthalate from

- Alkaline Wastewater from Polyester Fabrics. *Desalination*, Vol. 186, No. 1-3, (December 2005), Pp. 29-37, ISSN 00119164
- Choi, K. H.; Zhang, D.D.; Dionysiou, D.; Oerther, D & Sorial G.A. (2005). Effect of Permeate Flux and Tangential Flow On Membrane Fouling for Wastewater Treatment, *Separation and Purification Technology*, Vol. 45, No.1, (September 2005), Pp. 68-78, ISSN 13835866
- Chollangi, A. & Hossain, M. (2007). Separation of Proteins and Lactose from Dairy Wastewater. *Chemical Engineering and Processing*, Vol.46, No.5, (May 2007), Pp. 398-404, ISSN 02552701
- Clech, P.; Jefferson, B.; Chang, I.S. & S.J. Judd. (2006). Critical flux Determination by the Flux-Step Method in A Submerged Membrane Bioreactor, *Journal membrane Science* 227 (2006) 17-53. ISSN:03767388
- Cornelissen E.R.; Janse, W. & Koning, J. (2002). Wastewater treatment with the internal MEMBIOR. *Desalination*, Vol. 146, No. 1-3, (September 2002), Pp. 463-466, ISSN 00119164.
- Čuda, P.; Pospíšil, P. & Tenglerová, J. (2006). Reverse Osmosis in Water Treatment of Boilers. *Desalination*, Vol.198, No.1-3, (October 2006), Pp. 41-46, ISSN 00119164.
- Cui, Z.F. & Muralidhara, H.S. (Eds.). (2010). *Membrane Technology*. Elsevier, ISBN 978-1-85617-632-3, Langford Lane, UK
- Dauvin, G.; Escudier, J-P.; Carrère, H.; Bérot, S.; Fillaudeau, L. & Decloux, M. (2001). Recent and Emerging Applications of Membrane Processes in the Food and Dairy Industry. *Trans. Icheme.*, Vol. 79, No. 2, (June 2001), Pp. 89-102, ISSN 09603085
- Dresch, M.; Dauvin, G. & Chaufer, B. (1999). Membrane Processes for the Recovery of Dairy Cleaning in Place Solutions. *Lait*, Vol. 79, No. 2, (March 1999), Pp. 245-259, ISSN 00237302
- Dresch, M.; Dauvin, G. & Chaufer, B. (2001). Integrated Membrane Regeneration Process for Dairy Cleaning-In-Place. *Separation and Purification Technology*, Vol. 22-23, No. 1, (March 2001), Pp. 181-191, ISSN 13835866
- Dumay, J.; Radier, S.; Barnathan, G.; Bergé, J. & Jaouen, P. (2008). Recovery of Valuable Soluble Compounds from Washing Waters Generated During Small Fatty Pelagic Surimi Processing by Membrane Processes. *Environmental Technology*, Vol. 29, No. 4, Pp. (451-461), ISSN 0959-3330, London, England
- Escobar, J. (2010) Optimización Del Proceso de Ultrafiltración de Efluentes de Una Industria de Cereales. Thesis Doctor, Institute Technological of Toluca, México
- Escobar, J.; Muro, C. & Estupiñan J. (2011). Optimización Del Proceso de Ultrafiltración de Efluentes de Una Industria de Cereales. *Afinidad: Revista de Química Teórica Y Aplicada*, Vol.68, No. 551, (January 2011), ISSN 0001-9704
- Espinasse, B.; Bacchin, P. & Aimar, P. (2002). On an Experimental Method to Measure Critical Flux in Ultrafiltration. *Desalination*, No.1-3, (September 2002), Pp. 146 91-96, ISSN 00119164
- Fährnich, A.; Mavrov, V. & Chmiel, H. (1998). Membrane Processes for Water Reuse in the Food Industry. *Desalination*, Vol. 119, No. 1-3, (September 1998), Pp. 213-216, ISSN 00119164
- Fernández, P.; Riera, F.A.; Álvarez, R. & Álvarez, S. (2010). Nanofiltration Regeneration of Contaminated Single-Phase Detergents Used in the Dairy Industry. *Journal of Food Engineering*, Vol. 97, No.3, (April 2010), Pp. 319-328, ISSN 02608774

- Field, R.W.; Wu, D.; Howell, J.A. & Gupta, B.B. (1995). Critical flux concept for microfiltration fouling. *Journal Of Membrane Science*, Vol. 100, No. 3, (abril 1995), Pp. 259-272, ISSN 03767388.
- Foley, G. (2006). A Review of Factors Affecting Filter Cake Properties in Dead End Microfiltration of Microbial Suspensions, *Journal of Membrane Science*, Vol. 274, No.1-2, (Abril 2006), Pp. 38-46, ISSN 03767388
- Foley, G., McCarthy, A.A. & Walsh, P.K. (2005). Evidence for Shape-Dependent Deposition in Crossflow Microfiltration of Microbial Cells, *Journal of Membrane Science*, Vol.250, No.1-2, (March 2005), Pp. 311-313, ISSN 03767388
- Forstmeier, M.; Goers, B. & Wozuy, G. (2002). Product Recovery and Reduction of Wastewater Disposal Costs in A Detergent Production Facility. *Engineering in Life Sciences*, Vol.3, No.4, (April 2002), Pp. 181-185, ISSN 0009286X
- Galambos, I.; Molina, J.; Jray, P.; Vatai, G. & Molnr, E. (2004). High Organic Content Industrial Wastewater Treatment by Membrane Filtration. *Desalination*, Vol.162, (March 2004), Pp.117-120, ISSN 00119164
- Gsan-Guiziu, G.; Alvarez, N.; Jacob, D. & Daufin, G. (2007). Cleaning in Place Coupled With Membrane Regeneration for Re-Using Caustic Soda Solutions. *Separation and Purification Technology*, Vol.54, No.3, (May 2007), Pp. 329-339, ISSN 13835866
- Gsan-Guiziu, G.; Boyaval, E. & Daufin, G. (2002). Nanofiltration for the Recovery of Caustic Cleaning-In-Place Solutions: Robustness Towards Large Variations of Composition. *Journal of Dairy Research*, Vol. 69, No. 4, (November 2002), Pp. 633-643, ISSN 00220299
- Guizard, C. & Amblard, P. (2009). Chapter 6. Current Status and Prospects for Ceramic Membranes Applications in *Handbook of Membrane Separation: Chemical, Pharmaceutical, Food and Biotechnological Applications*. Ed. Taylor Francis Group. Pabby, K.; Rizvi, S. & Sastre A., Pp. 139-179, Boca Ratn, USA.
- Guizard, C.; Ayrl, A. & Julbe A. (2002). Potentiality of Organic Solvents Filtration With Ceramic Membranes. A Comparison With Polymer Membranes. *Desalination*, Vol.147, (Septembre 2002) Pp. 275-280, ISSN 00119164
- Hafez, A.; Khedr, M. & Gadallah H. (2007). Wastewater Treatment and Water Reuse of Food Processing Industries. Part II: Techno-Economic Study of A Membrane Separation Technique. *Desalination*, Vol.214, No.1-3, (August 2007), Pp. 261-272, ISSN 00119164
- Henk, M.A. (1993). Recycling of Caustic Cleaning Solutions Using Cross-Flow Filtration in the Dairy Industry. Ph.D. Thesis, University of Zurich, Switzerland
- Hughes, D. & Field, R.W. (2006). Crossflow Filtration of Washed and Unwashed Yeast Suspensions At Constant Shear Under Nominally Sub-Critical Conditions. *Journal of Membrane Science*, Vol.280, No.1-2, (September 2006), Pp. 89-98, ISSN 03767388
- Hwang, K.J.; Chou, F.Y. & Tung, K.L. (2006). Effects of Operating Conditions On Performance of Cross-Flow Microfiltration of Fine Particle Protein Binary Suspension, *Journal Membrane Science*, 274, 183, 2006.ISSN:03767388
- Iaquinta, M.; Stoller, M. & Merli, C. (2006). Development of Synthetic Wastewater from the Tomato Industry for Membrane Processing Purposes. *Desalination*, Vol. 200, No. 1-3, Pp. (314-320), ISSN 0011-9164, Amsterdam, Netherlands
- Iaquinta, M.; Stoller, M. & Merli, C. (2009). Optimization of A Nanofiltration Membrane Process for Tomato Industry Wastewater Effluent Treatment. *Desalination*, Vol.245, No.1-3, (September 2009), Pp. 314-320, ISSN 00119164

- Jaffrin, M.; Ding, L.; Akoum, O. & Brou A. (2004). A Hydrodynamic Comparison Between Rotating Disk and Vibratory Dynamic Filtration Systems. *Journal of Membrane Science*, Vol.24 No.1-2, (October 2004), Pp. 155–167, ISSN 03767388
- Kaeselev, B., Kingshott, P. & Jonsson, G. (2002). Influence of the Surface Structure On the Filtration Performance of UV-Modified PES Membranes. *Desalination*, Vol.146, No.1-2, (September 2002), Pp. 265-271, ISSN 00119164
- Kartal, C. & Akbas, H. (2005). Study On the Interaction of Anionic Dye-Nonionic Surfactants in A Mixture of Anionic and Non-Ionic Surfactants by Adsorption Spectroscopy. *Dyes Pigments*, Vol. 65, No. 3, (June 2005), Pp. 191-195, ISSN 01437208
- Kaya, Y., Aydiner, C.; Barlas, H. & Keskinler, B. (2006). Nanofiltration of Single and Mixture Solutions Containing Anionics and Nonionic Surfactants Below Their Critical Micelle Concentration (Cmcs). *Journal of Membrane Science*, Vol. 282, No.1-2, (October 2006), Pp. 401-412, ISSN 03767388
- Kaya, Y.; Barlas, H. & Arayici, S. (2009). Nanofiltration of Clearing in Place (CIP) Wastewater in A Detergent Plant: Effects of Ph, Temperature and Transmembrane Pressure On Flux Behaviour. *Separation and Purification Technology*, Vol. 45, No.2, (February 2009), Pp.117-129, ISSN 13835866
- Khayet, M.; Matsuura, T. & Mengual, J. (2005). Porous Hydrophobic/Hydrophilic Composite Membranes: Estimation of the Hydrophobic-Layer Thickness. *Journal of Membrane Science*, Vol.266, No.1-2, (December 2005), Pp. 68-78, ISSN 03767388
- Kim, Y.; Ahn, W.; Kim, J. & Kim, Y. (2005). in Situ Fabrication of Self-Transformable and Hydrophilic Poly(Ethylene Glycol) Derivative-Modified Polysulfone Membranes. *Biomaterials*, Vol.26, No.16, (June 2005), Pp. 2867-2875, ISSN 01429612
- Knutsen, J.S. & Davis R.H. (2006). Deposition of Foulant Particles During Tangential Flow Filtration, *Journal of Membrane Science*, Vol.271, No.1-2, (March 2006), Pp. 101–113, ISSN 03767388
- Koo, C.G.; Mohammad, A., W. & Suja, F. (2011). Recycling of Oleochemical Wastewater for Boiler Feed Water Using Reverse Osmosis Membranes. A Case Study. *Desalination*, Vol. 271, No. 1-3, (April 2011), Pp. 178-186, ISSN 00119164
- Kuca, M. & Szaniawska, D. (2009). Application of Microfiltration and Ceramic Membranes for Treatment of Salted Aqueous Effluents from Fish Processing. *Desalination*, Vol.241, No.1-3, (May 2009), Pp. 227-235, ISSN 00119164
- Lefebvre, O. & Moletta, R., (2006). Treatment of Organic Pollution in Industrial Saline Wastewater: A Literature Review. *Water Research*, Vol.40, No.20, (December 2006), Pp. 3671-3682, ISSN 00431354
- Lefebvre, X.; Palmeri, J.; Sandeaux, J; Sandeaux, R.; David, P.; Maleyre, B.; Guizard, C.; Amblard, P.; Diaz, J. & Lamaze B.(2003). Nanofiltration Modelling: A Comparative Study of the Salt Filtration Performance of A Charged Ceramic Membrane and an Organic Nanofilter Using the Computer Simulation Program NANOFLUX. *Separation and Purification Technology*, Vol.32, No.1–3, Pp. 117–126, ISSN 13835866
- Luo, J; Ding, L.; Wan, Y.; Paullier, P. & Jaffrin M. (2010). Application of NF-RDM (Nanofiltration Rotating Disk Membrane) Module Under Extreme Hydraulic Conditions for the Treatment of Dairy Wastewater. *Chemical Engineering Journal*, Vol.163, No.3, (October 2010), Pp. 307-316, ISSN 00219592

- Madaeni, S.S. & Mansourpanah, Y. (2006). Screening Membranes for COD Removal from Diluted Wastewater. *Desalination*, Vol.197, No.1-3, (October 2006), Pp. 23-32, ISSN 00119164
- Mänttari, M. & Nyström, M. (2000). Critical Flux in NF of High Molar Mass Polysaccharides and Effluents from the Paper Industry. *Journal of Membrane Science*, Vol. 170, No. 2, (May 2000), Pp. 257-273, ISSN 03767388
- Mantzavinos, D. & Kalogerakis, N. (2005). Treatment of Olive Mill Effluents: Part I. Organic Matter Degradation by Chemical and Biological Process-An Overview. *Environmental International*, Vol.31, No.2, (February 2005), Pp. 289-295, ISSN 01604120
- Martín, A.; Martínez, F.; Malfeito, J.; Palacio, L.; Prádanos, P.; & Hernández, A. (2003). Zeta Potential of Membranes As A Function of Ph: Optimization of Isoelectric Point Evaluation. *Journal of Membrane Science*, Vol.213, No.1-2, (March 2003), Pp. 225-230, ISSN 03767388
- Matthiasson, E. (1983). the Role of Macromolecular Adsorption in Fouling of Ultrafiltration Membranes. *Journal of Membrane Science*, Vol.16, Pp. 23-26, ISSN 03767388
- Mavrov, V.; Fährnich, A. & Chmiel, H. (1997). Treatment of Low-Contaminated Waste Water from the Food Industry to Produce Water If Drinking Quality for Reuse. *Desalination*, Vol.113, No.2-3, (November 1997), Pp. 197-203, ISSN 00119164
- Mavrov, V. & Bélières, E. (2000). Reduction of Water Consumption and Wastewater Quantities in the Food Industry by Water Recycling Using Membrane Processes. *Desalination*, Vol.131, No.1-3, (December 2000), Pp. 75-86, ISSN 00119164
- McCutcheon, J. & Elimelech, M. (2006). Influence of Concentrative and Dilutive Internal Concentration Polarization On Flux Behavior in Forward Osmosis. *Journal of Membrane Science*, Vol.284, (November 2006), Pp. 237-247, ISSN 03767388
- McKeown, N.B.; Budd, P.M.; Msayib, K J.; Ghanem, B.S.; Kingston, H.J.; Tattershall, C.E.; Makhseed, S., Reynolds, K.J. & Fritsch, D. (2005). Polymers of Intrinsic Microporosity (Pims): Bridging the Void Between Microporous and Polymeric Materials. *Chemistry - A European Journal*, Vol.11, No.9, (April 2005), Pp. 2610-2620, ISSN 00092665
- Merin, U.; Gésan-Guiziou, G.; Boyaval, E. & Daufin, G. (2002). Cleaning-In-Place in the Dairy Industry: Criteria for Reuse of Caustic (Naoh) Solutions. *Lait*, Vol. 82, No. 3, Pp. 357-366, ISSN 00237302
- Mi, B, & Elimelech M. (2008). Chemical and Physical Aspects of Organic Fouling of Forward Osmosis Membranes. *Journal of Membrane Science*, Vol.320, No.1-2, (July 2008), Pp. 292-302, ISSN 0367388
- Miyoshi, H. (1998). Diffusion Coefficients of Ions Through Ion Exchange Membrane in Donnan Dialysis Using Ions of Different Valence. *Journal of Membrane Science*, Vol.141, No.1, Pp. 101-110, (April 1998), ISSN 03767388
- Mohammadi, T. & Esmaelifar, A. 166 (2004). Wastewater Treatment Using Ultrafiltration At A Vegetable Oil Factory, *Desalination*, Vol.166, (August 2004) Pp.329-337, ISSN 00119164
- Muro, C.; Díaz, C.; García, B.; Zavala, R.; Ortega, R.; Álvarez, R. & Riera, R. (2010). Recuperación de Los Componentes Del Lactosuero Residual de Una Industria Elaboradora de Queso Utilizando Membranas. *Afinidad: Revista de Química Teórica Y Aplicada*, Vol.67, No.547, (Mayo 2010), Pp. 212-220, ISSN 0001-9704

- Muro, C.; Escobar, J.; Zavala, R.; Esparza, M.; Castellanos, J.; Gómez R. & García M. (2009). Evaluación Del Proceso de Microfiltración En Un Efluente Residual de Una Industria Alimentaria Para Su Reuso. *Revista Internacional de Contaminación Ambiental*, Vol.25, No.4, (November 2009), Pp. 229-238, ISSN 01884999
- Noronha, M.; Britz, T.; Mavrov., V.; Janke, H.D. & Chmiel, H. (2002). Treatment of Spent Process Water from A Juice Company for Purpose of Reuse: Hybrid Process Concept and On-Site Test Operation of A Pilot Plant. *Desalination*, Vol., 143, No.2, (May 2002), Pp. 183-196, ISSN 00119164
- Novalic, S.; Dabrowski, A. & Kulbe, D. (1998). Nanofiltration of Caustic and Acidic Cleaning Solutions With High COD. Part 2. Recycling of HNO₃. *Journal of Food Engineering*, Vol.38, No.2, Pp. 133-140, ISSN 02608774
- Ognier, S., Wisniewski, C. & Grasmick, A. (2002). Influence of Macromolecule Adsorption During Filtration of A Membrane Bioreactor Mixed Liquor Suspension, *Journal of Membrane Science*, Vol.209, No.1, (November 2002), Pp. 27-37, ISSN 03767388
- Okokchina. (2010). Hollow Fiber Module. 05.07.2011, Available from <Http://Www.Okokchina.Com/Pall.Com/Pdf/Mtcpaper.Pdf>
- Oktay, S.; Iskender, G.; Babuna, F.; Kutluay, G. & Orhon D. (2007). Improving the Wastewater Management for A Beverage Industry With In-Plant Control. *Desalination*, Vol.211, No. 1-3, (June 2007), Pp. 138-143 ISSN 00119164
- Park Y.G. (2002). Effect of Ozonation for Reducing Membrane-Fouling in the UF Membrane. *Desalination*, Vol.147 No. 1-3, (September 2002), Pp. 43-48, ISSN 00119164
- Peng, P., Fane, A. & Li, X. (2005). *Desalination* by Membrane Distillation Adopting A Hydrophilic Membrane. *Desalination*, Vol.173, No.1, (March 2005), Pp. 45-54, ISSN 00119164
- Rajkumar, K.; Muthukumar, M. & Sivakumar R. (2010). Novel Approach for the Treatment and Recycle of Wastewater from Soya Edible Oil Refinery Industry – An Economic Perspective. *Resources, Conservation and Recycling*, Vol.54, No.10, (August 2010), Pp. 752-758, ISSN 09213449
- Räsänen, E.; Nyström, M.; Sahlstein, J. & Tossavainen, O. (2002). Purification and Regeneration of Diluted Caustic and Acidic Washing Solutions by Membrane Filtration. *Desalination*, Vol. 149, No. 1-3, (September 2002), Pp. 185-190, ISSN 00119164
- Rautenbach, R. & Albrecht R. (1989). *Membrane Processes*, John Wiley & Sons, Inc. Chichester ISSN 19816286
- Rögener, F.; Mavrov, V. & Chmiel, H. (2002b). Modeling of Impurity Concentrations in the Cleaning Zones of Bottle Washing Machines in the Treatment of Alkaline Solutions and Rinsing Water. *Chemical Engineering and Technology*, Vol. 25, No. 1, (January 2002), Pp. 41-47, ISSN 09307516
- Rögener, F.; Mavrov, V. & Chmiel, H. (2002c). Treatment of Rinsing Water from A Bottle Washing Machine by Membrane Filtration With the Goal of Re-Use. *Chemie-Ingenieur-Technik*, Vol. 74, No. 4, (April 2002), Pp. 517-524+373, ISSN 0009286X
- Rögener, F.; Willems, M.; Mavrov, V. & Chmiel, H. (2002a). the Influence of Cleaning Additives On Rejection and Permeability in Nanofiltration and Ultrafiltration of Bottle Washing Solutions. *Separation and Purification Technology*, Vol. 28, No. 3, (September 2002), Pp. 207-217, ISSN 13835866

- Sarkar, B.; Chakrabarti, P.P.; Vijaykumar, A. & Kale, V. (2006). Wastewater Treatment in Dairy Industries-Possibility of Reuse. *Desalination*, Vol.195, No.3-4, (March 2009), Pp. 141-152, ISSN 00119164
- Schaep, J. & Vandecasteele, C. (2001). Evaluating the Charge of Nanofiltration Membranes. *Journal of Membrane Science*, Vol.188, No.1, (Junmy 2001), Pp. 129-136, ISSN 03767388
- Scharnagl, N.; Bunse, U. & Peinemann, K.-V. (2000). Recycling of Washing Waters from Bottle Cleaning Machines Using Membranes. *Desalination*, Vol.131, No.1-3, (December 2000), Pp. 55-63, ISSN 00119164
- Simate, G.S.; Cluett, J.; Iyuke, S.E., Musapatika, E.T.; Ndlovu, S.; Walubita, L.F. & Alvarez, A.E. (2011). the Treatment of Brewery Wastewater for Reuse: State of the Art. *Desalination*, Vol.273, No.2-3, (June 2011), Pp. 235-247, ISSN 00119164
- Stoller, M. & Chianese, A. (2006). Optimization of membrane batch processes by means of the critical flux theory. *Desalination*, Vol. 191, No. 1-3, (May 2006), Pp. 62-70, ISSN 00119164.
- Tay, J.-H. & Jeyaseelan, S. (1995). Membrane Filtration for Reuse of Wastewater from Beverage Industry. *Resources, Conservation and Recycling*, Vol., 15, No 1, Pp. 33-40, ISSN 09213449
- Turano, E.; Curcio, S.; de Paola, M.G.; Calabro, V. & Dorio, G. (2002). an Integrated Centrifugation-Ultrafiltration System in the Treatment of Olive Mill Wastewater. *Journal of Membrane Science*, Vol.209, No.2, (November 2002), Pp. 519-531, ISSN 03767388
- Vourch, M.; Balannec, B.; Chaufer, B. & Dorange, G. (2008). Treatment of Dairy Industry Wastewater by Reverse Osmosis for Water Reuse. *Desalination*, Vol.219, No.1-3, (January 2008), Pp. 190-202, ISSN 00119164
- Vrijenhoek, E., Hong, S., & Elimelech, M. (2001). Influence of Membrane Surface Properties On Initial Rate of Colloidal Fouling of Reverse Osmosis and Nanofiltration Membranes. *Journal of Membrane Science*, Vol.188, No. 1, (June M2001), Pp. 115-128, ISSN 03767388
- Vyas, H.K.; Bennett, R.J. & Marshall, A.D. (2002). Performance of Crossflow Microfiltration During Constant Transmembrane Pressure and Constant Flux Operations, *International Dairy Journal*, Vol.12, No.5, Pp. 473-479, ISSN 0250-5118
- Walha, K.; Ben Amar, R.; Bourseau, P. & Jaouen, P. (2009). Nanofiltration of Concentrated and Salted Tuna Cooking Juices. *Process Safety and Environmental Protection*, Vol.87, No.5, (September 2009), Pp. 331-335, ISSN 09575820
- Wendler, B.; Goers, B. & Wozny, G. (2002). Regeneration of Process Water Containing Surfactants by Nanofiltration. Investigation and Modelling of Mass Transport. *Water Science and Technology*, Vol. 46, No. 1-3, Pp. 287-292, ISSN 02731223
- Wu, T.; Mohammada, A.; Jahim, J. & Anuar, N. (2007). Palm Oil Mill Effluent (POME) Treatment and Bioresources Recovery Using Ultrafiltration Membrane: Effect of Pressure On Membrane Fouling. *Biochemical Engineering Journal*, Vol.35, No.3, (August 2007), Pp. 309-317, ISSN 1369703X
- Yu, H.; Ziegler, C.; Oszcipok, M.; Zobel, M. & Hebling, C. (2006). Hydrophilicity and Hydrophobicity Study of Catalyst Layers in Proton Exchange Membrane Fuel Cells. *Electrochimica Acta*, Vol.51, No.7, (January 2006), Pp.1199-1207, ISSN 02510790

- Zahrim, A.Y.; Tizaoui, C. & Hilal, N. (2011). Coagulation With Polymers for Nanofiltration Pre-Treatment of Highly Concentrated Dyes: A Review. *Desalination*, Vol. 244, No. 1-3, (January 2011), Pp. 1-16, ISSN 00119164
- Zhao, C., Zhou, X., & Yue, Y. (2000). Determination of Pore Size Distribution On the Surface of Hollow-Fiber Filtration Membranes: A Review of Methods. *Desalination*, No. 129, Vol.2, (July 2000) Pp. 107-123, ISSN 00119164
- Zhao, Y., Xing, W., Xu, N., & Wong, F. (2005). Effects of Inorganic Electrolytes On Zeta Potentials of Ceramic Microfiltration Membranes. *Separation and Purification Technology*, Vol.42, No.2, (March 2005), Pp. 117-121, ISSN 13835866

Food Industrial Processes - Methods and Equipment

Edited by Dr. Benjamin Valdez

ISBN 978-953-307-905-9

Hard cover, 418 pages

Publisher InTech

Published online 22, February, 2012

Published in print edition February, 2012

The global food industry has the largest number of demanding and knowledgeable consumers: the world population of seven billion inhabitants, since every person eats! This population requires food products that fulfill the high quality standards established by the food industry organizations. Food shortages threaten human health and are aggravated by the disastrous, extreme climatic events such as floods, droughts, fires, storms connected to climate change, global warming and greenhouse gas emissions that modify the environment and, consequently, the production of foods in the agriculture and husbandry sectors. This collection of articles is a timely contribution to issues relating to the food industry. They were selected for use as a primer, an investigation guide and documentation based on modern, scientific and technical references. This volume is therefore appropriate for use by university researchers and practicing food developers and producers. The control of food processing and production is not only discussed in scientific terms; engineering, economic and financial aspects are also considered for the advantage of food industry managers.

How to reference

In order to correctly reference this scholarly work, feel free to copy and paste the following:

Claudia Muro, Francisco Riera and María del Carmen Díaz (2012). Membrane Separation Process in Wastewater Treatment of Food Industry, Food Industrial Processes - Methods and Equipment, Dr. Benjamin Valdez (Ed.), ISBN: 978-953-307-905-9, InTech, Available from: <http://www.intechopen.com/books/food-industrial-processes-methods-and-equipment/membrane-separation-process-in-wastewater-treatment-of-food-industry>

INTECH
open science | open minds

InTech Europe

University Campus STeP Ri
Slavka Krautzeka 83/A
51000 Rijeka, Croatia
Phone: +385 (51) 770 447
Fax: +385 (51) 686 166
www.intechopen.com

InTech China

Unit 405, Office Block, Hotel Equatorial Shanghai
No.65, Yan An Road (West), Shanghai, 200040, China
中国上海市延安西路65号上海国际贵都大饭店办公楼405单元
Phone: +86-21-62489820
Fax: +86-21-62489821

© 2012 The Author(s). Licensee IntechOpen. This is an open access article distributed under the terms of the [Creative Commons Attribution 3.0 License](https://creativecommons.org/licenses/by/3.0/), which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

IntechOpen

IntechOpen