We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,300

Open access books available

172,000

International authors and editors

190M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities

WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com

Energy Efficiency Improvements in a Distribution Network based on Local Voltage Control using Energy Storage Systems and Active Loads

Lucian Mihet-Popa and Voicu Groza

Additional information is available at the end of the chapter

<http://dx.doi.org/10.5772/59308>

1. Introduction

The European Union target for 2020, regarding CO₂ decrease in the electricity sector, is of 20 %. This will assume an important increase in PV installation all over Europe producing a few Giga Watts of additional capacity [1-4].

Today, the problem of energy efficiency becomes a very important issue. That means the entire industry is turning towards clean, renewable energy with different actively controlled loads, including Electric Vehicles (EV) and smart sensors. Increased distributed generation in the existing power systems is becoming significant. In the near future it will be based on DER components including energy storage systems and on smart-grids [2, 5-12].

The battery package solutions are an interesting and useful option for storing surplus energy from the network (e.g. resulting from solar and wind intermittency) for a later use. It may also act as a peak shaving unit and thereby contribute to a stronger grid. Vanadium redox flow batteries have many advantages over other storage technologies, including storage efficiency, low maintenance costs and a long life cycle [13-17].

In order to study various aspects of Battery Storage Systems (BSS) accurate battery dynamic models are required [13-26].

Control strategies for battery energy storage systems have become a critical design issue. The challenge is to smooth the intermittent power output of RES, and to keep the rated voltage of the distribution substation within the standard limits [3, 9-12, 19-24].

This paper focuses on simulation models, validated by measurements using experimental facility of an active and distributed power systems laboratory, with storage systems connected together with PV Systems and a Flex-House with controllable loads at a distribution network. Three types of local voltage control of the bus-bar to which the BSS was connected are also described, implemented and tested successfully.

This paper is structured as follows: in Section II, the distributed power system laboratory architecture is introduced; The Section III presents the simulation models of DER components used in this paper while the Section IV is devoted to implementation, simulation and testing of control strategies for DER components in a distribution network. Section V concluded this paper.

2. Distributed energy network architecture

The laboratory used for testing and to validate the simulation models in this research is a smart grid with distributed control and with a high share of renewable systems.

The experimental facility of the lab contains a Wind/PV/Diesel Hybrid Mini-Grid with local storage and a novel control infrastructure. It includes two wind turbines (10 kW and 11 kW), three PV-plants (7.2 kW and 2 × 10 kW), a diesel gen-set (48 kW/60 kVA), an intelligent office building-Flex House with controllable loads (10 kW), a number of loads (75 kW, 3×36 kW), a Vanadium Redox Battery-VRB of 15 kW/120 kWh and three containers, each with an EV Li-ion battery pack of 50 Ah/16 kWh and 75 Ah/27 kWh, respectively and a bi-directional power converter of 90 kW.

The facility is spread across three sites located several hundred meters apart, as can be seen in Figure 1a).

At each of the sites there is a switchboard that let the already mentioned components to be connected to two bus bars. The components are all connected in one distributed control and measurement system that enables very flexible setup with respect to the experimental configuration [25-28], as it is shown in Figure 1b).

The acquisition of data and the control system (hardware and software) is capable for the supervision and control of the research platform with a high penetration of renewable energy systems. The software program, responsible for monitoring and supervision, is written in Java and is able to handle the data acquisition, and to control the outputs variable of the components. The sensors outputs are connected to a signal conditioning system, which in turn is connected to the data acquisition (DAQ) board based on SCADA System.

Certain of the active loads can be controlled by the centralized controller which is able to receive the data and the events from wireless switches and smart sensors. In control room, a small touch-screen graphical user interface can be used to change the controller policy (Figure 1c). The building controller can obtain information on the status of the power network, and based

on that will adapt its control strategy accordingly. The control system is based on a closed loop controller, in which the active policies, measurement data and user settings can be communicated back to the grid.

a)

b)

Figure 1. a) The distributed power system laboratory with real components, b) details about the Micro-Grid architecture of the lab and c) GUI generated by SCADA for control system.

All units of the distribution network – generators, loads, storage systems, and the switchgear – are automated and remote-controllable.

Each unit is locally monitored and controlled by a specialized controller node.

The node is able to connect together an industrial PC, data storage, measurements and I/O interfaces into a portable and compact container with the backup power and the Ethernet switch inside.

The flexible control system was used for testing the components and the control strategies implemented, for the validation of the simulation models.

3. Distributed energy resources components modeling

3.1. PV panel and system modeling and validation

The model of the PV system contains the PV panel’s model and the model of the inverter. It has as inputs the irradiation, the ambient temperature and the wind speed, which are converted into cell temperature and irradiation to be used as inputs for the model of the panels (Figure 2a), and as output the AC power from the inverter [25-28].The block *Measurements*, in Figure 1a), contains the inputs of the simulation model (irradiation, temperature and wind speed), which are used by the *Data processing* block as inputs to convert them into cell temperature and irradiation to be used further by *PV Panel* blocks, as inputs together with the number of cells in series (ns), the number of panels in series (nps) and with the number of strings in parallel (nsp).

The simulation model takes into account the variation of the parameters (open-circuit voltage- V_{OC} and short-circuit current- I_{SC}) with respect to temperature- T_{cell} and irradiation- G_{cell} and also the tilt angle and orientation of the panels.

The PV inverter is characterized by a power dependent efficiency where the input power of the model is the maximum DC power produced by the panels.

The dynamic model of the PV System (PV panels and PV inverter) has been built with standard block components from the library and also using the dynamic simulation language (DSL), in Power Factory, to implement the equations and to define the states and the parameters of the model.

The model of the panels is based on a single diode equivalent electrical circuit, described by an exponential equation [25-28], as can also be seen in Figure 2 b).

a)

b)

Figure 2. Details about the single diode electrical circuit and the exponential equations of the PV model (on the top) and its implementation using standard block components.

The simulation model was validated using experiments carried out using experimental facility of a research and development lab with real components [25-28], as was shown in Figure 1.

A block diagram with the PV model implementation steps (Figure 3a) and with a comparison between simulation and measurements (Figure 3b) is shown in Figure 3.

To validate the simulation model of the PV components and PV systems and to show the significance of considering the atmospheric conditions, such as irradiation, temperature and wind speed, and also the orientation of the panels and its tilt angle, the simulations were compared with experimental results (Figure 3b) carried out using the experimental facilities of the distributed power system laboratory-SYSLAB, shown in Figure 1.

The SCADA system facility disposes of two types of available measured data: ambient parameters (taken from a weather station as can be seen in Fig. 3a) and electrical parameters (taken from the DAQ board of the PV inverter).

The ambient data are the wind speed, the ambient temperature and the horizontal solar irradiance. The data read from the weather station is measured in different conditions as the PV array: the irradiance is measured on a horizontal plane and the station is positioned further and higher than the PV array. The electric data represent the DC current, voltage and power on each of the three PV input strings, measured directly by the PV inverter.

The electric measurements have a time period of 1 seconds and the environment measurements have a sampling time of 10 seconds; thus the system changes states each 10 seconds, and only once in this 10 seconds interval the model takes the current value from the previous state.

In Figure3b) is shown a comparison between measured and simulated output power, voltage and current (P_{DC} , I_{DC} , V_{DC}) for a time series of 1 day. Considering the tilt angle and panels' orientation, the influence of solar irradiance and wind speed on the cell temperature the measurements and simulations are almost identically, as can be seen in Figure 3b).

a)

b)

Figure 3. a) A block diagram with details about the steps of PV simulation model implementation and b) comparison between simulations and measurements DC current, voltage and power for a PV panel and the output power of the inverter (P_{ac}) as a function of time for 24h.

3.2. Actively controlled loads

The simulation model of the intelligent office building, called Flex-House, is based on the equivalent electro-thermal model of the building (Figure 4) using a stochastic discrete-time linear state-space model (1), combining with physical knowledge regarding heat transfer inside the house, together with statistical methods to estimate model parameters [28-29].

The office building is heated by 10 electrical heaters of 1 kW each, which can be used as active controllable loads in the distribution system.

The model for the building is formulated as one room lumped-RC-model in accordance with the commonly used thermal-electrical analogy:

$$\left\{ \begin{array}{l} C_i \cdot \frac{dT_i}{dt} = \frac{1}{R_{ia}} \cdot (T_a - T_i) + \frac{1}{R_{im}} \cdot (T_m - T_i) + \frac{1}{R_{ih}} \cdot (T_h - T_i) + A_w \cdot G \\ C_m \cdot \frac{dT_m}{dt} = \frac{1}{R_{im}} \cdot (T_i - T_m) \\ C_h \cdot \frac{dT_h}{dt} = \frac{1}{R_{ih}} \cdot (T_i - T_h) + P_h \end{array} \right. \quad (1)$$

Where C_i is the heat capacity of the house, R_{ia} represents the thermal resistance from the indoor to the ambient, A_w is the effective window area of the house with heating influence. The state space variables are: T_i – inside temperature, T_m – second inside temperature which defines an internal medium and T_h – temperature in the electrical heater.

Figure 4 a) shows the heat flow diagram for the building (upper) and the equivalent RC-circuit, as well.

The implementation of the simulation model (Figure 4b) is based on (1) and is divided into four separate parts, a thermal model of the building (*FH_ThermalSlot* block), a controller model (*FH_Controller* block), a module to read input data (*FH_Input Measurement* block) and a load connected to a power system (*FH_LoadSlot* block). The input values are measured ambient temperature and solar radiation. From the right the blocks are: input data reader, thermal model of the building, the building temperature controller and the power system load model.

a)

b)

c)

Figure 4. a) Flex House office building heat-flow diagram (upper) and its equivalent single room RC-circuit diagram, b) implementation of the building model with actively controlled loads and c) simulation results of the temperature inside the building (T_{inside}) and the power consumption of the heaters (Active Power) for one day.

Figure 4c) has shown a simulation of the temperature inside the building and the power consumption of the heaters, for one day, using measured temperature and solar radiation from SYSLAB via SCADA system, as inputs of the simulation model.

3.3. Battery energy storage components and systems modeling

We have used in this study, as battery energy storage components, 2 types of devices: a Li-ion battery of 26 kWh/75 Ah designed for EV applications and a Vanadium Redox Battery (VRB) package of 15 kW/190 kWh, for storing excess energy from the grid and to use it in order to control the grid voltage and frequency.

3.3.1. EV battery modeling and simulation

An equivalent circuit modeling with one or two RC block model is the common approach for lithium-cell batteries [14-17]. A single RC block model is adequate for many problems of industrial relevance and has also been used in this paper in combination with a runtime-based electrical battery model (Figure 5).

Figure 5. The electrical equivalent circuit model of the EV battery and its equations.

The runtime electrical battery model (on the left in Figure 5) represents the battery lifetime and contains a self-discharge resistor ($R_{\text{self-discharge}}$), a condenser (C_{capacity}) and a current-controlled source (I_{batt}). $R_{\text{self-discharge}}$ is used to characterize the self-discharge energy loss when batteries are stored for a long time and depends on SOC and temperature. C_{capacity} represents the whole charge stored in the battery (SOC) and can be express like in Figure 5 [14].

Where C_n represents the nominal capacity of the battery and $f_1(\text{cycle})$ and $f_2(T)$ are cycle number and temperature dependent correction factors.

On the right side in Figure 5 it is represented the Thevenin electrical circuit model which represents the voltage-current characteristic of the battery. The model contains a series resistor (R_s) and a RC parallel network (R_t , C_t) to predict the transient response of the battery. Each parameter of the Thevenin circuit is a function of SOC, current and temperature and was

implemented in MATLAB/Simulink and DlgSILENT Power Factory using two-dimensional look-up tables based on the measurements shows in Figure 6a).

The series resistance voltage droop (V_s) and the equivalent voltage transient response (V_t) are combined with the open-circuit voltage (V_{OC}) to obtain the battery terminal voltage (V_{batt}), as it is described by the equations on the right side of the Figure 5.

The model of the battery pack was implemented based on the equations presented in Figure 5 and the measurements presented in [30] as shown in Figure 6. The model provides the SOC, power of the battery and the battery voltage as a function of SOC, current and temperature.

Each parameter of the Thevenin circuit is a function of SOC, current and temperature and was implemented using two-dimensional look-up tables based on the measurements at different SOC, current levels and temperatures using pulse current discharging/charging test.

a)

Figure 6. a) Details with EV battery storage simulation model implementation based on equivalent circuit and measurements and b) simulation results of the EV battery pack system with a pulsed current during discharging mode.

In Figure 6b) was shown a time-series simulation with EVs battery cell and package voltage and SOC during the discharging mode when the battery was discharged from full rate to zero, when a battery constant pulsed current of 25 A was applied.

3.3.2. Modeling of the vanadium redox battery system validated by measurements

The VRB model has been implemented in MATLAB/Simulink and DIgSILENT PowerFactory [25]-[26] and is based on the equivalent electrical circuit using the power balance between the input and the stored power.

The power flow is dependent on the efficiency of different components, such as: cell stacks, electrolytes, pumps, power converter and also on the power losses, as it is shown in Figure 7a).

Figure 7b) shows the schematic structure of the simulation model implemented in Power Factory, including Battery Model, charge/discharge controller, PLL block and Static Generator with its Controller. The VRB system frame also contains the measurements blocks, such as voltage, active & reactive power and frequency, used as inputs for different components of the model. The VRB Simulation Model has as outputs cell current and voltage and SOC level, which are the inputs for charge/discharge controller, as can also be seen in Figure 7b).

The simulation model was validated by measurements taken from the DAQ board of the VRB system.

The experiment have been acquired for a time scale of 36 hours considering the starting point of the SOC=93.5%, meanwhile the battery was discharged with a constant power of $P_{AC}=15kW$, until the State of Charge decreased to SOC=18%. After that a sequence of charging was considered from SOC=14% until SOC=87% at the constant power of $P_{AC}=10kW$.

As can be seen in Figure 7c) a comparison between simulation results and experiments of the SOC level of the battery is presented. It is shown a very small difference between curves, which means that the developed simulation model can be consider an accurate tool for studying and analyzing the characteristics of the battery energy storage system in a distribution grid.

Figure 7. a) VRB simulation model implemented using experimental results based on the equivalent circuit, b) block diagram of the Battery System Simulation Model and c) comparison between simulations and measurements.

These characteristics of the battery have been computed based on the results of experiments [14] where different electric values at different loads and SOC levels were measured. The

simulation model was validated by measurements using experimental facility of the active and distributed power systems laboratory presented in Figure 1 [25-26].

4. Control strategies of DER components in a distribution network

As a part of the power system, the low-voltage distribution grid has the objective to provide energy to the end consumer.

A major objective in a distribution network is to control the voltage due to a large number of factors, such as various load profiles and load types or due to a different number of phases (asymmetrical distribution of DERs in the network).

In Figure 8 a) is depicted the configuration of the consumers along a feeder in a distribution network with a voltage profile increasing or decreasing in function of the number of active loads (including EVs) and PV systems connected to the distribution network along the feeders.

Figure 8. a) Voltage profiles in a low-voltage distribution grid with b) DER components used in this study.

Due to the PV penetration the voltage along the feeders could increase over the admissible limits defined by standards. Also, due to the EVs connected along the feeders the voltages can decrease exceeding the minimum level. In this case a local voltage controller using distributed energy storage and/or a local voltage controller by load shifting could be an option.

Three types of controllers for voltage regulation have been developed and implemented in MATLAB/Simulink and DIgSILENT PowerFactory, for controlling the bus-bar voltage at the connecting point.

One of them is based on local control by load shifting and two of them are controlling the voltage with the help of energy storage systems.

4.1. Voltage control by load shifting

The ability to control active units (only Flex House heaters in our case) will decrease the tension on the low-voltage distribution network by consuming locally the PV production. The energy management systems of the smart houses, such as the SMA Sunny Home Manager [17], can raise the contribution of PV energy being consumed at the distribution customer's site. Therefore decentralized consumption is raised and the stress and losses in the grid are decreased.

4.1.1. Implementation

To test the voltage controller the Flex House has only been connected with the PV system at the same bus-bar, as was shown in Figure 8b).

The simulation model of the intelligent office building, called Flex-House, is based on the equivalent electro-thermal model of the building, presented in (Figure 4) using a stochastic discrete-time linear state-space model (1) combining with physical knowledge regarding heat transfer inside the house together with statistical methods to estimate model parameters [13]-[15], [26].

The model contains 2 subsystems, a thermal model of the building and a voltage controller model. A module to read input data and a load connected to the power system is also included. The input values are measured ambient temperature and solar irradiation. Figure 9a) shows the block diagram of the building model implemented in MATLAB&Simulink with details about the voltage controller implementation using stateflow chart, presented in Figure 9b).

b)

Figure 9. a) Implementation of the Flex House simulation model with voltage controller using stateflow chart and b) details about voltage controller implementation.

The voltage controller was developed using a state flow chart, which is an interactive graphical design tool for developing and simulating event driven system based on finite-state machine theory. It is a thermostatic control for the building, so that when the temperature inside the building is below a certain set point the heaters in the building turn on, and when the temperature is above another set point the heaters turn off.

4.1.2. Simulation results versus measurements

Figure 10 point out the simulation results with a comparison between normal operation (Figure 10 a), when the voltage control is not activated, and the situation when the voltage at the local bus-bar is controlled using the load shifting (Figure 10 b) by consuming the PV energy production. The voltage was kept under a certain level (1.04 in this case) when the PV production grows, increasing the heaters power (FH power) and doing that the inside temperature of the house. As was shown in Figure 10 b) when the power production increased more heaters were switched on by the local controller and the inside temperature was increased from 21 °C to 27 °C.

To validate the local voltage controller in Figure 10c) it is shown an experimental test using the distributed power system laboratory presented in Figure 1, when the PV system was connected to the grid together with the Flex House.

The parameters which were monitored are heaters output power, the temperature inside the office building and the voltage, which was measured at the bus-bar where the Flex House was connected. As was shown in Figure 10c), when the voltage overtaken the maximum value, set it up at 398 V in this case, the local controller reacts by modifying the heaters power, and implicitly the inside temperature of the house.

The events that point out the state transitions are marked with colored circles. The marks in the first graphic correspond to the local controller response and are the effect of the voltage limit intersection with the voltage at the bus-bar. This voltage is also plotted in the third window. The red circles point out the events when the bus-bar voltage increases to the upper limit, while the blue circles show the events when safe voltage limits are touched and the local controller turns back to the control state. Finally, the green circles show the events when the lower voltage boundary is touched.

a)

b)

Figure 10. a) Normal operation without any control versus b) local voltage control by load shifting, and c) voltage controller validated by measurements using the distributed power system lab from Figure 1.

4.2. Voltage control using battery energy storage systems

4.2.1. Implementation

Two voltage controllers have been developed and implemented based on finite state machine for controlling the bus-bar voltage at the connecting point (Figure 11).

An overvoltage controller, able to charge the battery when the bus-bar voltage exceeds the limits (Figure 11b), and a voltage controller able to set-up the battery to run in schedule mode (Figure 11c), have been implemented in MATLAB/Simulink and DlgSILENTPowerFactory.

The first controller adjusts the voltage at the bus-bar charging the battery when an overvoltage is detected. That means the voltage is adjusted at the bus bar when exceeds the maximum value (set-up here at $1.1 U_n$), due to the PV production, modifying the state of the battery (discharging/charging).

Only when an over-voltage is detected the controller will modify the charging state of the battery.

Another method of controlling the voltage with the help of storage energy systems it is to set the EV to run in schedule mode. That means the battery is scheduled to operate during the day in function of the weather conditions, such as PV penetration. This control method doesn't require any voltage measurements on the bus-bar, but it has to be appropriately scheduled for charging with the right amount of energy in the middle of the day.

a)

Figure 11. a) Implementation of the EV model with the voltage controller, b) voltage controller developed in state flow for over-voltage control and c) EV controller implementation using schedule mode.

4.2.2. Simulation results

This section shows two study cases with PV production for 1 week. The PV system is connected together with the Smart-House at the same bus-bar, whilst the battery energy storagesystem is connected to a different bus-bar at the same distribution network, as can be seen in Figure 12 a). Due to the PV penetration, voltage at the bus-bar will exceeds the upper acceptable value (set-up at 1.1 in this case regarding European norm EN 50160). Integration of energy storage systems in distribution network to store excessive energy can be a solution to alleviate the over-voltage problem.

Figure 12 b) shows the case when the voltage controller (presented in Figure 12 b)) is employed. The EV's operation here is outlined as using the voltage control during the day, when the PV system is producing the power. The EV battery system is connected to the network only when an over voltage exists and it consumes the surplus active power until the power injected into the grid is not affecting the voltage to the bus-bar, exceeding the voltage limit, as can also be seen in Figure 12 b).

In Figure 12 c) is shown the simulation results for another case when the voltage is controlled by a static battery storage system (VRB system in our case), arranging the battery to work in scheduling mode. The VRB was programmed to operate (charged) between 10-18 o'clock during the day, when the PV systems produce the active power, and has been discharged during the night, operating in an efficient way. The drawback of this case is that the VRB has to be suitably scheduled of charging itself with the appropriate amount of energy in the daytime.

a)

b)

Figure 12. a) Simulation results for normal operation, b) with over voltage control and c) with EV battery control in schedule mode.

5. Conclusion

In this paper we have described the development of simulation tools for DER components in a distribution network. The main focus was on modeling and implementation of the model components and systems with voltage controllers using a smart-house load shifting and using energy storage systems (EV battery), as well, for PV penetration.

The simulation models were elaborated to simulate and test the growth PV production effects on voltage variations in a distribution network. Another objective has been to use it in simulating distribution system power constraints and methods for assisting high load cases.

The PV, Flex-House, VRB system and EV battery system simulation models have been implemented in two software packages, MATLAB/Simulink and DIGSILENT Power Factory, taking into accounts the characteristics, the efficiency and also the power losses of their components.

The models have been validated using measurements from a dedicated power system research lab with real components.

Comparison with experimental data, acquired using the SCADA system and processed in MATLAB, has shown that the models can be an accurate tool for prediction of energy production with Intelligent Houses and Battery Energy Storage Systems, as well.

Three types of voltage controllers have also been developed and implemented, using a state flow chart and a PI controller, based on finite-state machine. A voltage controller using load shifting (active units), an overvoltage controller, able to charge the battery when the bus-bar voltage exceeds the limits, and a voltage controller able to set-up the battery to run in schedule mode. In the case of the former, the EV battery is connected to the distribution network only when an over voltage appears and consumes the surplus active power until the power injected into the network is not causing the bus voltage to overtaken the limit. It means that the battery requires fewer charging/discharging cycles, leading to increased battery life.

Simulation results and experiments have shown that the controllers have been designed and implemented successfully.

As a future work we will try to develop and implement a coordinated control of DER components to improve the voltage profile of the distribution network.

Author details

Lucian Mihet-Popa^{1*} and Voicu Groza²

*Address all correspondence to: lucian.mihet@upt.ro; groza@site.uOttawa

¹ Politehnica University of Timisoara, Department of Electrical Engineering, Romania

² University of Ottawa, Department of Information Technology and Engineering, Canada

References

- [1] K. Richardson, D. Dahl-Jensen, J. Elmeskov, C. Hagem, J. Henningsen, J. A. Korstgard, N. B. Kristensen, P. E. Morthorst, J. E. Olesen, and M. Wier, "Green energy - the road to a Danish energy system without fossil fuels," Danish Commission on Climate Change Policy, 2010.

- [2] "Smart Grid i Danmark", joint report by energinet.dk and DanskEnergi, September 2010.
- [3] X. Liu, A. Aichhorn, L. Liu and H. Li, "Coordinated control of distributed energystorage system with tap changer transformers for voltage rise mitigation under high photovoltaic penetration", IEEE Transactions on Smart Grid, Vol. 3, No. 2, June 2012, pp. 897-906.
- [4] European Commission Draft, "Energy 2020-A strategy for competitive, sustainable and secure energy", Brussels, September 2010. [Online]. Available: <http://eur-lex.europa.eu/LexUriServ/LexUriServ.do?uri=COM:2010:0639:FIN:EN:PDF>.
- [5] Y. Riffonneau, S. Bacha, S. Barruel and S. Ploix, "Optimal Power Management for grid connected PV Systems with batteries", IEEE Transaction on Sustainable Energy, vol. 2, no. 3, pp. 309-320, July 2011.
- [6] H. Jiayi, J. Chuanwen, and X. Rong, "A review on distributed energy resources and Micro Grid", ELSEVIER Renewable & Sustainable Energy Reviews, vol. 12, pp. 2472-2483, 2008.
- [7] P. C. Loh, L. Zhang and F. Gao, "Compact integrated energy systems for distributed generations", IEEE Transactions on Industry Electronics, Vol. 5, May 2012.
- [8] "Smart Grid: Reinventing the Electric Power System", IEEE Power & Energy Magazine, March 2012.
- [9] A. Timbus, M. Larsson and C. Yuen, "Active Management of Distributed Energy Resources Using Standardized Communications and Modern Information Technologies", IEEE Transactions on Industrial Electronics, Vol. 56, No. 10, October 2009, pp. 4029-4037.
- [10] J.C. Vasquez, R.A. Mastromauro, J.M. Guerrero and M. Liserre, "Voltage Support Provided by a Droop-Controlled Multifunctional Inverter", IEEE Transactions on Industrial Electronics, Vol. 56, No. 11, November 2009, pp. 4510-4519.
- [11] P. Palensky and D. Dietrich, "Demand Side Management: Demand Response, Intelligent Energy Systems, and Smart Loads", IEEE Transactions on Industrial Informatics, Vol. 7, No. 3, August 2011, pp. 381-388.
- [12] T. Strasser, F. Andren, F. Lehmann, M. Stifter, P. Palensky, "Online Reconfigurable Control Software for IEDs", IEEE Transactions on Industrial Informatics, Vol. 9, No. 3, August 2013, pp. 1455-1465.
- [13] A.D. Hansen, P. Sorensen, L.H. Hansen, H. Bindner, "Models for a Stand-Alone PV System", Risoe National Laboratory, Roskilde, Risoe-R-1219 (EN) / SEC-R-12, Dec. 2000.
- [14] H. Bindner, C. Ekman, O. Gehrke and F. Isleifsson, "Characterization of Vanadium-Flow Battery", Riso-R-1753 Report, Roskilde, Denmark, October 2010.

- [15] W. Wang, B. Ge, D. Bi and D. Sun, "Grid-Connected Wind Farm Power Control using VRB-based Energy Storage System", *IEEE Transaction on Energy Conversion*, pp. 3772-3777, 2010.
- [16] A. C. Hill, M. C. Such, D. Chen, J. Gonzalez and W. M. Grady, "Battery energy storage for enabling integration of distributed solar power generation", *IEEE Transactions on Smart Grid*, Vol. 3, No. 2, June 2012, pp. 850-857.
- [17] L. Barote, R. Weissbach, R. Teodorescu, C. Marinescu, M. Cirstea, "Stand-Alone Wind System with Vanadium Redox Battery Energy Storage", *IEEE International Conference on Optimization of Electrical and Electronic Equipments, OPTIM'08*, pp. 407-412, 22-24 May 2008, Brasov, Romania.
- [18] C. Blanc, A. Ruffer, "Multiphysics and energetic modeling of a vanadium redox flow battery", in *Proc. of IEEE International Conference on Sustainable Energy Technologies (ICSET)*, November 24, 2008, pp. 696-701.
- [19] F. Baccino, S. Grillo, M. Marinelli, S. Massucco and F. Silvestro, "Power and energy control strategies for a vanadium redox flow battery and wind farm combined system", in *Proc. of IEEE Power Engineering Society Conf. and Exhibition on Innovative Smart Grid Technology (ISGT Europe)*, December 5, 2011, pp. 1-8;
- [20] J. Chahwan, C. Abbey and G. Joos, "VRB modeling for the study of output terminal voltages, internal losses and performance", in *Proc. of IEEE Canada Electrical Power Conference (EPC)*, 2007, pp. 387-392.
- [21] S. Teleke, M. E. Baran, A. Q. Huang, S. Bhattacharya and L. Andersen, "Control strategies for battery energy storage for wind farm dispatching", *IEEE Transactions on Energy Conversion*, Vol. 24, No. 3, September 2009, pp. 725-732.
- [22] Z. Feng, W. Ke, C. Jianye and Z. Hua, "Control strategy for vanadium redox battery inverter in islanding microgrid", *Advanced Materials Research Journal*, Vol. 8, pp. 5794-5800, Switzerland 2012.
- [23] C. Blanc and A. Rufer, "Optimization of the operating point of a vanadium redox flow battery", in *Proc. of IEEE Energy Conversion Congress and Exposition (ECCE) 2009*, San Jose, CA, 20-24 September, pp. 2600-2605.
- [24] F. Marra, Y. T. Fawzy, T. Buló and B. Blazic, "Energy storage option for voltage support in low-voltage grids with high penetration of photovoltaic", in *Proc. of 3rd IEEE PES Innovative Smart Grid Technologies (ISGT)*, Berlin, December 2012.
- [25] L. Mihet-Popa, C. Koch-Ciobotaru, F. Isleifsson and H. Bindner, "Development of tools for simulation systems in a distribution network and validated by measurements", *IEEE International Conference on Optimisation of Electrical and Electronic Equipment, OPTIM 2012*, May 24-26, Brasov-Romania, pp. 1022-1031.
- [26] L. Mihet-Popa, C. Koch-Ciobotaru, F. Isleifsson and H. Bindner, "Development of tools for DER Components in a distribution network", in *Proc. of the 20th International*

al Conference on Electrical Machines, IEEE ICEM 2012, September 2-5, Marseille-France, pp. 1022-1031.

- [27] C. Koch-Ciobotaru, L. Mihet-Popa, F. Isleifsson and H. Bindner, "Simulation Model developed for a Small-Scale PV-System in a Distribution Network", in Proc. of the IEEE 7th International Symposium on Applied Computational Intelligence and Informatics-SACI 2012, Timisoara-Romania, May 24-26, pp. 257-261.
- [28] Y. Zong, L. Mihet-Popa, D. Kullmann, A. Thavlov, O. Gehrke and H. Bindner, "Model Predictive Controller for Active Demand Side Management with PV Self-Consumption in an Intelligent Building", in Proc. of IEEE PES Innovative Smart Grid Technologies Europe (ISGT), Berlin-Germany, October 14-17, 2012.
- [29] Y. Zong, D. Kullmann, A. Thavlov, O. Gehrke and H. Bindner, "Application of Model Predictive Control for Active Load Management in a Distributed Power System with High Wind Penetration", IEEE Transactions on Smart Grid, Vol. 3, No. 2, June 2012, pp. 1055-1062.
- [30] L. Mihet-Popa, O.M.F. Camacho and P.B. Norgard, „Charging and discharging tests for obtaining an accurate dynamic electro-thermal model of high power lithium-ion pack-system for hybrid and EV applications“, in Proc. of the IEEE PES Power Tech Conference, Grenoble, June 16-20, 2013.