We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

6,300

Open access books available

172,000

International authors and editors

190M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities

WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com

A Recent Review in Performance of Organic Rankine Cycle (ORC)

Syamimi Saadon and Salmah Md Saiful Islam

Abstract

Increasing emissions of carbon dioxide and fuel prices lead to extra efforts in finding solution to reduce the environment waste heat. One of the solutions emerging is the organic Rankine cycle (ORC) system. It is one of the promising exhaust heat recovery technologies which is widely been used to recover low to medium-grade heat rather than conventional steam Rankine cycle system. This chapter highlights on the different conditions and configurations of ORCs that are usually been applied. These different configurations have different constraints and usually will be considered based on the applications.

Keywords: organic Rankine cycle, preheater, supercritical, superheating, waste heat recovery

1. Introduction

As higher efficiency of industrial technology is in demand, more and latest technologies are needed to produce energy. Increasing of population growth [1] and escalating process of electricity are mostly due to emission gases from the industry, vehicles, deforestation and others. In the aerospace industry, engineers continuously search for new methods to upgrade the efficiency of the engines. Recovery waste heat could increase the engine efficiency [2]. Although society undergoes global issues, social problems or economy crisis, this does not stop aerospace industry from expanding which leads to increase in demand on aircraft. This results in increasing of fuel price since more conventional fuel is needed and causes pollution into the environment [3]. Still, the price in this development is used to optimize the engine. In each flight, greater revenue could be achieved when the number of passengers is greater. And to have more passengers, lighter aircraft is needed. It is important to note that weight is very crucial in changing aircraft engines as it connects linearly with the amount of fuel used in every unit of force powered by engine (specific fuel consumption). Waste heat recovery (WHR) is one of the most important solutions found to lower the emission and fuel consumption [4]. Waste heat or low-grade waste heat is heat energy produced in the atmosphere through internal combustion. However, these low-grade waste heat are not sufficient enough to generate power due to insufficient low temperature. Thus, to recover these waste heat, organic Rankine cycle (ORC) system is one of the beneficial exhaust heat recovery technologies which is widely utilized in the applications of low grade heat recovery rather than conventional Rankine cycle [5]. By combining an ORC with energy system, for instance in power plants, organic fluid of low boiling point is

utilized to change heat into electricity. The organic fluids or refrigerants used in air conditioning systems accumulates (collect) heat from a volume of air and release it to different type of heat exchanger which increases the expansion of high vapor pressure in expander. The heat accumulated is transformed into mechanical power or electricity and therefore will help to increase the thermal efficiency and the overall performance of the engine. Thus, higher thrust could be obtained as less electrical power is needed from aircraft engine resulting lower engine bleed air [2, 5, 6]. Because of its thermodynamic properties, organic fluid is the best selection for low quality heat sources with temperatures below than 100°C [2]. By selecting proper working fluid for low waste heat recovery system and modeling an optimum design of heat exchanger configurations, the waste energy recovered through this ORC system could be maximized. Thus, designing a fuel-efficient and cheaper heat exchanger, ORC power plant can effectually utilize the economic and environmental issues especially in aerospace industry.

2. Aspects of recovery waste heat systems

Based on second law of thermodynamics, the efficiency of a process would not be 100% as there is no process that can entirely transform all amount of heat into work. The energy that is not used to produce work is being dissipated as heat at different temperatures, levels streams. On aircraft, half of the fuel energy lost through this way. Nevertheless, these sources of waste heat are everywhere; from this lost energy, only a part of it can be used to produce mechanical work or other purposes, where around 30% of the total waste heat could be changed to useful work. As the demand of aircraft is increasing vastly, the aviation industry has been the world center of attraction as new technologies are needed and maximum exploitation of fuel is a must. The conversion of heat energy to mechanical or electrical power depends on the characteristics of the source. Let say in an air conditioning system, an external hose is two or three degrees above the ambient temperature, it is a waste to recover that little amount of energy, however, this power leak will be an irreversibility process together with other similar leaks will decrease the thermal efficiency. This is called as waste heat and is an unused heat energy produced as a by-product of process of energy transformation, as a natural consequence on any non-adiabatic process from the thermodynamics law. Most of the available waste heat is low waste heat that can be used by an ORC which utilizes low boiling point organic fluid as working fluid, for example, toluene, hexane or pentane. Presently, there has not been any waste heat recovery (WHR) system added to an aircraft. Nevertheless, researchers suggest on adding WHR system to future engines and propose to make changes in current engines. However, it is a hassle to change the actual design of the engine as more expenses will be used in research, tests and certifications and a lot of heat source needs to be taken into account. Pasini et al. [7] analyzed the possibilities of heat recovery results in overall efficiency of an aircraft engine. A waste heat recovery system is modeled in a jet engine and a turbo propeller engine. Their project takes into account the nozzle works in off design state. The heat emitted influences greatly in the system performance. They also developed a numerical thermodynamic code to evaluate the positive impacts of waste heat recovery in a turboprop, a turbofan and a turbojet. The turbofan engine is of great interest due to large fraction of thrust is provided by cold flow, whilst gas generator supplies needed power. The authors then concluded that the enthalpy level ahead of exhaust nozzle of gas generator could be decreased without losing a lot of thrust. From the results of the calculations, it was found an increase of thermal efficiency about

4% when heat recovery was done (efficiency of regeneration was 0.5). At the same time, if the efficiency was 0.7, an increase of 10% was achieved. From the numerical simulations, the best place for heat recovery is from hot gas before entering nozzle. Another research done by Li et al. [8] was to study the small-scale ORC system performance with low grade heat sources to provide electricity in various working state. The experiment setup includes normal ORC system components, for instance, turboexpander with high speed generator, finned tube condenser, ORC pump and plate evaporator. Results found that the turbine power and condenser heat output, ORC pump power and evaporator heat input, turbine isentropic, overall efficiencies and system thermal efficiencies rises when heat source temperature rises too. The fluid of ORC during superheat and pressure at turbine inlet were two crucial variables that kept constant with temperature heat source and pump speed of ORC.

2.1 Organic Rankine cycle

ORC utilizes organic compound instead of water as a working fluid, generally, a refrigerant, a hydrocarbon such as pentane, butane, perfluorocarbon or silicon oil. The organic fluid's boiling point is much lesser compared to water and enable heat recovering at lesser temperatures instead of the steam Rankine cycle [9]. ORC's first commercial applications with medium-scale power plants for geothermal and solar applications were developed in the late 1970s and 1980s. These days, over 200 ORC power plants are recognized with more than 1800 MWe installed and the technologies keep on increasing day by day [10]. Mostly, the plants were installed in biomass CHP application, geothermal plants and plants of WHR followed. The layout of ORC is much simpler compared to the steam cycle as there is no water vapor attached to the boiler, and a single heat exchanger could be utilized for the three processes of evaporation including preheating, vaporizing and superheating. ORC is able to use low grade heat sources than steam Rankine cycle. Since it could be utilized in lower temperature at the turbine inlet and reduce thermal stresses in the boiler. In regular steam plant systems, the performance cycle is at risk damage due to gaseous infiltrations that occur in sub atmospheric condensing pressure. In steam-based cycle, the usage of a single tube for evaporation is abstained due to large density difference that exists in between liquid and vapor phases. However, some organic fluids have condensation pressure higher than the atmospheric pressures and this avoids the infiltration of non-condensable gases in the condenser. The small differences in density organic fluid phase of liquid and vapor also enables the use of once-through boilers. This led to avoidance of using steam drums and simplified the operation of the whole plant. A simple plant system can be developed and less cost is needed when uses organic fluid compared to steam based cycle. In ORC, usage of deaerator is unnecessary but that is not the case for steam base cycle. Due to presence of oxygen, water deaerator or water treatment must be added to avert erosion. Because of low fluid density in the cycle low-pressure part, steam cycle also needs large turbines, heat exchangers and hydraulic diameter for pipes. Meanwhile, since organic fluid has higher density fluid, usage of compact appliances is allowed, especially in marine application, the available space for recovery plant of waste heat is restricted. Other than that, the enthalpy drop in ORC is much lower compared to steam cycle. The process in ORC can be done in a single stage with much simpler turbine compared to steam cycle which requires turbine with some expansion stages. ORC normally operated at much lower pressure levels and rarely exceeding 30 bars. Thus, ORC is beneficial in low to medium power range due to its cycle simplicity, less cost and stress level needed at boiler, easier to control and simpler usage of components [11].

2.1.1 Difference between steam Rankine cycle and organic Rankine cycle

Traditional steam Rankine Cycle utilizes water and higher pressure vapor as the main flow fluid in the cycle and mainly used in high temperature more than 500°C. However, ORC uses organic pure less boiling point or working fluid mixture mostly used in lower temperature process less than 500°C. Thus, ORC is more advantageous in recovering less temperature heat energy for various temperature ranges. Although steam Rankine cycle is the most common technology used in recovering heat process that converts heat into electricity, it is unfit for conditions of low temperature and pressure. This results from the need for high temperature and pressure in operation. If exhaust temperature and pressure are similar, the SRC exhaust steam enthalpy is greater and the heat from the cold sources increases [12].

Based on the **Figure 1** which is the T-s diagram above, two important differences could be found. Firstly, the curve of the organic fluid is abundantly vertical, meanwhile, water has negative curve of saturated vapor slope. Hence, when process of expansion finish, the limitation of vapor quality invisibles in ORC cycle and superheating vapor is unnecessary before the turbine inlet. Second, the gap in entropy between saturated liquid and saturated vapor for organic fluids is lesser. Thus, the enthalpy vaporization is lesser. The organic working fluid mass flow rate should therefore be greater than water to absorb equal thermal power in the evaporator, resulting in more pump consumptions [13].

2.1.2 Supercritical organic Rankine cycle

ORC can be operated in a subcritical or supercritical cycle. In supercritical cycle, the working fluid evaporation ends in supercritical area and the heat rejection in condenser occurs in the subcritical area. Many studies have been performed on the supercritical ORC. **Figure 2** provides the temperature and entropy changes of supercritical ORC.

Yagli et al. [14] modeled subcritical and supercritical ORC to recuperate exhaust gas waste heat of biogas fuelled CHP engine. Comparing with subcritical condition,

Figure 1. T-s diagram of the water saturation curves of water and a few typical ORC organic fluids applications [13].

Figure 2.
 Supercritical ORC temperature and entropy change [14].

supercritical ORC shows greater performance. At constant pressure, supercritical ORC performance rise as turbine inlet temperature rises. The most excellent performed cycle net power, thermal efficiency and exergy efficiency are evaluated as 79.23 kW, 15.51 and 27.20% for subcritical and 81.52 kW, 15.93 and 27.76% for supercritical ORC, respectively. Guo et al. [15] studied the subcritical and transcritical ORC performance in regards to the evaporator pinch point locations. Found that transcritical ORCs gives higher performance as the heat source outlet temperatures lessen. Ran et al. [16] studied the impact of big transformation in the thermophysical properties of pseudocritical region. Utilizing network output, thermal efficiency and total vapor area an optimization method was found. The results showed that in transcritical ORC's, the thermophysical properties of the working fluid work at supercritical coefficient and logarithmic mean temperature difference (LMTD). Moloney et al. [17] analyzed the pressure effect to optimize the first law efficiency, second law's efficiency and net power of a supercritical ORC with 170–240°C turbine inlet temperature suitable for geothermal reservoirs of medium temperature. Found that supercritical cycle is much more efficient than subcritical cycle to optimize the plant efficiency. Chowdury et al. [18] presented an ORC simulation with different source of heat from the actual vehicle exhaust in supercritical state. The simulation shows that the key in transforming the operating temperature at the evaporator outlet is to modify the mass flow rate.

2.1.3 Application of organic Rankine cycle

The ORC technology has been utilized broadly and applied in various industrial activities especially in biomass and geothermal application. Nevertheless, ORC technology has been increasing in solar thermal system and heat recovery applications from industrial waste heat.

2.1.3.1 The combined heat and power (CHP) of biomass

There is widespread use of agricultural or industrial processes such as lumber or agricultural waste in biomass due to low energy density than the fossil fuels

and availability of heat and electricity, where biomass is suitable on off-grid case or unreliable grid connection. Local generation results in smaller power plants that exclude traditional steam cycles that in this power range are not profit-making.

Figures 3 and 4 define the working principle of such cogeneration system, at a temperature from 150 to 320°C, heats from combustion is transmitted from the flue gases to the heat transfer fluid in two heat exchangers. When temperature lowers a little bit below 300°C, heat transfer fluid (thermal oil) is sent to the ORC loop to evaporate the working fluid. Then, the evaporated fluid expands, to preheat the liquid using recuperator and when temperature reached 90°C, the fluid condensed to produce hot water.

ORC efficiency is lesser compared to traditional steam cycles and gradually reduces for small scale units. To raise the overall energy conversion efficiency of plant, heat demand is needed and could be met through space heating or industrial processes (wood drying). Load of plant could be managed through on- site heat request or maximize power generation which includes additional wasting heats but increases, the full load operating hours per year.

From **Figure 3**, even though the CHP system's electrical efficiency is somewhat less (18%), the overall system efficiency is 88% greater than centralized power plants where most residual heat is lost. These gases need to be cooled to the least possible value, so that acid dew point could not be achieved and to lower the losses in flue gases. Two heat transfer loops are utilized to achieve this point (high and low temperature). The lower temperature loops are installed after the high flue temperature to lower the outlet temperature. Competitive technology in generating electric out of solid biofuels is biomass gasification where biomass changes into an organic gas mainly consisting H_2 , CO , CO_2 and CH_4 . In order to remove solid particles, this synthetic gas is treated and filtered and finally burned in an ICE or in a gas turbine. Contrasting Biomass CHP's technology and costs with an ORC with gasification, gasification yields higher investment costs (75%), higher maintenance costs (200%) and more power-to-thermal ratio, where utilization is increase profit-making. ORC is an established technology meanwhile gasification plants are normally used as prototype in operation.

Figure 3.
Energy flows in a CHP system of biomass [13].

2.1.3.2 Geothermal energy

Geothermal heat sources ranges from 10 to 300°C. The actual lower technological limit to generate electricity is about 80°C, and became less efficient with temperature less than 80°C and causes uneconomical geothermal plants. The potential of geothermal energy in Europe is shown in **Table 1** and indicates that low temperature sources have higher potential.

For better production and injection, boreholes need to be drilled in the ground (**Figure 5**) to recover heat at an acceptable temperature. Then, the hot brine is pumped out of the first one and injected at a lower temperature in the second. Boreholes might be few thousand meters deep which results in working continuously for few months depend on the configuration of the geology and causes increasing share of drilling for geothermal plant cost investment (up to 70%) [19]. High auxiliary consumption is also characterized by low geothermal ORC: the pumps ingest 30–50% of the gross power output [20]. The brine pump together with a significant flow rate has to circulate the brine over large stances is the primary consumer. Working fluid of pump consumption is greater than higher temperature cycles, as the ratio of pump consumption to turbine output power

Figure 4.
Biomass CHP ORC system working principle [13].

Temperature	MWth	MWe
65–90°C	147,736	10,462
90–120°C	75,421	7503
120–150°C	22,819	1268
150–225°C	42,703	4745
225–350°C	66,897	11,150

Table 1.
Geothermal energy potential in Europe for different temperature ranges of heat sources [19].

Figure 5.
Geothermal ORC system working principle [13].

(‘back work ratio’) rose as evaporation temperature lowered. Geothermal heat sources temperature ($>150^{\circ}\text{C}$) allow for CHP, where the condensing temperature is restricted to a higher temperature such as 60°C , enabling district heating uses cooled water. Thus, the overall efficiency of energy recovery rises with lower electrical efficiency expenses.

2.1.3.3 Solar power plants

Solar power concentration is the best technology on a linear or punctual collector that tracks and reflects the sun, transferring heat to high temperature fluid. Electricity is generated as heat is transmitted to a power cycle; electricity is generated. The three primary technologies of concentration are the parabolic platform, solar tower and the parabolic trough. Punctual concentrating technologies consist of parabolic dishes and solar towers, results in more concentration factor and greater temperatures. For solar towers, the Stirling engine (small-scale plants), the steam cycle or even the combined cycle is the best suited power cycles. Parabolic troughs operate at lesser temperature ($300\text{--}400^{\circ}\text{C}$). Till today, they were combined to traditional steam Rankine cycles to generate electricity [21]. Geothermal or biomass power plants for example, steam cycles need higher temperatures, pressure and installed power to be more cost-effective. Organic Rankine cycle is a favorable technology that could lower the small scale of investment costs by working at lesser temperatures and reduce total installed power to kW scale. The working principle of the system is shown in **Figure 6**. As Fresnel linear technology need lower investment costs [22], they are suitable for ORCs but operate at lesser temperature.

Till recently, only a few of CSP plants with ORC are accessible on the market:

- In 2006, at Arizona, a 1MWe solar concentration of ORC power plant was accomplished. The ORC module utilizes n-pentane as the working fluid with 20% efficiency. On design point, the overall solar energy efficiency is 12.1% [23].
- Few small-scale for the applications of remote-off grid were studied. The only proof of concept obtained is that 1KWe system installed for rural

Figure 6.
 Solar ORC system working principle [13].

electrification in Lesotho by “STG International”. To produce and integrate small size solar thermal technology with medium temperature collectors and an ORC to acquire economics equivalent to big installation of solar thermal is the objective of this project. This design intended to change or adding diesel generators in developing countries at off-grid areas through generating clean power at lesser costs.

2.1.3.4 Mechanical and industrial heat recovery

At low temperature, most of the application in manufacturing industry reject load. Normally, the heat is enormous in large-scale plants, and could not be used again for on-site district heating. The heat then discharged into the atmosphere and results in two types of pollution [24]:

- Health/Environmental issues results from pollutants (CO_2 , NO_x , SO_x , HC) of flue gases.
- Unbalance of aquatic equilibrium and negative effector biodiversity due to rejection of heat.

These two types of pollution could be diminished by waste heat recovering. Moreover, it could provide on-site electricity to be consumed or sent it back to the grid. Normally, waste heat is recuperated through an intermediate heat transfer loop in such a system and used to evaporate the cycle’s working fluid. In USA, power generation from industrial waste heat sources is approximately about 750 MWe [25]. Some industries have greater potential in recovery of waste heat. One of it, the cement industrial loses 40% of flue gas heat. These flue gases are placed at a temperature of 215–315°C after the preheater of limestone or in the clinker cooler [26]. CO_2 released from the cement industry is 5% of the world’s total CO_2 emissions, half of the results from fossil fuels combustion in kilns [24]. Further possible industries include iron and steel industries (for example, 10% of CO_2 emissions in China),

refineries or chemical industries. Although their potential is higher and cost-effective (1000–2000 €/kWe), ORC recovery waste heat cycles have only 9–10% of the world's installed ORC plants compared to biomass CHP and geothermal units [10].

2.1.3.5 Aircraft engine

Perullo et al. [27] integrated an ORC to an engine for power generation. They mentioned the problem, as bypass ratio keep on growing and the engine cores becomes effective, the diameter of engine fan increases and the core size decreases which causes pneumatic offset needing greater percentage of the core flow and results in higher performance penalties. They tried to solve the problem by changing the pneumatic off-take to an electrical and used power generated to drive external air to the environmental control system (ECS). With the idea of no-bleed aircraft, performance penalties for shrinking cores and increased fan diameter are supposed to be eliminated and they had demonstrated that a rise in efficiency from 0.9 to 2.5% is possible. Boeing has also applied the no-bleed system; but using generator as the source of energy, not ORC where the generator works with energy taken from the APU and engines. As this application save fuel by 3%, this explain why they put this idea together in ORC rather than extracting energy from fuel, the waste heat could supply the energy needed. ORC is used due to the low quality of the range temperature. The WHR system is placed in the core jet exhaust of a turbofan engine. Conversely to land ORC systems, used in steam power plants for instance, an on-board ORC would suppose operating conditions that may vary continuously in the course of every few hours in external pressure and temperatures. The amount of heat extracted from the engine should be considered to avoid reduction of thrust. The system is distributed in the nozzle, the nose cowl and the Pylon. It uses R245fa as the working fluid having demonstrating highest thermal efficiency in a wide range of operating pressure. The MathCAD 2001 software was used to model the design to govern whether energy is enough to extract our f the exhaust gases to a power of 270 hp. motor. **Figure 7** below describes the ORC schematics.

The model was integrated on a CFM56-7B configuration and cruise conditions were used in it. Some assumptions were done; not analyzing the system with take-off conditions as working fluid dissociates at high temperatures, heat is taken out of core exhaust flow before expanding in the nozzle, assuming a weight of 430 kg and was used to calculate the fuel burn reduction (0.9%) a TSFC reduced its value in 2% compared to the engine alone. It was also assumed that the ORC could produce

Figure 7.
Aircraft engine ORC system working principle [27].

greater power which is needed to drive the ECS air compressor and resulted in reduction of TSFC for 22%. Perullo et al. [27] concluded that an ORC WHR system could produce more power on the existing engine and can be utilized to supply sufficient power to a compressor driving air to the ECS. They suggested that the design system should be reconfigured to obtain the best results of fuel burn and take into account the need of an electric starting mechanism if the bleed system was removed in future research. The option of using the engine cowl or the anti-icing system in the wings as the condenser of the ORC system was suggested as well.

2.1.4 Organic Rankine cycle (ORC) with regenerator (RORC)

Regenerative ORCs are designed where ORCs and turbine bleeding are integrated to a heat exchanger. The cycle heats up the working fluid upon infiltrating the evaporator which is almost similar to the ORC with recuperator. **Figure 8(a)** and **(b)** provides the schematic cycle and T-s diagram of regenerative cycle.

At 139°C of turbine inlet temperature, Le et al. [28] utilized a genetic method to optimize the first law and effectiveness of the system for diverse fluids. When examining, CO₂ results the worst while recuperative cycle was discovered for greater efficiencies compared to simple cycle. Moloney et al. [17] studied the environmental fluids with critical temperature below 200°C in regenerative supercritical ORCs to upgrade the geothermal energy efficiency and noted that CO₂ operates the lowest. The same purpose was enforced by Muhammad et al. [29] to the basic ORC; single and double stage regenerative ORC for applications of recovering waste heat. Studies showed that the single and double stage regenerative ORC has greater thermal efficiency with lower economic performance rather than the basic ORC.

2.1.5 Organic Rankine cycle with superheating

Found that superheating of dry fluid negatively affects the ORC's efficiency while wet fluid positively affects the ORC's efficiency and isentropic fluid did not really affect ORC. Nevertheless, an experimental observation by [15] indicated that ORC with wet fluid superheat utilizing R245fa at 1.8°C and if the superheat rises to 8.7°C, the system is stable. Thus, even for dry working fluid, superheating is essential.

Li et al. [30] conducted an experimental study to inquire the performance of a small-scale ORC system with low grade heat source to produce electricity at various

Figure 8.
 (a) ORC with regenerator and its (b) T-s diagram [28].

working state. It was found that the fluid of ORC during superheat and pressure at the turbine inlet were two main variables able to be managed with temperature of heat source and speed of the ORC pump. It was also found that superheat and internal heat exchanger are crucial for ORC from both perspectives of thermodynamic and techno-economic. Roy et al. studied the consequences of superheat and recovering on ORC system at certain degree of superheat [31]. Note that Guo et al. [15] argued if the superheat coupled with an internal heat exchanger, greater development could be done. Zhang et al. inquires the consequences of superheat and internal heat exchanger on three ORC designs' thermos-economic performance from fluid properties and heat sources. It has been discovered that the thermo-economic performance of internal heat exchanger ORC with dry surpasses the wet fluid as temperature of heat source load increases [32]. Brizard et al. [33] suggested preventing condensation drops during operation of superheating; the inlet of expander must exceed 20°C. Radulovic et al. [34] mentioned that superheat is important in cycle especially in wet fluids. As the temperature of superheater rises, the cycle efficiency also rises and the chance of the working fluid condenses during pressure drop inside turbine, resulting in corrosion and efficiency drop is lesser. To get a higher efficiencies and net power output, superheating is important to prevent wet expansion. Feng et al. [35] found that rises the superheat degree assure the decrease in mean heat transfer temperature difference in superheating area of evaporator causes decreasing of overall heat transfer area, and decrease in the investment cost of the system. It was also found that outlet temperature of evaporator and superheat degree gives good feedback on the efficiency of exergy. Li et al. [30] construct an investigation on the experimental of a small-scale ORC system under designated working state for the recovery application of low-grade thermal energy. The reaction between condenser cooling water temperatures and superheat.

R245fa at turbine inlet were measured and analyzed on the performance of the system. The outcomes show that when evaporating pressure is constant, superheat at the inlet of expander gives negative feedback on the turboexpander and performance of the at some temperatures of cold water. In conclusion, superheat is crucial in assuring an efficient and safe system operation. Bianchi et al. [36] presented an experimental micro-ORC setup for low-temperature application by implementing a test bench to acquire data for the energy system characterization. From the results, it was found that for the tested working points, efficiency is from 2.9 to 4.4% and increases as degree of superheating decreases. Ismail et al. [37] concluded that utilizing superheated vapor in the system with internal heat exchanger results in increasing of thermal efficiency ORC. The mass flow rate required for the system together with superheated vapor is lower than the saturated vapor system. Thus, superheated is essential to lower the mass flow rate, and enhanced the performance of the system with presence of internal heat exchanger.

3. Conclusion

This chapter presents a comprehensive review on the developments of organic Rankine cycle (ORC) systems that have been used for power generation by using a waste heat source. This review also highlights more on the different configurations of ORCs used, depending on their applications. From here, we could conclude that superheating and the condition of the organic working fluid are crucial in ORC system from the thermodynamic point of views. Therefore, this study plans to investigate the design of an ORC model with better output power by modifying the configurations and adding a superheating device and also to study the effect of using organic dry working fluid (R245fa) at supercritical condition.

IntechOpen

Author details

Syamimi Saadon^{1,2*} and Salmah Md Saiful Islam¹

1 Department of Aerospace Engineering, Faculty of Engineering, University Putra Malaysia, Serdang, Malaysia

2 Faculty of Engineering, Aerospace Manufacturing Research Centre (AMRC), University Putra Malaysia, Serdang, Selangor

*Address all correspondence to: mimisaadon@upm.edu.my

IntechOpen

© 2019 The Author(s). Licensee IntechOpen. This chapter is distributed under the terms of the Creative Commons Attribution License (<http://creativecommons.org/licenses/by/3.0>), which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

References

- [1] Rusev TM. Comparative Study of Different Organic Rankine Cycle Models: Simulations and Thermo-Economic Analysis for a Gas Engine Waste Heat Recovery Application. 2014;1-77
- [2] Rangel-Martnez D. Assessment of the Integration of an Organic Rankine Cycle for Waste Heat Recovery from Bleed Air for Implementation on Board an Aircraft. Master Thesis. Durham University; 2018
- [3] Mazlan NM, Savill M, Kiporous T. Effects of biofuels properties on aircraft. Emerald Insight. 2015;87(5):393-401
- [4] Baccioli A, Antonelli M. Control variables and strategies for the optimization of a WHR ORC system. Energy Procedia. 2017;129:583-590
- [5] Patel P, Modh J, Patel V. Parametric Analysis of Organic Rankine Cycle (ORC) for Low Grade Waste Heat Recovery. Proceedings of the National Conference on Thermal Fluid Science and Tribo Application TFSTA2016-50. 2016
- [6] Saadon S. Computational modelling of an Organic Rankine Cycle (ORC) waste heat recovery system for an aircraft engine. In: MATEC Web of Conferences, vol. 151, p. 02001. EDP Sciences. 2018;02001
- [7] Pasini S, Ghezzi I, Andriani R, Ferri LDA. Heat recovery from aircraft engine. Energy Conversion Engineering Conference and Exhibit, (IECEC), 35th Intersociety. 2000;6:8
- [8] Li L, Ge YT, Luo X, Tassou SA. Experimental investigations into power generation with low grade waste heat and R245fa organic Rankine cycles (ORCs). Applied Thermal Engineering. 2017;115:815-824
- [9] Shi L, Shu G, Tian H, Deng S. A review of modified organic Rankine cycles (ORCs) for internal combustion engine waste heat recovery (ICE-WHR). Renewable and Sustainable Energy Reviews. 2018;92:95-110
- [10] Enertime, "The organic Rankine cycle and its applications. 2011. Available from: <http://www.cycle-organique-rankine.com>
- [11] Sung T, Kim KC. An organic Rankine cycle for two different heat sources: Steam and hot water. Energy Procedia. 2017;129:883-890
- [12] Zhang X, Wu L, Wang X, Ju G. Comparative study of waste heat steam SRC, ORC and S-ORC power generation systems in medium-low temperature. Applied Thermal Engineering. 2016;106:1427-1439
- [13] Quoilin S, Van Den Broek M, Declaye S, Dewallef P, Lemort V. Techno-economic survey of organic Rankine cycle system. Renewable and Sustainable Energy Reviews. 2013;22:168-186
- [14] Yagli H, Koc Y, Koç A, Adnan G, Tandiroglu A. Parametric optimization and exergetic analysis comparison of subcritical and supercritical organic Rankine cycle (ORC) for biogas fuelled combined heat and power (CHP) engine exhaust gas waste heat. Energy. 2016;111:923-932
- [15] Guo C, Du X, Yang L, Yang Y. Performance analysis of organic Rankine cycle based on location of heat transfer pinch point in evaporator. Applied Thermal Engineering. 2014;62(1):176-186
- [16] Ran T, Qingsong AN, Lin SHI, Huixing Z, Xiaoye D. Performance analyses of supercritical organic Rankine cycles (Orcs) with large variations of the thermophysical properties in the

pseudocritical region. 3rd International Seminar on ORC Power Systems, October 12-14, 2015, Brussels, Belgium. 2015:1-10. Paper ID: 53

[17] Moloney F, Almatrafi E, Goswami DY. Working fluid parametric analysis for regenerative supercritical organic Rankine cycles medium geothermal reservoir organic Rankine cycles for for medium geothermal reservoir temperatures. *Energy Procedia*. 2017;**129**:599-606

[18] Chowdhury JI, Nguyen KB, Thornhill D, Douglas R, Glover S. Modelling of organic Rankine cycle for waste heat recovery process in supercritical condition. *International Journal of Mechanical, Aerospace, Industrial and Mechatronics Engineering*. 2015;**9**(3):477-482

[19] Rentizelas A, Karellas S, Kakaras E, Tatsiopoulou I. Comparative technoeconomic analysis of ORC and gasification for bioenergy applications. *Energy Conversion and Management*. 2009;**50**(3):674-681

[20] Karytsas C, Mendrinou D, Radoglou G. The Current Geothermal Exploration and Development of the Geothermal Field of Milos Island in Greece *GHC Bulletin*. 2004;**25**:17-21

[21] Frick S, Kranz S, Saadat A, Huenges E. Design approach for geothermal binary power. *Plants*. 2009

[22] Müller-steinhausen H, Trieb F. Concentrating Solar Power—A Review of the Technology. Vol. 18. Stuttgart, Germany: Institute of Technical Thermodynamics, German Aerospace Centre; 2004. pp. 43-50

[23] Ford G. CSP: Bright future for linear fresnel technology? *Renewable Energy Focus*. 2008;**9**(5):48-49

[24] Canada S, Cohen G, Cable R, Brosseau D, Price H. Parabolic Trough

Organic Rankine Cycle Power Plant. United States. 2005. p. 5

[25] Bundela PS, Chawla V. Sustainable development through waste heat recovery. *American Journal of Environmental Sciences*. 2010;**6**(1):83-89

[26] Engin T, Ari V. Energy auditing and recovery for dry type cement rotary kiln systems—A case study. *Energy Conversion and Management*. 2005;**46**(4):551-562

[27] Perullo CA, Mavris DN, Fonseca E. An Integrated Assessment of an Organic Rankine Cycle Concept for Use in Onboard Aircraft Power Generation. In *ASME Turbo Expo: Turbine Technical Conference and Exposition* American Society of Mechanical Engineers. 2013

[28] Le VL, Feidt M, Kheiri A, Pelloux-Prayer S. Performance optimization of low-temperature power generation by supercritical ORCs (organic Rankine cycles) using low GWP (global warming potential) working fluids. *Energy*. 2014;**67**:513-526

[29] Muhammad I, Park BS, Kim HJ, Lee DH, Muhammad U, Heo M. Thermo-economic optimization of Regenerative Organic Rankine Cycle for waste heat recovery applications. *An International Journal Energy Conversion and Management*. 2014;**87**(November):107-118

[30] Li L, Ge YT, Tassou SA. Experimental study on a small-scale R245fa organic Rankine cycle system for low-grade thermal energy recovery. *Energy Procedia* *Energy Procedia* 2017;**105**:1827-1832

[31] Roy J, Misra A. Parametric optimization and performance analysis of a regenerative organic Rankine cycle using R-123 for waste heat recovery. *Energy*. 2012;**39**(1):227-235

[32] Zhang C, Liu C, Xu X, Li Q, Wang S, Chen X. Effects of superheat and internal heat exchanger on thermoeconomic performance of organic Rankine cycle based on fluid type and heat sources. *Energy*. 2018;**159**:482-495

[33] Brizard A, Dolz V, Galindo J, Royo-Pascaul L. Dynamic modeling of an organic Rankine cycle to recover waste heat for transportation vehicles. *Energy*. 2017;**129**:192-199

[34] Radulovic J, Benedikt K. Utilisation of diesel engine waste heat by Organic Rankine Cycle. *Applied Thermal Engineering*. 2015;**78**:437-448

[35] Feng Y, Zhang Y, Li B, Yang J, Shi Y. Comparison between regenerative organic Rankine cycle (RORC) and basic organic Rankine cycle (BORC) based on thermoeconomic multi-objective optimization considering exergy efficiency and levelized energy cost (LEC). *Energy Conversion and Management*. 2015;**96**:58-71

[36] Bianchi M et al. Experimental performance of a micro-ORC energy system for low grade heat recovery. *Energy Procedia*. 2017;**129**:899-906

[37] Ismail H, Aziz AA, Rasih RA, Jenal N, Michael Z, Roslan A. Performance of organic Rankine cycle using biomass as source of fuel. *Journal of Advanced Research in Applied Sciences and Engineering Technology*. 2016;**4**(1):29-46